

GLV 005-01

ENPHASE ENERGY

ACB V1.5, I07-Series, S-Series

**C10/26 - DECLARATION OF CONFORMITY for power-generating units
GLV ed2.1.2 (12/2019)**

for the application of annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019)



HOMOLOGATION
LINAET

The undersigned,

Manufacturer: Enphase Energy
Address: 1420 North McDowell Boulevard
Petaluma, CA, 94954
United States of America

Represented by:
Country:
email:
Telephone:

Enphase Energy
Netherlands
dmnchin@enphaseenergy.com
(+31) 20 241 05 98

Hereby declares that each production unit completed in the list in tab 'list of power-generating units' of this homologation application complies with the following conditions:
1. The power-generating unit complies with the relevant requirements set out in annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019).

2. In order to substantiate this, a separate technical file has been submitted at least for each separate product series of the 'C10/26 list of power-generating units' of this homologation application. Each technical file shall be drawn up on the basis of a checklist Annex D, duly and correctly completed by the manufacturer, accompanied by all the required proof of conformity.
2.1. For technical requirements for which the required proof of conformity (column J in checklist annex D) is a declaration of honour by the manufacturer, the manufacturer declares by signing and dating this declaration of conformity the correctness of the information (conform / not conform / not applicable) provided by him or her in columns K, L and M of this checklist.

2.2. For technical requirements for which the required proof of conformity (column J in checklist Annex D) is a test report or a certificate, the necessary test reports and/or certificates are available * in the technical file:

- Certificates have been issued by an EN 45011 (or ISO 17065:2012) certification body accredited for these materials.

- Test reports have been established by an ISO 17025:2005 or ISO 17065:2012 laboratory accredited for these tests.

2.3 A list of the document references or the certificates of conformity referred to in the checklist Annex D is also available in the technical file.



Done at: Melbourne, Australia
On: 18/03/2020

Homologated by Synergrid on: 19/03/2020
Stamp Synergrid & signature:

(stamp manufacturer & signature)
ENPHASE ENERGY

SYNERGRID a.s.p. i.v.z.w.
Galerie Rayensstraat/galerij 4/2
T.V.A./B.T.W. BE 0402.958.091

Homologation period till 01/05/2020 (see exceptions in chapter 3 of C10/11 ed 2.1 (01/09/2019)):
If at the time of submission of this homologation application it is not yet possible to submit all the necessary certificates and/or test reports (exception 3), or that the units do not yet have all the required characteristics (exceptions 1 and 2), a temporary homologation may be granted. All necessary certificates and/or test reports must be in the possession of Synergrid at the latest on 30/04/2020 in order to obtain a final homologation. If this is not the case, the temporary C10/26 homologation will be withdrawn.

11	Additional characteristics	In these columns optional additional characteristics of the units are indicated, following the information in checklist annex D and the corresponding technical file. Put an "X" at each relevant additional characteristic. Note: Only units < 1 MW that are "Type B ready" may be applied in an installation > 1 MW (installation "Type B" according to the European Network Code (ENC). A unit < 1 MW is only "Type B ready" if it complies with all optional or optional-relevant items indicated in column I of the checklist annex D.
12	Limitations	These columns specify limitations of the units to their application in certain types of installations, in accordance with the information in the checklist in annex D and the corresponding technical file. Put an "X" to each relevant limitation
13	Application	Indicate the applications for which the unit is suitable. Indicate an "X" with each application for which the unit can be used
14	Synergist approval date Temporary homologation (expires on 01/05/2020)	Date on which the submitted homologation file was approved for synergist for a limited period of time. A temporary homologation is granted if the applicant provides evidence in chapter 3 of C10/11 and 1.01/09/2019 and has not yet submitted all the test reports required for a definitive homologation with his homologation application (specimens 5), or if the units do not yet have all the required progress reports (1 and 2). The expiry date for a temporary homologation is 01/05/2020 - see conditions in chapter 3 of C10/11 and 2.1.01/09/2019.
15	Synergist approval date Final homologation	Date on which the submitted homologation file was definitively approved by Synergist. A final approval will be granted as soon as Synergist has a fully compliant homologation dossier. A final homologation only remains valid under the following conditions: - No change that has an influence on the initial approval are made to the production of the units. - There is no new edition of the technical file submitted for approval that has been successful. - The validity date of the test report in the technical file submitted for approval is not applicable. (1) See also the general Synergist procedure V101 for homologation of material, which is applicable. (1)

SYNERGRID s.a.s. b.l.-v.z.w.
Galerie Ravensteingalerij 4/2
BE-1000 Brussels/Bruxelles/Brussel
T.V.A./B.T.W. BE 0402.958.091

**FINAL
HOMOLOGATION**