


GLV **013.5** HUawei SUN2000

**C10/26 - DECLARATION OF CONFORMITY for power-generating units**  
GLV **ed2.1.2 (12/2019)**

for the application of annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019)



The undersigned,	Manufacturer:	Huawei Technologies (Netherlands) B.V. Herikerbergweg 36, 1101CM Amsterdam Zuid-Oost, The Netherland	Represented by:	Mustafa Temur Belgium mustafa.temur1@huawei.com 0032 475826664
	Address:		Country:	
			email:	
			Telephone:	

Hereby declares that each production unit completed in the list in tab 'list of power-generating units' of this homologation application complies with the following conditions:

1. The power-generating unit complies with the relevant requirements set out in annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019).

2. In order to substantiate this, a separate technical file has been submitted at least for each separate product series of the 'C10/26 list of power-generating units' of this homologation application. Each technical file shall be drawn up on the basis of a checklist Annex D, duly and correctly completed by the manufacturer, accompanied by all the required proof of conformity.

- 2.1 For technical requirements for which the required proof of conformity (column J in checklist annex D) is a declaration of honour by the manufacturer, the manufacturer declares by signing and dating this declaration of conformity the correctness of the information (conform / not conform / not applicable) provided by him or her in columns K, L and M of this checklist.
- 2.2. For technical requirements for which the required proof of conformity (column J in checklist Annex D) is a test report or a certificate, the necessary test reports and/or certificates are available \* in the technical file:
  - Certificates have been issued by an EN 45011 (or ISO 17065:2012) certification body accredited for these materials.
  - Test reports have been established by an ISO 17025:2005 or ISO 17065:2012 laboratory accredited for these tests.
- 2.3 A list of the document references or the certificates of conformity referred to in the checklist Annex D is also available in the technical file.



Done at:	(location)	Amsterdam	Homologated by Synergrid on:	
On:	(date)	3-12-2019	Stamp Synergrid & signature:	NS. 01. 2020
(stamp manufacturer & signature)				

\* Transition period till 01/05/2020 (see exceptions in chapter 3 of C10/11 ed 2.1 (01/09/2019)):

If at the time of submission of this homologation application it is not yet possible to submit all the necessary certificates and/or test reports (exception 3), or that the units do not yet have all the required characteristics (exceptions 1 and 2), a **temporary homologation** may be granted. All necessary certificates and/or test reports must be in the possession of Synergrid at the latest on 30/04/2020 in order to obtain a final homologation. If this is not the case, the temporary C10/26 homologation will be withdrawn.

**FINAL  
HOMOLOGATION**

BE 0405 028 094  
000 Brixellstraße  
Graz 9000  
Karl-Franz-Universität Graz  
Technische Fakultät  
4100

HOMOLOGATION  
FINAL

POWER-GENERATING UNITS TO BE HOMOLOGATED FOR LIST C10/26 ACCORDING TO THE REQUIREMENTS OF ANNEX D OF THE TECHNICAL PRESCRIPTION C10/11 ed2.1 (01/09/2019)  
 2. C10/26 list with power-generating units in accordance with annex D of C10/11 ed2.1 (01/09/2019)  
 [GLV 013.5] HUAWEI SUN2000  
 checklist ed 2.1.2 (12/2019)

1	2	3	4	5	6		8	9	10	11					12			13			14	15			
					ONLY for units (suitable for) energy storage: Name and reference of the power control system	power control system type EnFuLrL				other power control system	POWER	ADDITIONAL CHARACTERISTICS	LIMITATIONS	APPLICATION	Final homologation	Synergid approval date									
SYNERGRID reference number (GLVxxx-yy-zzzz)	BRAND NAME	Name of the product SERIES	REFERENCE of the model / type of the unit	FIRMWARE VERSION			Power (rated) power (W)	Size maximum apparent power (VA)	1-phase or 3-phase	D.3 integrated automatic separation system	D.4.1 additional operating frequency range (3.15 Hz - 52.5 Hz)	D.6.2 power response to underfrequency	D.7.2 active power reduction P(U)	D.7.1 only homologated for "small power-generating installations"	D.4.3 only homologated for connection to HV-network	D.9.1 use in module < 800W	(...)	Solar energy	Wind energy	CHP (combined heat & power)	Energy storage	Backup power system	Other	Temporary homologation (expires on 01/05/2020)	Final homologation
	HUAWEI	SUN2000	SUN2000-165KTL-H1	V100R001			185000	185000	3-phase	X	X	X													

EXPLANATIONS FOR THE COMPLETION OF THE TABLE

Column	Title	Remarks
1	SYNERGRID reference number (GLVxxx-yy-zzzz)	In the case of a positive homologation, each C10/26-homologated power-generating unit is given a unique Synergid reference number: xxx = unique reference or the manufacturer yy = serial number of manufacturer xxx's record xxx zzz = unique unit reference for the manufacturer xxx Note: - GLV is the internal Synergid-abbreviation for Declaration of Conformity, based on the Dutch word "certificeringsverklaring". Brand name under which the unit is marketed on the Belgian market.
2	Brand name	Name of the product series
3	Name of the product series	Unique product name or reference. Units of the same product range must be unequivocally distinguished from each other through this name or reference.
4	Reference of the model / type of the unit	Reference of the firmware version of the unit.
5	Firmware version	This case is only applicable for units (suitable for) energy storage, provided with a power control system of type EnFuLrL, compliant to the requirements in C10/11 ed2.1 (01/09/2019) §4.1.7 and §7.11.2.1
6	power control system type EnFuLrL	This case is only applicable for units (suitable for) energy storage, provided with a power control system of another type than EnFuLrL. Name and reference of the power control system, compliant to the requirements in C10/11 ed2.1 (01/09/2019) §7.11.2.2
7	other power control system	Active (electrical) power in W at the terminals of the unit, as stated on the technical sheet / data sheet / brochure and nomenclature. [For photovoltaic inverters, see also definition in §3.2.5 of IEC 62883-2:2015-11]
8	Power (rated) power	Maximum apparent (electrical) power at the terminals of the unit, as stated on the certificate / the test report / the technical sheet / data sheet / brochure.
9	Size - maximum apparent power (VA)	Indicate whether the unit is single- or three-phase. This characteristic refers to the unit itself, not to the nature of the connection to the distribution network to which the unit can be connected.
10	1-phase or 3-phase	

SYNERGRID a.s.b.l. N.Z.W.  
 Galerie Ravensteijnlaan 4/2  
 BE-1000 Bruxelles/Brussel  
 T.V.A./B.T.W.: BE 0402.958.091

**FINAL HOMOLOGATION**

Naturel Technologies Nederlanders B.V.  
 1101 CA Amsterdam  
 Tel: +31-20-7200000  
 Fax: +31-20-6200088  
 EMail: sales@naturel.nl  
 BTW: NL0915201801

C10/26 - homologation - 2. list of power-generating units  
 ed2.1.2 (12/2019) on the basis of C10/11 ed2.1 (01/09/2019) - p. 1/2

11	Additional characteristics	<p>In these columns optional additional characteristics of the units are indicated, following the information in checklist annex D and the corresponding technical file. Put an "x" at each relevant additional characteristic.</p> <p>Note: Only units &lt; 1 MW that are "Type B ready" may be applied in an installation ≥ 1 MW (installation "Type B" according to the European Network Code RIG). A unit &lt; 1 MW is only "Type B ready" if it complies with <u>all</u> optional properties ticked in column I of the checklist Annex D.</p>
12	Limitations	<p>These columns specify limitations of the units to their application in certain types of installations, in accordance with the information in the checklist in annex D and the corresponding technical file. Put an "x" to each relevant limitation.</p>
13	Application	<p>Indicate the applications for which the unit is suitable. Include an "x" with each application for which the unit can be used.</p>
14	Synergird approval date Temporary homologation (expires on 01/05/2020)	<p>Date on which the submitted homologation file was approved by Synergird for a limited period of time.</p> <ul style="list-style-type: none"> <li>- A temporary homologation is granted if the applicant invokes exceptions in chapter 3 of C10/11 ed2.1 (01/09/2019) and has not yet submitted all the test reports required for a definitive homologation with his homologation application (exception 3), or if the units do not yet have all the required properties (exceptions 1 and 2);</li> <li>- The expiry date for a temporary homologation is 01/05/2020 - see conditions in chapter 3 of C10/11 ed2.1 (01/09/2019).</li> </ul>
15	Synergird approval date Final homologation	<p>Date on which the submitted homologation file was definitively approved by Synergird.</p> <ul style="list-style-type: none"> <li>- A final approval will be granted as soon as Synergird has a fully compliant homologation dossier.</li> <li>- A final homologation only remains valid under the following conditions: <ul style="list-style-type: none"> <li>- No changes that have an influence on the initial approval are made to (the production of) the units;</li> <li>- There is no new edition of prescription C10/11.</li> </ul> </li> <li>- The validity date of the test reports in the technical file submitted for approval has not been exceeded.</li> </ul> <p>See also the general Synergird procedure S1/01 for homologation of material, which is applicable. (1)</p>

(1) - S1/01 Technical specification: procedure for application for homologation and renewal of homologation of materials

HOMOLOGATION  
FINIT

FINAL  
HOMOLOGATION

01/05/2020  
13:28:06  
B1/2661  
B1/2661  
B1/2661