


GLV 105-18	SolaX Power	X1-MINI G4, X1-BOOST G4	
<b>C10/26 - DECLARATION OF CONFORMITY for power-generating units</b> GLV ed2.1.2 (12/2019)			
for the application of annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019)			

The undersigned,	Manufacturer:	SolaX Power Network Technology (Zhe jiang)	Represented by:	Jason Shen
	Address:	No. 288, Shizhu Road, Tonglu Economic Development Zone, Zhejiang Province, 310000 P. R. CHINA	Country:	PEOPLE'S REPUBLIC OF CHINA
			email:	<a href="mailto:Jason.shen@solaxpower.com">Jason.shen@solaxpower.com</a>
			Telephone:	+86-571-56260008

the following conditions:


1. The power-generating unit complies with the relevant requirements set out in annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019).
2. In order to substantiate this, a separate technical file has been submitted at least for each separate product series of the 'C10/26 list of power-generating units' of this homologation application. Each technical file shall be drawn up on the basis of a checklist Annex D, duly and correctly completed by the manufacturer, accompanied by all the required proof of conformity.

2.1 For technical requirements for which the required proof of conformity (column J in checklist annex D) is a declaration of honour by the manufacturer, the manufacturer declares by signing and dating this declaration of conformity the correctness of the information (conform / not conform / not applicable) provided by him or her in columns K, L and M of this checklist.

2.2. For technical requirements for which the required proof of conformity (column J in checklist Annex D) is a test report or a certificate, the necessary test reports and/or certificates are available \* in the technical file:

- Certificates have been issued by an EN 45011 (or ISO 17065:2012) certification body accredited for these materials.
- Test reports have been established by an ISO 17025:2005 or ISO 17065:2012 laboratory accredited for these tests.

file.



Done at: HangZhou (location)	<b>浙江艾罗网络能源技术股份有限公司</b> <b>SOLAX POWER NETWORK TECHNOLOGY (ZHEJIANG) CO., LTD.</b>	Homologated by Synergrid on:	7/8/2027
On: 2023-03-31 (date)		(stamp manufacturer & signature)	Stamp Synergrid & signature:

\* Transition period till 01/05/2020 (see exceptions in chapter 3 of C10/11 ed 2.1 (01/09/2019)):

If at the time of submission of this homologation application it is not yet possible to submit all the necessary certificates and/or test reports (exception 3), or that the units do not yet have all the required characteristics (exceptions 1 and 2), a temporary homologation may be granted. All necessary certificates and/or test reports must be in the possession of Synergrid at the latest on 30/04/2020 in order to obtain a final homologation. if

POWER-GENERATING UNITS TO BE HOMOLOGATED FOR LIST C10/26 ACCORDING TO THE REQUIREMENTS OF ANNEX D OF THE TECHNICAL PRESCRIPTION C10/11 ed2.1 (01/09/2019)  
 2. C10/26 list with power-generating units in accordance with annex D of C10/11 ed2.1 (01/09/2019)

GLV 195-13 SolaX Power X1-MINI G4, X1-BOOST G4

checklist ed 2.1.2 (12/2019)

1	2	3	4	5	6		7		8	9	10	11				12			13			14	15															
					ONLY for units (suitable for) energy storage: Name and reference of the power control system		P <sub>acr,r</sub> rated (active) power (W)	S <sub>max</sub> maximum apparent power (VA)				1-phase or 3-phase	D.3 integrated automatic separation system	D.4.1 RFG type B ready = suitable for use in installation > 11kV	D.6.2 additional operating frequency range (51.5 Hz - 52.5 Hz)	D.7.2 active power reduction (PL)	D.7.1 compliant power control system provided (e.g. EHPUR)	D.4.3 only homologated for connection to HV-network	D.9.1 only homologated as a backup power system according to §2.1.1	D.9.1 only homologated for use in module < 800W	D.4.3 only homologated for connection to HV-network	D.7.1 only homologated for "small power-generating installations"	D.7.2 compliant power control system provided (e.g. EHPUR)	D.4.3 only homologated for connection to HV-network	D.9.1 only homologated as a backup power system according to §2.1.1	D.9.1 only homologated for use in module < 800W	D.4.3 only homologated for connection to HV-network	Solar energy	Wind energy	CHP (combined heat & power)	Energy storage	Backup power system	Other	Synergrid approval date	Final homologation			
					power control system type EnFluRi	other power control system																														D.3	(+)	D.4.1
	SolaX Power	X1-MINI G4	X1-MINI-0.6K-G4	Master:1.00 Manager:1.00			600	600	1-phase	X	X	X						X																				
	SolaX Power	X1-MINI G4	X1-MINI-0.7K-G4	Master:1.00 Manager:1.00			700	770	1-phase	X	X	X						X																				
	SolaX Power	X1-MINI G4	X1-MINI-1.1K-G4	Master:1.00 Manager:1.00			1100	1210	1-phase	X	X	X						X																				
	SolaX Power	X1-MINI G4	X1-MINI-1.5K-G4	Master:1.00 Manager:1.00			1500	1650	1-phase	X	X	X						X																				
	SolaX Power	X1-MINI G4	X1-MINI-2.0K-G4	Master:1.00 Manager:1.00			2000	2200	1-phase	X	X	X						X																				
	SolaX Power	X1-MINI G4	X1-MINI-2.5K-G4	Master:1.00 Manager:1.00			2500	2750	1-phase	X	X	X						X																				
	SolaX Power	X1-MINI G4	X1-MINI-3.0K-G4	Master:1.00 Manager:1.00			3000	3300	1-phase	X	X	X						X																				
	SolaX Power	X1-MINI G4	X1-MINI-3.3K-G4	Master:1.00 Manager:1.00			3300	3300	1-phase	X	X	X						X																				
	SolaX Power	X1-BOOST G4	X1-BOOST-2.5K-G4	Master:1.00 Manager:1.00			2500	2750	1-phase	X	X	X						X																				
	SolaX Power	X1-BOOST G4	X1-BOOST-3K-G4	Master:1.00 Manager:1.00			3000	3300	1-phase	X	X	X						X																				
	SolaX Power	X1-BOOST G4	X1-BOOST-3.3K-G4	Master:1.00 Manager:1.00			3300	3630	1-phase	X	X	X						X																				
	SolaX Power	X1-BOOST G4	X1-BOOST-3.6K-G4	Master:1.00 Manager:1.00			3680	4048	1-phase	X	X	X						X																				
	SolaX Power	X1-BOOST G4	X1-BOOST-4.2K-G4	Master:1.00 Manager:1.00			4200	4620	1-phase	X	X	X						X																				
	SolaX Power	X1-BOOST G4	X1-BOOST-5K-G4	Master:1.00 Manager:1.00			5000	5000	1-phase	X	X	X						X																				
	SolaX Power	X1-BOOST G4	X1-BOOST-6K-G4	Master:1.00 Manager:1.00			6000	6000	1-phase	X	X	X						X																				

SYNERGRID s.a.s. b.l.v.z.w.  
 Galerie Ravensteingalerij 4/2  
 BE-1000 Bruxelles/Brussel  
 T.V.A./B.T.W : BE 0402 958 091

EXPLANATIONS FOR THE COMPLETION OF THE TABLE

Column	Title	Remarks
1	SYNERGRID reference number (GLVxxx-yy-zzzz)	In the case of a positive homologation, each C10/26-homologated power-generating unit is given a unique Synergrid reference number: xxx = unique reference or the manufacturer yy = serial number of manufacturer xxx's record xxx zzzz = unique unit reference for the manufacturer xxx Note: "GLV" is the internal Synergrid-abbreviation for Declaration of Conformity, based on the Dutch word "Geijkvornisgeheidsverklaring".
2	Brand name	Brand name under which the unit is marketed on the Belgian market.
3	Name of the product series	Name of the product range. Note: For each separate product range (or each group of units with common characteristics) a separate checklist according to Appendix D is required (sheet 3) together with the corresponding conformity proof documents.

Jason Shen

FINAL  
 HOMOLOGATION

4	Reference of the model / type of the unit	Unique product name or reference. Units of the same product range must be unequivocally distinguished from each other through this name or reference.
5	Firmware version	Reference of the firmware version of the unit.
6	power control system type EnFluR1	This case is only applicable for units (suitable for) energy storage, provided with a power control system of type EnFluR1, compliant to the requirements in C10/11 ed2.1 (01/09/2019) §4.1.7 and §7.11.2.1
7	other power control system	This case is only applicable for units (suitable for) energy storage, provided with a power control system of another type than EnFluR1; Name and reference of the power control system, compliant to the requirements in C10/11 ed2.1 (01/09/2019) §7.11.2.2
8	P <sub>ac</sub> , rated (active) power (W)	Active (electrical) power in W at the terminals of the unit, as stated on the technical sheet / data sheet / brochure and nameplate. (For photovoltaic inverters: see also definition in §3.2.5 of IEC 62894 2016-11)
9	S <sub>max</sub> - maximum apparent power (VA)	Maximum apparent (electrical) power at the terminals of the unit, as stated on the certificate / the test report / the technical sheet / data sheet / brochure.
10	1-phase or 3-phase	Indicate whether the unit is single- or three-phase. This characteristic refers to the unit itself, not to the nature of the connection to the distribution network to which the unit can be connected.
11	Additional characteristics	In these columns optional additional characteristics of the units are indicated, following the information in checklist annex D and the corresponding technical file. Put an "X" at each relevant additional characteristic. <b>Note:</b> Only units < 1 MW that are "type B ready" may be applied in an installation ≥ 1 MW (installation "type B" according to the European Network Code RfG). A unit < 1 MW is only "type B ready" if it complies with all optional properties ticked in column I of the checklist Annex D.
12	Limitations	These columns specify limitations of the units to their application in certain types of installations, in accordance with the information in the checklist in annex D and the corresponding technical file. Put an "X" to each relevant limitation.
13	Application	Indicate the applications for which the unit is suitable. Include an "X" with each application for which the unit can be used.
14	Synergrid approval date Temporary homologation (expires on 01/05/2020)	Date on which the submitted homologation file was approved by Synergrid for a limited period of time. - A temporary homologation is granted if the applicant invokes exceptions in chapter 3 of C10/11 ed2.1 (01/09/2019) and has not yet submitted all the test reports required for a definitive homologation with his homologation application (exception 3), or if the units do not yet have all the required properties (exceptions 1 and 2). - The expiry date for a temporary homologation is 01/05/2020 - see conditions in chapter 3 of C10/11 ed.2.1 (01/09/2019).
15	Synergrid approval date Final homologation	Date on which the submitted homologation file was definitely approved by Synergrid. - A final approval will be granted as soon as Synergrid has a fully compliant homologation dossier. - A final homologation only remains valid under the following conditions: - No changes that have an influence on the initial approval are made to (the production of) the units. - There is no new edition of prescription C10/11. - The validity date of the test reports in the technical file submitted for approval has not been exceeded. See also the general Synergrid procedure S1/01 for homologation of material, which is applicable. (1)

C10 - S1/01 Technical specification: procedure for application for homologation and renewal of homologation

SYNERGRID a.s.b.l.-v.z.w.  
Galerie Rayensteingalerij 4/2  
BE-1000 Bruxelles/Brussel  
T.V.A./B.T.W. BE0402358091

*Jason Shen*

**FINAL  
HOMOLOGATION**