

GLV175-09	FOXESS	H3 and AC3 Series
C10/26 - DECLARATION OF CONFORMITY for power-generating units GLV ed2.1.2 (12/2019)		
for the application of annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019)		



The undersigned,	Manufacturer:	FOXESS CO., LTD.	Represented by:	Jingcheng Zhu
		No.939, Jinhai Third Road, New Airport		
		Industry Area, Longwan District,		
	Address:	Wenzhou, Zhejiang, China	Country:	China
			email:	foxrd@fox-ess.com
			Telephone:	86 (0510) 68092998

the following conditions:

1. The power-generating unit complies with the relevant requirements set out in annex D "Technical basic requirements regarding the power-generation units" of the Synergrid prescription C10/11 ed2.1 (01/09/2019).
2. In order to substantiate this, a separate technical file has been submitted at least for each separate product series of the 'C10/26 list of power-generating units' of this homologation application. Each technical file shall be drawn up on the basis of a checklist Annex D, duly and correctly completed by the manufacturer, accompanied by all the required proof of conformity.
 - 2.1 For technical requirements for which the required proof of conformity (column J in checklist annex D) is a declaration of honour by the manufacturer, the manufacturer declares by signing and dating this declaration of conformity the correctness of the information (conform / not conform / not applicable) provided by him or her in columns K, L and M of this checklist.
 - 2.2. For technical requirements for which the required proof of conformity (column J in checklist Annex D) is a test report or a certificate, the necessary test reports and/or certificates are available * in the technical file:
 - Certificates have been issued by an EN 45011 (or ISO 17065:2012) certification body accredited for these materials.
 - Test reports have been established by an ISO 17025:2005 or ISO 17065:2012 laboratory accredited for these tests.

FINAL
HOMOLOGATION

Done at:	No. 99, Hongye Road,	Homologated by Synergrid on:	08/12/2023
On:	Suzhou Industrial	Stamp Synergrid & signature:	SYNERGRID a.s.b.l.-v.z.w.
	Park, Suzhou,		Galerie Ravensteingalerij 4/2
	Jiangsu, P.R.		BE 1000 Bruxelles/Brussel
	2023-06-06		T.V.A./B.T.W. BE 0402.958.091
(stamp manufacturer & signature)	苏州能源股份有限公司 FOXESS CO., LTD.		

* Transition period till 01/05/2020 (see exceptions in chapter 3 of C10/11 ed 2.1 (01/09/2019)):
If at the time of submission of this homologation application it is not yet possible to submit all the necessary certificates and/or test reports (exception 3), or that the units do not yet have all the required characteristics (exceptions 1 and 2), a temporary homologation may be granted. All necessary certificates and/or test reports must be in the possession of Synergrid at the latest on 30/04/2020 in order to obtain a final homologation. if

C10/26 - homologation - 1. GLV
ed2.1.2 (12/2019) on the basis of C10/11 ed.2.1 (01/09/2019)

GLV175-09	FOXESS	III and MCA Series
-----------	--------	--------------------

checklist of 2.1.2 (12/2019)

SYNERGID a.s.b.l.-v.z.w.
Galerie Ravensteingalerij 412
BE-1000 Bruxelles/Brussel
T.V.A./B.T.W.: BE 0402.958.001

Column	Title	Remarks
1	SYNCRID reference number (YYXXX-YY-ZZZZ)	In the case of a positive homologation, each C10/20-homologated power-generating unit is given a unique Syncriid reference number: xxx = unique reference of the manufacturer yy = serial number of manufacturer xxx's record xxx zzzz = unique unit reference for the manufacturer xxx Note: "ZZZ" is the internal Syncriid-abbreviation for Declaration of Conformity, based on the Dutch word "Getuigenisgevingverklaring".
2	Brand name	Brand name under which the unit is marketed on the Belgian market.
3	Name of the product series	Name of the product ranges. Note: For each separate product range (or each group of units with common characteristics) a separate checklist according to Appendix D is required (sheet 3) together with the corresponding conformity proof documents.
4	Reference of the model / type of the unit	Unique product name or references. Units of the same product range must be unequivocally distinguished from each other through this name or reference.
5	Firmware version	Reference of the firmware version of the unit.
6	power control system (type En1681)	This case is only applicable for units (suitable for) energy storage, provided with a power control system of type En1681, compliant to the requirements in C10/11 ed2.1 (01/09/2019) § 4.1.7 and § 7.11.2.1
7	other power control system	This case is only applicable for units (suitable for) energy storage, provided with a power control system of another type (see En1681). Name and reference of the power control system, compliant to the requirements in C10/11 ed2.1 (01/09/2019) § 7.11.2.2
8	P _{act} (rated active power) [W]	Active (selected) power in W at the terminals of the unit, as stated on the technical sheet / data sheet / brochure and nameplate. (For photovoltaic inverters: see also definition in § 2.2.3 of IEC 62941 2016-11)
9	S _{max} = maximum apparent power [VA]	Maximum apparent (selected) power at the terminals of the unit, as stated on the certificate / test report / the technical sheet / data sheet / brochure.
10	1-phase or 3-phase	Indicate whether the unit is single- or three-phase. This characteristic refers to the unit itself, not to the nature of the connection to the distribution network to which the unit can be connected.
11	Additional characteristics	In these columns optional additional characteristics of the units are indicated, following the information in checklist annex D and the corresponding technical file. Put an "X" at each relevant additional characteristic. Note: Only units < 1 MVA that are "type B ready" may be applied in an installation ≥ 1 MVA (installation "type B" according to the European Network Code RNE). A unit < 1 MVA is only "type B ready" if it complies with all optional properties listed in column I of the checklist Annex B.

FINAL
HOMOLOGATION

12	Limitations	These columns specify limitations of the units to their application in certain types of installations, in accordance with the information in the checklist in annex D and the corresponding technical file. Put an "X" to each relevant limitation.
13	Application	Indicate the applications for which the unit is suitable. Include an "X" with each application for which the unit can be used.
14	Synergrid approval date Temporary homologation (expires on 01/05/2020)	Date on which the submitted homologation file was approved by Synergrid for a limited period of time. - A temporary homologation is granted if the applicant invokes exceptions in chapter 3 of C10/11 ed2.1 (01/09/2019) and has not yet submitted all the test reports required for a definitive homologation with his homologation application (exception 3), or if the units do not yet have all the required properties (exceptions 1 and 2). - The expiry date for a temporary homologation is 01/05/2020 - see conditions in chapter 3 of C10/11 ed2.1 (01/09/2019).
15	Synergrid approval date Final homologation	Date on which the submitted homologation file was definitively approved by Synergrid. - A final approval will be granted as soon as Synergrid has a fully compliant homologation dossier. - A final homologation only remains valid under the following conditions: - No changes that have an influence on the initial approval are made to (the production of) the units; - There is no new edition of prescription C10/11; - The validity date of the test reports in the technical file submitted for approval has not been exceeded. See also the general Synergrid procedure SI/01 for homologation of material, which is applicable. (1)

(1) - SI/01 Technical specification: procedure for application for homologation and renewal of homologation of materials

麦田能源股份有限公司
FOXESS CO., LTD.
SYNERGRID a.s.b.l.-v.z.w.
Galerie Ravensteingalerij 4/2
BE-1000 Bruxelles/Brussel
T.V.A/B.T.W.V. BE 0402.958.091

FINAL
HOMOLOGATION