



Product Testing



Decospan NV
Lageweg 33
8930 Menen
BELGIUM

Eurofins Product Testing A/S
Smedeskovvej 38
8464 Galten
Denmark

CustomerSupport@eurofins.com
www.eurofins.com

VOC EMISSION TEST REPORT

CDPH

12 July 2023

1 Sample Information

Sample name	Shinnoki MDF
Batch no.	-
Stated production date	28/04/2023
Product type	Wood based panel
Sample reception	11/05/2023

2 Brief Evaluation of the Results

Regulation or protocol	Conclusion	Version of regulation or protocol
CDPH		CDPH/EHLB/Standard Method V1.2. (January 2017)
-Classroom scenario	Pass	
-Office scenario	Fail	

Full details based on the testing and direct comparison with limit values are available in the following pages
Regarding pass/fail decision rule please see appendix

Liva Kjær Hansen
Analytical Service Manager

Laura Hartung Sørensen
Analytical Service Manager