

Liquid Petroleum Gas Safety Certificate

Safety inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations 1998.



Registered Business		Trailer		Customer Detail				
Chedd Ltd Birmingham Farm, Guildford, Surrey, GU5 9AT +44 01483 534552		P55BRA		Mr Paul Stephenson Unit 1 Russell Place Farm Guildford, Surrey GU3 3EZ				
Appliance Details								
	Appliance Type	Make	Model	Flue Type	Inspected			
1	Gas hob	Smev	4 Burner	FL	Yes			
2	Single oven gas	Smev	Grill	FL	Yes			
3	Fridge	Trigano	Fridge	OF	Yes			
4	water heater	Truma	BS10	RS	Yes			
5								
Inspection Details								
	Combustion Reading	Safety Devices(s) Correct Operation	Ventilation Provision Satisfactory	Visual Condition of Flue & Termination Satisfactory	Flue Performance Test	Appliance Serviced	Appliance Safe to Use	
1	0	Yes	Yes	Yes	Pass	No	Yes	
2	0000	Yes	Yes	Yes	Pass	No	Yes	
3	0000	Yes	Yes	Yes	Pass	No	Yes	
4	0001	Yes	Yes	Yes	Pass	No	Yes	
5								
Defects Identified		Label & Warning Notice Issued			CO Alarm(s)		PASS OR FAIL	
1		No			Fitted	Yes	Inspection Pass (Yes or No)	Yes
2		No						
3		No						
4		No			Tested and Satisfactory	Yes		
5								
Is the LPG cylinder housing satisfactory		Yes	Gas tightness satisfactory	Yes	LPG regulator operating pressure	35 mbar	Next inspection due on or before 22/06/26	
Gas installation pipework visual inspection satisfactory		Yes	ECV accessible and operable	Yes	LPG regulator lock-up pressure	45 mbar		
Technician Details			Report Received By			Certificate Information		
Name: Josh Soper Company Gas Safe Number: 4573 Signature:			Received by: No person present Name: Signature:			Certificate Number: 425 Date of certificate: 22/06/26		