

Appion Inc. Phone: 303-937-1580 Fax: 1599 2800 South Tejon St. Englewood, CO 80110 USA

www.AppionInc.com

Voltage Drop thru Extension Cords

- Recovery equipment is used primarily in the hot summer months when supply voltage can be at the lowest point of the year due to the demand from A/CR equipment operating at peak conditions
- When <u>low supply voltage</u> and a <u>long, undersized extension cord</u> are combined, it will have a disastrous effect on equipment performance and can lead to electrical equipment failure.
 - > The **G5 Twin and G1 Single** designed with features that allow the unit to shut itself off when subjected to overheating due to low voltage.
- Extension cords, when sized properly, and kept as short as possible, will deliver the available supply power without excessive voltage drop to the equipment through the cord itself.
- Oversized extension cords have less resistance, less voltage drop, and operate at lower temperatures, <u>increasing the efficiency and life expectancy</u> of both the equipment and cord itself.
- However, extension cords that are undersized, or longer than needed, have higher resistance, greater voltage drop, run hotter, and are the primary reason for poor equipment performance and field service electrical equipment failures.

Recommended Extension cord sizes for industrial-duty field service electrical equipment:

- Up to 25 feet 12/3 UL/CSA cord
- 25 to 100 feet 10/3 UL/CSA cord

Service tip: Always use the <u>shortest length</u> and <u>largest gauge</u> extension cord possible when operating industrial-duty field service electrical equipment.