



DataView[®]

Data Analysis & Reporting Software

Sample Reports

The DataView[®] Professional software included with the PowerPad[™] automatically generates reports from the stored data. These reports can be displayed on your PC and printed. Each report includes all test results in both tabular and graphic format, as well as operator and test site information. Comments typed by the operator will also be included.

DataView allows you to display waveforms, trend graphs, harmonic spectrums, text summaries, transients and stored alarms. You can zoom in and out and pan through sections of the graph to analyze the data and customize views, templates and reports to your exact needs.

This document includes two sample reports generated from data that was recorded with the PowerPad. You may jump to any page in the reports by clicking on the links below.


Trend Report

- Frequency
- Voltage (phase-to-neutral)
- Current
- Current and Voltage THD
- Voltage Unbalance
- Wattage
- Watt Hours
- Power Factor
- Individual Current Harmonics
- Apparent Power
- Trend Summary Report

Transient Report

- Three-phase Voltage and Current
- Zoomed-in Transient Cycle plus Harmonics
- One cycle of Three-phase Current plus Harmonics
- Transient Report


Channel Name: Uthd Line1



Name	Date	Time	Avg	Min	Max	Units
Uthd Line1	8/12/2004	12:30:02.500 PM	2.169	0.000	4.400	%
Uthd Line2	8/12/2004	12:30:02.500 PM	2.138	0.000	3.600	%
Uthd Line3	8/12/2004	12:30:02.500 PM	2.090	0.000	3.500	%
Vthd Line1	8/12/2004	12:30:02.500 PM	2.065	0.000	4.200	%
Vthd Line2	8/12/2004	12:30:02.500 PM	2.028	0.000	5.100	%
Vthd Line3	8/12/2004	12:30:02.500 PM	2.001	0.000	3.500	%
Athd Line1	8/12/2004	12:30:02.500 PM	41.67	0.000	47.50	%
Athd Line2	8/12/2004	12:30:02.500 PM	36.72	0.000	39.10	%
Athd Line3	8/12/2004	12:30:02.500 PM	42.03	0.000	53.00	%

8/12/2004 - 12:30:02.000 PM
 Val
 2.300 — Uthd Line1
 2.300 — Uthd Line2
 2.300 — Uthd Line3
 2.100 — Vthd Line1
 2.100 — Vthd Line2
 2.100 — Vthd Line3
 43.20 — Athd Line1
 37.90 — Athd Line2
 43.40 — Athd Line3


Channel Name: W Line1
 VoltageRatio: 1.000
 CurrentRatio: 1.000



Name	Date	Time	Avg	Min	Max	Units
W Line1	8/12/2004	12:30:02.500 PM	-3.302E+3	-5.226E+3	0.000	W
W Line2	8/12/2004	12:30:02.500 PM	-3.384E+3	-5.196E+3	0.000	W
W Line3	8/12/2004	12:30:02.500 PM	-3.082E+3	-4.971E+3	0.000	W
W Sum of Phases	8/12/2004	12:30:02.500 PM	-9.769E+3	-15.35E+3	0.000	W
VAR Line1	8/12/2004	12:30:02.500 PM	-1.579E+3	-2.563E+3	557.9	VAR
VAR Line2	8/12/2004	12:30:02.500 PM	-1.424E+3	-2.378E+3	499.0	VAR
VAR Line3	8/12/2004	12:30:02.500 PM	-1.555E+3	-2.461E+3	514.1	VAR
VAR Sum of Phases	8/12/2004	12:30:02.500 PM	-4.559E+3	-7.339E+3	1.571E+3	VAR
VA Line1	8/12/2004	12:30:02.500 PM	3.667E+3	0.000	5.830E+3	VA
VA Line2	8/12/2004	12:30:02.500 PM	3.678E+3	0.000	5.726E+3	VA
VA Line3	8/12/2004	12:30:02.500 PM	3.461E+3	0.000	5.563E+3	VA
VA Sum of Phases	8/12/2004	12:30:02.500 PM	10.81E+3	0.000	17.05E+3	VA

8/12/2004 - 12:30:02.000 PM
 Val
 -3.414E+3 — W Line1
 -3.499E+3 — W Line2
 -3.194E+3 — W Line3
 -10.11E+3 — W Sum of Phases
 -1.643E+3 — VAR Line1
 -1.450E+3 — VAR Line2
 -1.613E+3 — VAR Line3
 -4.706E+3 — VAR Sum of Phases
 3.790E+3 — VA Line1
 3.788E+3 — VA Line2
 3.581E+3 — VA Line3
 11.16E+3 — VA Sum of Phases

Channel Name: W-hours Line1
 VoltageRatio: 1.000
 CurrentRatio: 1.000




Name	Date	Time	Avg	Min	Max	Units
W-hours Line1	8/12/2004	12:30:02.500 PM	-812.3	-1.729E+3	-4.697	Wh
W-hours Line2	8/12/2004	12:30:02.500 PM	-838.3	-1.772E+3	-4.815	Wh
W-hours Line3	8/12/2004	12:30:02.500 PM	-754.7	-1.614E+3	-4.434	Wh
W-hours Sum of Phases	8/12/2004	12:30:02.500 PM	-2.405E+3	-5.115E+3	-13.89	Wh
VA-hours Line1	8/12/2004	12:30:02.500 PM	900.4	5.216	1.920E+3	VAh
VA-hours Line2	8/12/2004	12:30:02.500 PM	908.4	5.232	1.926E+3	VAh
VA-hours Line3	8/12/2004	12:30:02.500 PM	847.9	4.923	1.812E+3	VAh
VA-hours Sum of Phases	8/12/2004	12:30:02.500 PM	2.657E+3	15.37	5.658E+3	VAh
VAR-hours Line1	8/12/2004	12:30:02.500 PM	-385.8	-826.7	-2.271	VARh
VAR-hours Line2	8/12/2004	12:30:02.500 PM	-347.2	-745.8	-2.003	VARh
VAR-hours Line3	8/12/2004	12:30:02.500 PM	-382.5	-814.4	-2.237	VARh
VAR-hours Sum of Phases	8/12/2004	12:30:02.500 PM	-1.115E+3	-2.387E+3	-6.485	VARh

8/12/2004 - 12:30:02.000 PM
 Val
 -4.697 — W-hours Line1
 -4.815 — W-hours Line2
 -4.434 — W-hours Line3
 -13.89 — W-hours Sum of Phases
 5.216 — VA-hours Line1
 5.232 — VA-hours Line2
 4.923 — VA-hours Line3
 15.37 — VA-hours Sum of Phases
 -2.271 — VAR-hours Line1
 -2.003 — VAR-hours Line2
 -2.237 — VAR-hours Line3
 -6.485 — VAR-hours Sum of Phases





Channel Name: Arms Line1
 CurrentRatio: 1.000

8/12/2004 - 12:30:02.000 PM

Val
 32.60 — Arms Line1
 32.80 — Arms Line2
 31.00 — Arms Line3
 3.100 — Arms Neutral




Name	Avg	Min	Max	Units
Arms Line1	31.52	0.000	50.40	A
Arms Line2	31.91	0.000	50.00	A
Arms Line3	29.99	0.000	48.60	A
Arms Neutral	2.929	0.000	4.300	A



Channel Name: VA Line1
 VoltageRatio: 1.000
 CurrentRatio: 1.000

8/12/2004 - 12:30:02.000 PM

Val
 3.790E+3 — VA Line1
 3.788E+3 — VA Line2
 3.581E+3 — VA Line3
 11.16E+3 — VA Sum of Phases



Name	Avg	Min	Max	Units
VA Line1	3.667E+3	0.000	5.830E+3	VA
VA Line2	3.678E+3	0.000	5.726E+3	VA
VA Line3	3.461E+3	0.000	5.563E+3	VA
VA Sum of Phases	10.81E+3	0.000	17.05E+3	VA

Trend Summary Report

Database: C:\Program Files\DataView\DataFiles\PowerPad\1trend.dvb

Operator

AEMC Instruments

200 Foxborough Blvd

Foxborough, MA 02035
508-698-2115

Test Site

Comments

Tests run on a large message display.

Trend recordings are each shown on a separate page of this report for the following parameters

frequency

voltage (phase-to-neutral)

current

current, voltage thd

voltage unbalance

wattage

watt hours

power factor

individual current harmonics


apparent power



Transient Report

Recording Start Date
Recording Duration
Instrument ID


8/20/2004 - 6:30:27 PM
0 (s)
Model: 3945 - 1 1 100132



Name	Date	Time	RMS	Units
4Cycles V2	8/20/2004	6:30:27.399 PM	110.2	V
4Cycles V1	8/20/2004	6:30:27.399 PM	73.75	V
4Cycles V3	8/20/2004	6:30:27.399 PM	113.5	V
4Cycles I1	8/20/2004	6:30:27.399 PM	5.587	A
4Cycles I2	8/20/2004	6:30:27.399 PM	6.330	A
4Cycles I3	8/20/2004	6:30:27.399 PM	5.378	A

8/20/2004 - 6:30:27.000 PM

Val	Series
0.000	4Cycles V2
0.300	4Cycles V1
147.7	4Cycles V3
-0.200	4Cycles I1
-7.100	4Cycles I2
7.200	4Cycles I3




Start Date: 8/20/2004
Start Time: 6:30:27.400 PM
Duration: 66.667 (mS)
Frequency: 60.00 Hz
Magnitude Of Transient: -137.0
Data Point Of Transient: 28.00
VoltageRatio: 1.000
CurrentRatio: 1.000

Name	Date	Time	Duration	Units
Transient Trigger V2	8/20/2004	6:30:27.416 PM	2.083	(mS)

8/20/2004 - 6:30:27.000 PM



Val	Series
0.000	Transient Trigger V2

Channel Name: Waveform V1
 Frequency: 60.00 Hz
 VoltageRatio: 1.000



8/20/2004 16.667 (mS) 8/20/2004
 6:30:27.399 PM 3 mSec/Div 6:30:27.416 PM


Name	Date	Time	Duration	RMS	Units
Waveform V1	8/20/2004	6:30:27.399 PM	16.667	73.57	V
Waveform V1	8/20/2004	6:30:27.416 PM	16.667	73.90	V
Waveform V1	8/20/2004	6:30:27.433 PM	16.667	73.81	V
Waveform V1	8/20/2004	6:30:27.450 PM	16.667	73.70	V
Waveform V2	8/20/2004	6:30:27.399 PM	16.667	0.132	V
Waveform V2	8/20/2004	6:30:27.416 PM	16.667	115.9	V
Waveform V2	8/20/2004	6:30:27.433 PM	16.667	132.6	V
Waveform V2	8/20/2004	6:30:27.450 PM	16.667	132.6	V
Waveform V3	8/20/2004	6:30:27.399 PM	16.667	114.2	V
Waveform V3	8/20/2004	6:30:27.416 PM	16.667	113.5	V
Waveform V3	8/20/2004	6:30:27.433 PM	16.667	113.2	V
Waveform V3	8/20/2004	6:30:27.450 PM	16.667	113.2	V




Waveform V1

(%)	(%)	(%)
H01 100.0	H18 0.3	H35 0.5
H02 0.8	H19 2.0	H36 0.3
H03 20.6	H20 0.3	H37 0.8
H04 0.3	H21 0.8	H38 0.3
H05 12.3	H22 0.4	H39 0.8
H06 0.4	H23 0.8	H40 0.3
H07 4.2	H24 0.3	H41 0.6
H08 0.3	H25 1.2	H42 0.4
H09 1.3	H26 0.3	H43 0.3
H10 0.3	H27 1.2	H44 0.3
H11 3.7	H28 0.3	H45 0.7
H12 0.4	H29 0.7	H46 0.3
H13 2.1	H30 0.2	H47 0.4
H14 0.3	H31 0.9	H48 0.2
H15 1.7	H32 0.3	H49 0.5
H16 0.2	H33 0.9	H50 0.3
H17 1.4	H34 0.3	

Channel Name: Waveform I1
 Frequency: 60.00 Hz
 CurrentRatio: 1.000



Name	Date	Time	Duration	RMS	Units
Waveform I1	8/20/2004	6:30:27.399 PM	16.667	5.589	A
Waveform I1	8/20/2004	6:30:27.416 PM	16.667	5.587	A
Waveform I1	8/20/2004	6:30:27.433 PM	16.667	5.586	A
Waveform I1	8/20/2004	6:30:27.450 PM	16.667	5.587	A
Waveform I2	8/20/2004	6:30:27.399 PM	16.667	6.497	A
Waveform I2	8/20/2004	6:30:27.416 PM	16.667	6.328	A
Waveform I2	8/20/2004	6:30:27.433 PM	16.667	6.247	A
Waveform I2	8/20/2004	6:30:27.450 PM	16.667	6.246	A
Waveform I3	8/20/2004	6:30:27.399 PM	16.667	5.408	A
Waveform I3	8/20/2004	6:30:27.416 PM	16.667	5.380	A
Waveform I3	8/20/2004	6:30:27.433 PM	16.667	5.362	A
Waveform I3	8/20/2004	6:30:27.450 PM	16.667	5.361	A



8/20/2004 - 6:30:27.000 PM
 Val
 -0.200 — Waveform I1
 -7.100 — Waveform I2
 7.200 — Waveform I3

Waveform I1					
		(%)			(%)
H01	100.0	H18	0.0	H35	0.0
H02	0.1	H19	0.1	H36	0.0
H03	1.2	H20	0.0	H37	0.1
H04	0.1	H21	0.1	H38	0.0
H05	1.8	H22	0.0	H39	0.0
H06	0.1	H23	0.0	H40	0.1
H07	0.6	H24	0.0	H41	0.0
H08	0.0	H25	0.1	H42	0.0
H09	0.4	H26	0.0	H43	0.1
H10	0.0	H27	0.1	H44	0.0
H11	0.2	H28	0.0	H45	0.1
H12	0.0	H29	0.1	H46	0.0
H13	0.2	H30	0.0	H47	0.1
H14	0.1	H31	0.0	H48	0.0
H15	0.1	H32	0.0	H49	0.0
H16	0.0	H33	0.1	H50	0.0
H17	0.1	H34	0.0		

Transient Report

Database: C:\Program Files\DataView\DataFiles\PowerPad\Samples\Transient.dvb

Operator

AEMC Instruments

200 Foxborough Blvd

Foxborough , MA 02035

Test Site

Comments

Page 1 shows all voltage and current measurements with a fault detected on phase B. The second (smaller) graph is a zoomed in view of the fault.

Page 2 show one cycle of each of the voltage phases along with Phase A harmonic content

Page 3 shows one cycle of each of the current phases along with Phase A harmonic content.

