

FLUKE®

Supplement

Title: CLKT Installation Guide

Supplement Issue: 1

Part Number: 4251231

Issue Date: 9/13

Print Date: June. 2010, Rev. 1, 3/11

Change #1

On the first page:

Change: CLKT, CLKTO, CLK

To: CLKT

On the first page, after the first paragraph, replace the sentence and Table 1 with:

The item in Table 1 is applicable to this Installation Guide.

Table 1

| Model | Application | Type | Size |
|--------------|--------------------|-------------|-------------|
| CLKT | Indoor/Outdoor | 3, 12 | 2", 3", 4" |

On the 7th page, under Step 10, replace the last two sentence with:

Gradually advance each fixing until the gasket is seen to compress evenly.

On the 8th page, replace the entire page with:

Gasket Compression

Tighten taptite screws until gasket compresses between 0.3-0.5 mm (0.012"-0.020"). Do not overtighten screws.

Note

Take all measurement with digital vernier calipers.