

BK120 SmartTrace[™] Breaker Finder Users Guide

^{© 2023-2024} Fluke Corporation. All rights reserved.

Specifications are subject to change without notice.

Introduction

The BK120 is a system to locate breakers in an electrical installation and to detect voltage. The system comprises the Transmitter and the Breaker Finder (the Product).

Contact Fluke

Fluke Corporation operates worldwide. For local contact information, go to our website: www.fluke.com.

To register your product, view, print, or download the latest manual or manual supplement, go to our website. For service information, contact your nearest Fluke dealer.

Product Use

Transmitter

- For best results, unplug all appliances and equipment on the circuit under test.
- 2. Plug the Transmitter into the socket and note which indicators light.
- 3. To determine the wiring, see the diagram on the Product shown for reference in Figure 1.



Figure 1. Transmitter

- 1 Red LED illuminates when you push the GFCI test button
- 2 Receptacle wiring check

	-	
Indicator	Wiring Scenario	Description
	CORRECT	Receptacle is wired correctly
0 • 0	OPEN GROUND	Ground contact is not wired
000	OPEN NEUTRAL	Neutral contact is not wired
000	OPEN HOT	Hot contact is not wired
	HOT / NEUT.REV.	Hot and neutral wirings are reversed
	HOT / GRD.REV.	Hot and ground wirings are reversed

Use the Product as a simple instrument to detect nearly all probable common improper wiring conditions. Read the Safety Information that is provided with the product package.

GFCI Test


To test a GFCI:

- Before you plug the Product into a GFCI socket, push the GFCI test button, if applicable, to trip the GFCI socket. If the GFCI does not trip, the socket is faulty and should be replaced.
- 2. After the GFCI trips, push the RESET button on the GFCI socket.

Consult an electrician to determine the problem.

3. Plug in the Product and push the blue GFCI test button on the Product for a minimum of 6 seconds. As you push the Product button, but before the GFCI trips, the LED to the left of the Product button briefly turns on. Once the GFCI trips, all of the LEDs on the Product go out. If the GFCI does not trip, or if any of the LEDs on the Product remain on, there is a problem with the wiring of the socket, the socket itself, or the Product.

Breaker Finder



Power On/Off

Momentarily push 1. Listen for a single beep to confirm activation. The Product performs a self-test upon powering ON, emitting beeps and light indications to ensure the proper visual and audio indications. A solid light on 1 indicates the Product is active.



Push () > 1 s to turn the product off. Listen for a double beep to confirm de-activation.



Breaker and Fuse identification

To identify a breaker:
1. Plug the Transmitter into the socket (See Figure 3.).

Figure 3. Transmitter in socket




2. Turn ON the Breaker Finder and slide the function selector to BREAKER FINDER position (See Figure 4.).

Figure 4. Turn on the Breaker Finder



3. Hold the Breaker Finder perpendicular to the breakers and scan slowly at the breaker panel with the flat surface of the tip end directly on the circuit breaker. During this scan, it may beep and/or have visual indication at several breakers as it measures the relative signal strength during the first scan process (See Figure 5.).

Figure 5.




Note

Inaccurate reading may occur if the tip is placed at any other angle.


 Repeat step 3 for the second scan, solid green indication illuminates when the Breaker Finder identifies the breaker that is powering the Transmitter (See Figure 6.).

Figure 6.




For optimal results or if the Breaker Finder detects two adjacent breakers on the second scan, reset the Breaker Finder, and turn the Breaker Finder 180° (see Figure7). Repeat step 3 and 4.

Figure 7.



5. To confirm you have found the correct breaker, trip off the breaker and check that the Transmitter in the socket is off (See Figure 8.).


Figure 8.



Non-contact voltage detection

- 1. Press ① momentarily to turn ON the Product.
- 2. Slide the switch to NCV position.
- Put the tip of the Product near an AC voltage until the Product produces a steady glow (purple or red) at the tip and produces a continual single beep when at the AC voltage source (See Figure 9.).

Figure 9.



The Product features dual sensitivity detection -

Proximity to the AC voltage source: Purple (See Figure 10.).

Figure 10.



At the AC voltage source: Beeping red (See Figure 11.).

Figure 11.



No voltage is detected: Flashing blue (See Figure 12.).


Figure 12.



Flashlight

Push ① momentarily to turn ON the Product and flashlight at the tip is ON. Push ① momentarily again to turn OFF the flashlight (See Figure 13.).

Figure 13. Flashlight



Auto Power Off

After about five minutes of nonuse, the Product automatically powers off to save battery life. The Product emits two beeps when the power automatically turns off. The absence of the light indication at the tip or a continual light flash on ① serves as a visual power-off indication.

Maintenance

Cleaning

∧ ∧ Warning

For safe operation and maintenance of the product:

- Remove the Product from measurement circuits before you clean the Product.
- · Never use acid-based detergents or solvent liquids for cleaning.
- After cleaning, do not use the Product until the Product is dried completely.

To clean the Product, use a damp cloth and a mild detergent. DO NOT IMMERSE in liquid.

Product Disposal

Dispose of the Product in a professional and environmentally appropriate manner:

- Delete personal data on the Product before disposal.
- Remove batteries that are not integrated into the electrical system before disposal and dispose of batteries separately.

Battery Replacement (Breaker Finder)

The blinking red indication (trapezoid) at the tip indicates that the batteries need to be replaced.


⚠ Marning

To avoid possible electric shock or personal injury:

- Do not operate the Product with the battery door or portions of the cover removed or loosened.
- Remove the batteries if the Product is not used for an extended period of time, or if stored in temperatures above 50 °C. If the batteries are not removed, battery leakage can damage the Product.

- 1. Turn the Product over and use a flat-head screwdriver to loosen the battery door screw and remove the door.
- 2. Replace the batteries with two new AAA (LR03) batteries.
- 3. Reattach the battery compartment door and fasten the screw to lock position.

Figure 14. Battery Replacement



Specifications

General Safety Information is in the printed Safety Information document that shipped with the Product. More specific safety information is listed where applicable.

Complete specifications are in the printed Safety Information and online at www.fluke.com.

LIMITED WARRANTY AND LIMITATION OF LIABILITY

Each Fluke product is warranted to be free from defects in material and workmanship under normal use and service. The warranty period is two years and begins on the date of shipment. Parts, product repairs, and services are warranted for 90 days. This warranty extends only to the original buyer or end-user customer of a Fluke authorized reseller, and does not apply to fuses, disposable batteries, or to any product which, in Fluke's opinion, has been misused, altered, neglected, contaminated, or damaged by accident or abnormal conditions of operation or handling. Fluke warrants that software will operate substantially in accordance with its functional specifications for 90 days and that it has been properly recorded on nondefective media. Fluke does not warrant that software will be error free or operate without interruption.

Fluke authorized resellers shall extend this warranty on new and unused products to end-user customers only but have no authority to extend a greater or different warranty on behalf of Fluke. Warranty support is available only if product is purchased through a Fluke authorized sales outlet or Buyer has paid the applicable international price. Fluke reserves the right to invoice Buyer for importation costs of repair/replacement parts when product purchased in one country is submitted for repair in another country.

Fluke's warranty obligation is limited, at Fluke's option, to refund of the purchase price, free of charge repair, or replacement of a defective product which is returned to a Fluke authorized service center within the warranty period.

To obtain warranty service, contact your nearest Fluke authorized service center to obtain return authorization information, then send the product to that service center, with a description of the difficulty, postage and insurance prepaid (FOB Destination). Fluke assumes no risk for damage in transit. Following warranty repair, the product will be returned to Buyer, transportation prepaid (FOB Destination). If Fluke determines that failure was caused by neglect, misuse, contamination, alteration, accident, or abnormal condition of operation or handling, including overvoltage failures caused by use outside the product's specified rating, or normal wear and tear of mechanical components, Fluke will provide an estimate of repair costs and obtain authorization before commencing the work. Following repair, the product will be returned to the Buyer transportation prepaid and the Buyer will be billed for the repair and return transportation charges (FOB Shipping Point).

THIS WARRANTY IS BUYER'S SOLE AND EXCLUSIVE REMEDY AND IS IN LIEU OF ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO ANY IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. FLUKE SHALL NOT BE LIABLE FOR ANY SPECIAL, INDIRECT, INCIDENTAL OR CONSEQUENTIAL DAMAGES OR LOSSES, INCLUDING LOSS OF DATA, ARISING FROM ANY CAUSE OR THEORY.

Since some countries or states do not allow limitation of the term of an implied warranty, or exclusion or limitation of incidental or consequential damages, the limitations and exclusions of this warranty may not apply to every buyer. If any provision of this Warranty is held invalid or unenforceable by a court or other decision-maker of competent jurisdiction, such holding will not affect the validity or enforceability of any other provision.

Fluke Corporation 6920 Seaway Blvd. Everett, WA 98203 U.S.A. Fluke Europe B.V PO Box 1186 5602 BD EINDHOVEN The Netherlands

11/99