# **Specifications**

Power 24D = 18-26 VDC

Consumption <4VA

Latching (LA) <68mA de-energized

<75mA energized for 50ms DEN/ENE <100mA energized

Setpoint Range 5 to 50mA, customer specified

Setpoint Adjust Factory set only

Isolation Voltage 3KV Frequency Range DC

Accuracy +/-1mA at any setpoint

Sensing Aperture 0.75" (19mm)

Case UL 94V-0 Flammability Rated

**Output Rating & Environmental** 

Operating Temp.  $-20 \text{ to } 50^{\circ} \text{ C}(-4 \text{ to } 122^{\circ} \text{ F})$ Storage Temp.  $-30 \text{ to } 60^{\circ} \text{ C} (-22 \text{ to } 140^{\circ} \text{F})$ 

0-95% RH, Non Condensing

**SDT** SPDT (Form C) Relay

1A General Purpose @ 120 VAC

2A @ 30 VDC

LA SPST Relay

1A General Purpose @ 120 VAC

2A @ 30 VDC

#### Note:

Product is sensitive to ambient magnetic fields. Provide four inches of space between the sensor and any device producing a magnetic field including relays, contactors, transformers and motors.

# **Switching Response Time**

ON Delay (at 30mA set point)

5% over Setpoint
50% over Setpoint
100% over Setpoint
55 ms max
55 ms max
55 ms max

# **Model Number Key**

DG1 - SDT - DEN-24D-050

Setpoint

 $005 = 5 \text{mA} \ 050 = 50 \text{mA}$ 

Power Supply 24D 24VDC

#### **Contact Action**

DEN Normally Deenergized, Auto Reset
 ENE Normally Energized, Auto Reset
 LA Latching (NCR or NOR)

#### **OUTPUT:**

SDT Single Pole Double Throw (SPDT or

Form C) relay

NCR Normally Closed (latches open on fault) NOR Normally Open (latches closed on fault)

#### **SENSING RANGE:**

1 Factory Set 5 to 50mA

#### **SENSOR TYPE:**

<u>DG</u> DC current sensing switch factory set trip point

#### **Sensors and Transducers**





#### Other NK Technologies Products Include:

AC & DC Current Transducers
AC & DC Current Operated Switches
1\$\phi\$ & 3\$\phi\$Power Transducers
Current & Potential Transformers (CTs&PTs)



**NK Technologies** 

3511 Charter Park Drive, San Jose, CA 95136 800-959-4014 or +1-408-871-7510 Phone +1-408-871-7515 FAX

sales@nktechnologies.com, www.nktechnologies.com



# **INSTRUCTIONS**



# DG SERIES DC Ground Fault Sensor

#### **Quick "How To" Guide**

- 1. Run the current carrying conductors you are monitoring through aperture.
- 2. Mount the sensor.
- 3. Connect power & output wiring.
  - A. Make sure power supply matches specifications.
  - B. Make sure output load matches the output shown on the sensors' label.

#### **Description**

DG Series are DC current operated relays designed to detect low level fault leakage from either positive or negative conductor to earth. They operate (switch) when the current level through the hole exceeds the setpoint. They are powered from 24 VDC. The outputs are isolated from the monitored circuit and the power supply.

#### Installation

Run both the positive and negative conductors feeding the monitored circuit load through opening in the sensor.

The sensor can be attached to a panel using screws through the mounting holes in the tabs. Tighten to 7 in/lbs maximum (snug will be fine, overtightening can damage the housing). Use the DIN-2 accessory kit for mounting to a DIN rail. DG switches work in the same environment as motors, contactors, heaters, pull-boxes, and other electrical enclosures. They can be mounted in any position or hung directly on wires with a wire tie. Leave at least four inch distance between sensor and other magnetic material. Relays, contactors, motors and transformers can cause the sensor to operate if they are too close to the sensing window.

# **Power Wiring**

Connect 24 VDC power to Terminals 1 and 2. Tighten to 4.5 In-Lb torque. The power supply connection is not polarity sensitive.

# **Output Wiring**

Connect control or monitoring wires to the sensor. Use up to 12-22 AWG copper wire and tighten terminals to 4.5 In-Lb torque. Be sure the output load does not exceed the switch rating.

Incandescent lamps can have "Cold Filament Inrush" current of up to 10 times their rated amperage. Use caution when switching lamps.


### **Setpoint Selection**

#### Range & Setpoint

DG relays are calibrated to operate at a set current value:

- 1. Determine what amount of fault current to be detected.
- 2. Chose auto reset or latching version.

Choosing a setpoint can be a challenge. Humans can usually feel 5mA, but the most common setpoint to protect equipment (heat strips) is 30mA. This sensor can be set to change contact state up to 50mA.




#### Auto reset connection.

Both NO and NC contacts can be used.

#### CONTACT ACTION TABLE

	No Power		Powered		Fault Detected	
	NO	NC	NO	NC	NO	NC
DEN	Open	Closed	Open	Closed	Closed	Open
ENE	Open	Closed	Closed	Open	Open	Closed
LA	Open	Closed	Open	Closed	Closed	Open
LED ACTION TABLE						
	Power	Status	Power	Status	Power	Status
DEN	Off	Off	On	Off	On	On
ENE	Off	Off	On	On	On	Off
LA	Off	Off	On	Off	On	On

Note that the Power LED indicates that the sensor is energized Note that the Status LED indicates that the output contacts have changed state: NO has closed, NC has opened.



#### Latching connection.

Order either NO or NC contacts. Reset by short across RESET terminals, do not apply voltage.

# **Trouble Shooting**

#### 1. Sensor is always tripped

- A. The setpoint may be set too low for current being monitored. *Find the fault in the monitored circuit or return to the factory to reset the trip point.*
- B. Switch has been overloaded and contacts are burned out. *Check the output load, remembering to include inrush on inductive loads (coils, motors, ballasts).*

#### 2. Sensor will not trip

- A. Unit is not powered. *Check power supply and power wiring.*
- B. The setpoint may be higher than the fault current. *Try the TEST button with no load connected to the output terminals.*
- C. Switch has been overloaded and contacts are burned out. Check the output load, remembering to include inrush on inductive loads (coils, motors, ballasts).