
INSTALLATION INSTRUCTIONS ADDENDUM



Powered Suspended Ceiling Projector System



205 Westwood Ave, Long Branch, NJ 07740 Phone: 866-94 BOARDS (26273) / (732)-222-1511 Fax: (732)-222-7088 | E-mail: sales@touchboards.com



SYSAUxP2

SYSAUxP2 Installation Instructions

DISCLAIMER

Milestone AV Technologies, and its affiliated corporations and subsidiaries (collectively, "Milestone"), intend to make this manual accurate and complete. However, Milestone makes no claim that the information contained herein covers all details, conditions or variations, nor does it provide for every possible contingency in connection with the installation or use of this product. The information contained in this document is subject to change without notice or obligation of any kind. Milestone makes no representation of warranty, expressed or implied, regarding the information contained herein. Milestone assumes no responsibility for accuracy, completeness or sufficiency of the information contained in this document.

Chief® is a registered trademark of Milestone AV Technologies. All rights reserved.



IMPORTANT SAFETY INSTRUCTIONS

A WARNING alerts you to the possibility of serious injury or death if you do not follow the instructions.

A CAUTION alerts you to the possibility of damage or destruction of equipment if you do not follow the corresponding instructions.

MARNING: FAILURE TO READ AND

FOLLOW THE FOLLOWING INSTRUCTIONS CAN RESULT IN SERIOUS PERSONAL INJURY, DAMAGE TO EQUIPMENT OR VOIDING OF FACTORY WARRANTY. It is the installer's responsibility to make sure all components are properly assembled and installed using the instructions provided.

READ ALL INSTRUCTIONS BEFORE USING THIS PRODUCT!!!!

DANGER: TO REDUCE THE RISK OF

ELECTRIC SHOCK:

1. Always turn off power at source before installing the outlet.

A WARNING: TO REDUCE THE RISK OF

BURNS, FIRE, ELECTRIC SHOCK, OR INJURY TO PERSONS:

- Always turn off power at source before servicing or removing the outlet.
- Do not use outdoors For indoor use only.
- Route cables as shown in these installation instructions.
- To disconnect, turn off power at source.



MARNING: RISK OF ELECTRIC SHOCK!

Make sure the outlet is properly grounded. See Grounding Instructions.

A WARNING: Failure to provide adequate

structural strength for this outlet can result in serious personal injury or damage to equipment! It is the installer's responsibility to make sure the structure to which this mount is attached can support the weight of the box.

A CAUTION: Apparatus shall not be exposed to

dripping or splashing and no objects filled with liquids, such as vases, shall be placed on the apparatus.

CAUTION: This equipment must be installed

and assembled by qualified service personnel in accordance with local building and electrical codes.


NOTE: Knockouts are provided for ease of installation. Any unused knockouts that have been punched are to be

closed up with a metal plug.

NOTE: Ambient Temperature - The manufacturer's maximum ambient temperature is 104°F (40°C) and minimum ambient temperature is 30°F (-1°C) so that the installer is able to determine acceptability of use of Accessories and components.


--SAVE THESE INSTRUCTIONS--

DIMENSIONS




SYSAUxP2 Installation Instructions

LEGEND



TOOLS REQUIRED FOR INSTALLATION / PARTS



Isolated Ground Receptacle

This product incorporates an isolated ground receptacle, identified by the orange triangle on its face. This feature may be useful to reduce common noise in the connected equipment. Its intended use is to reduce electrical noise (electromagnetic interference) by purposely insulating the grounding circuit from any metallic wiring system. The ground pin of the receptacle is connected to the green/yellow wire and is isolated from the metal mounting yoke of the receptacle. The accessible metal of the product is connected to the green wire. If it is not desired to use this feature, connect the green/yellow and green wires together.

References

Application Guide for Isolated Ground Wiring Devices 2007, National Electrical Manufacturers Association (NEMA)

IEEE Std 1100™-2005, "IEEE Recommended Practice for Powering and Grounding Electronic Equipment" (Emerald Book), Section 8.5.3.2.

IEEE Std 142[™]-2007, "IEEE Recommended Practice for Grounding of Industrial and Commercial Power Systems" (Green Book), Sections 5.5.1, 5.5.2

NFPA-70, "National Electrical Code", Article 250.146 Connecting Receptacle Grounding Terminal to Box.

- (D) Isolated Ground Receptacles. Where installed for the reduction of electrical noise (electromagnetic interference) on the grounding circuit, a receptacle in which the grounding terminal is purposefully insulated from the receptacle mounting means shall be permitted. The receptacle grounding terminal shall be connected to an insulated equipment grounding conductor run with the circuit conductors. This equipment grounding conductor shall be permitted to pass through one or more panel boards without a connection to the panel board grounding terminal bar as permitted in 408.40, Exception, so as to terminate within the same building or structure directly at an equipment grounding conductor terminal of the applicable derived system or service. Where installed in accordance with the provisions of this section, this equipment grounding conductor shall also be permitted to pass through boxes, wire ways, or other enclosures without being connected to such enclosures.
- Informational Note: Use of an isolated equipment grounding conductor does not relieve the requirement for grounding the raceway system and outlet box.

C22.2 No. 1, "Canadian Electrical Code, Part 1", Rule 10-906 Bonding conductor connection to circuits and equipment.

- (6) A bonding jumper shall be installed to connect the bonding conductor to the grounding terminal of a receptacle and in such a manner that disconnection or removal of the receptacle will not interfere with, or interrupt grounding continuity.
- (7) In the case of metallically enclosed systems where the grounding path is provided by the metal enclosure, a bonding jumper shall be installed to bond the grounding terminal of the receptacle to the enclosure.
- (8) Notwithstanding Sub-rules (6) and (7), the bonding jumper, in the case of receptacles having grounding terminals isolated from the mounting strap required for special equipment, shall be permitted to be extended directly back to the distribution panel.



WARNING: IMPROPER INSTALLATION CAN RESULT IN DEATH OR SERIOUS PERSONAL INJURY! This mounting system should be installed by qualified personnel.

IMPORTANT!: In addition to the SYSAU installation instructions accompanying the products, the following steps must also be taken when installing the **SYSAUxP2**.

NOTE: The SYSAUxP2 must be connected to a 15 Amp branch circuit.

NOTE: In some installations, the electrical install may be facilitated by loosening the wing nut and removing the entire outlet plate from the SYSAUxP2. (See Figure 1)




Figure 1

IMPORTANT!: There are two different methods of SYSAUxP2 installation:

- If installing the SYSAUxP2 in the flush mode, proceed to Installing in Flush Mode section.
- If installing the SYSAUxP2 in the above-tile mode, proceed to Installing in Above-Tile Mode section.

Installing in Flush Mode

- Loosen, but do not remove, two Phillips head screws holding outlet box to outer housing. (See Figure 2)
- Rotate outlet box counter-clockwise until it is free to be removed from housing. (See Figure 2)
- 3. Remove outlet box from housing. (See Figure 2)




Figure 2

4. Wire the outlet box as required. Refer to Table 1 and Table 2 for input and output specifications. (See Figure 3)

Table 1: Input Specifications

Input	
Input voltage, frequency	125 V AC, 60 Hz
Input connection type	4x14 AWG stranded, UL Style 1015, CSA TEW
Input Wire colors	Black - Line
	White - Neutral
	Green - Box Ground
	Green/Yellow - Isolated Ground
Input wire length (ft.)	1 (with a 3/4" stripped end)

Table 2: Output Specifications

Output	
Output	15 A, 1875 W
Power consumption	<0.5 watt
Fuses	Thermal current interrupting circuits are in MOVs
Quantity/Type	Duplex NEMA 5-15R Isolated Ground Receptacle
Color/Markings	Grey with protection symbol (Orange triangle)



CAUTION: Isolated ground-mounting means NOT grounded. Grounding wire connection required.

IMPORTANT!: If a separate isolated green/yellow ground wire is installed in the building wiring, attach it separately to the green/yellow isolated ground wire on box. If there is no separate green/yellow isolated ground wire, connect green ground wire to both green/yellow isolated ground wire and green box ground wire on box.

NOTE: The grounding conductors serving this outlet are to be connected to earth ground at the service equipment or other acceptable building earth ground such as the building frame in the case of a high-rise steel-frame structure. Connections should be made with minimum AWG 14 copper wire intended for use on a 15 Amp circuit. The conductors used to connect the outlet to the line or bus and ground shall not be any longer than necessary and shall avoid unnecessary bends.

NOTE: An insulated grounding conductor that is identical in size and insulation material and thickness to the grounded and ungrounded circuit supply conductors, except that it is green with or without one or more yellow stripes, is to be installed as part of the circuit that supplies the outlet. Refer to Table 250-122 of the National Electrical Code regarding the appropriate size of the grounding conductor.

NOTE: Pressure terminal or pressure splicing connectors and soldering lugs used in the installation of the outlet shall be identified as being suitable for the material of the conductors. Conductors of dissimilar metals shall not be intermixed in a terminal or splicing connector where physical contact occurs between dissimilar conductors unless the device is identified for the purpose and conditions of use.




Figure 3

- 5. Replace the outlet box in the housing. (See Figure 4)
- Rotate outlet box clockwise until it is in proper position to be secured to the housing. (See Figure 4)
- Tighten two Phillips screws to secure outlet box to housing. (See Figure 4)




Figure 4



 Install outlet cover (B) over outlet box using one 6-32 x 1/2" Phillips flat head screw (F) and one #06 lock washer (G). (See Figure 5)

NOTE: Be sure to line up hole in outlet cover over light in outlet.




Figure 5

9. Proceed to Outlet Box Use section.

Installing in Above-Tile Mode

- Loosen, but do not remove, two Phillips head screws holding outlet box to outer housing. (See Figure 6)
- 2. Rotate outlet box counter-clockwise until it is free to be removed from housing. (See Figure 6)
- 3. Remove outlet box from housing. (See Figure 6)




Figure 6

- Remove four Phillips screws from ring attached to outlet box. (See Figure 7)
- 5. Remove and discard ring from outlet box. (See Figure 7)




Figure 7

 Wire the outlet box as required. Refer to Table 1 and Table 2 on previous page) for input and output specifications. (See Figure 3)

- Lower outlet box into the mud ring (C) and attach two screw spacers (D) inside the mud ring on either side of outlet box using four 06-32 x 3/16" Phillips pan head screws (E). (See Figure 8)
- 8. Lower housing from above SYSAU, install outlet box assembly up into housing, and rotate clockwise into place. (See Figure 8) and (See Figure 9)




Figure 8

9. Tighten existing Phillips head screws (in outlet housing) to hold in place. (See Figure 9)

NOTE: Follow installation instructions (included with the SYSAU) to complete installation. Proceed with Step 10 after the SYSAU is installed above the tile.

NOTE: Be sure to line up hole in outlet cover over light in outlet.

 Install outlet cover (B) over outlet box using one 6-32 x 1/2" Phillips flat head screw (F) and one #06 lock washer (G). (See Figure 9)




Figure 9

Outlet Box Use

NOTE: The "PROTECTED" light indicates that the surge protection circuitry is active and operational. (See Figure 10)




Figure 10

11. Complete the installation following the SYSAU installation instructions.

SYSAUxP2 Installation Instructions

SYSAUxP2 Installation Instructions



205 Westwood Ave, Long Branch, NJ 07740 Phone: 866-94 BOARDS (26273) / (732)-222-1511 Fax: (732)-222-7088 | E-mail: sales@touchboards.com

Europe



Our Mounts. Your Vision.

Chief, a products division of Milestone AV Technologies

8800-002795 Rev00 ©2016 Milestone AV Technologies www.milestone.com 05/16 USA/International A 6436 City West Parkway, Eden Prairie, MN 55344

P 800.582.6480 / 952.225.6000

F 877.894.6918 / 952.894.6918

A Franklinstraat 14, 6003 DK Weert, Netherlands

P +31 (0) 495 580 852

F +31 (0) 495 580 845

Asia Pacific A Office No. 918 on 9/F, Shatin Galleria

18-24 Shan Mei Street Fotan, Shatin, Hong Kong

P 852 2145 4099

F 852 2145 4477

