

---

# PR Digital Range of Phase Comparison Equipment

## Operating Instructions

---



Bracken Hill, South West Industrial Estate,  
Peterlee, Co. Durham. SR8 2SW. England.  
Tel: +44 (0)191 586 3511 Fax: +44 (0)191 586 0227  
[www.seaward.co.uk](http://www.seaward.co.uk)  
[sales@seaward.co.uk](mailto:sales@seaward.co.uk)  
[service@seaward.co.uk](mailto:service@seaward.co.uk)

**Limited Warranty & Limitation of Liability**

SEAWARD Electronic Limited guarantees this product to be free from defects in material and workmanship under normal use and service for a period of 1 year. The period of warranty will be effective at the day of delivery.

© Copyright 2008

All rights reserved. Nothing from this edition may be multiplied, or made public in any form or manner, either electronically, mechanically, by photocopying, recording, or in any manner, without prior written consent from SEAWARD Electronic Limited. This also applies to accompanying drawings and diagrams.

Due to a policy of continuous development SEAWARD Electronic Limited reserves the right to alter the equipment specification and description outlined in this publication without prior notice and no part of this publication shall be deemed to be part of any contract for the equipment unless specifically referred to as an inclusion within such contract.

**Disposal of Old Product**

This product has been designed and manufactured with high quality materials and components that can be recycled and reused.

When the crossed out wheelex bin symbol is attached to a product it means the product is covered by the European Directive 2002/96/EC.

Please familiarise yourself with the appropriate local separate collection system for electrical and electronic products.

Please dispose of this product according to local regulations. Do not dispose of this product along with normal waste material. The correct disposal of this product will help prevent potential negative consequences for the environment and human health.

**PR Digital Range Phase Comparison Equipment**

The Seaward PR Digital Range of Phase Comparison Equipment provides a means of confirming the presence of voltage on electrical circuits from 1 to 33KV.

The PR Digital Range of Phase Comparison Equipment complies with the UK Electricity Council Engineering Recommendation G9.

**Contents**


1. **User Notes**
2. **Safety Notes**
3. **Standard Accessories**
4. **Description**
5. **Electrical Specifications**
6. **Operation**
7. **Battery Charging**
8. **Extension & Bent Rods**
9. **Proving Unit**
10. **Maintenance**
11. **Cleaning**


**1.0 User Notes**

These operating instructions are intended for the use of competent personnel.

**The PR Digital Range of Phase Comparison Equipment has been designed to make measurements in a dry environment.**

The following symbols are used in these operating instructions and on the PR Digital Range of Phase Comparison Equipment

 Warning of electrical danger!  
Indicates instructions must be followed to avoid danger to persons.

 Important, follow the documentation!  
This symbol indicates that the operating instructions must be adhered to in order to avoid danger.

**2.0 Safety Notes**

This PR Digital Range of Phase Comparison Equipment has been built and tested in accordance with:

BS EN 61243-2

To ensure safe operation of the unit, all notes and warnings in these instructions must be observed at all times.

**This instrument should only be used by competent, suitably trained personnel after due consideration of any hazard involved.**



**Never hold the instrument between the hand guard / digital display housing and the contact electrode.**



**The Phase Comparison Equipment and all associated cables and leads must be checked for signs of damage before the equipment is operated.**



**Always proof test before and after use.**



**Always ensure equipment is properly rated for use at the voltage in the system under test**



**Never allow any part of the instrument below the contact electrode to make contact with a live high voltage conductor**

Where safe operation of the equipment is no longer possible it should be immediately shutdown and secured to prevent accidental operation.

It must be assumed that safe operation is not longer possible:

- if the equipment or the cable show visible signs of damage, or
- the instrument does not function, or
- after long periods of storage under adverse environmental conditions.

**3.0 Accessories****3.1 Standard Accessories**

- PH3 proving unit (Part No 112A913)
- PSU100 battery charger (Part No 124A912)
- 1.5m Straight extension rod x 2 (Part No 141A901)
- Earth Lead 3m (Part No 109A019)
- Carry Case (Part No 71G014)

**3.2 Optional Accessories**

- 90 degree bent end extension rod (Part No 141A900)
- 120 degree bent end extension rod (Part No 141A912)

**4.0 Description**

The PR Instrument Range provides a means of determining the voltage on electrical circuits (when used as a potential indicator) or when connected to a secondary element enables phase angle comparison and indication of phase angle voltage at the point of paralleling two circuits.

The equipment has the following features:-

- 4.1 The units consist of an element manufactured from a high quality PVC grade 7 tube that conforms to BS3506. The tube supports and isolates a chain of high value internal resistors.
- 4.2 The total encapsulation of the load element prevents any internal tracking or leakage.
- 4.3 A handguard in the form of a digital display housing on the handle section of the unit prevents the operators hands from straying towards the high voltage ends of the potential indicator.
- 4.4 An additional phasing rod (secondary element) manufactured from the same high quality PVC as indicated in section 4.1 and supports / isolates another chain of high value resistors.
- 4.5 The phasing rod is also manufactured with a handguard and provides total encapsulation of the load elements.

- 4.6 The digital voltage display is incorporated into the handguard housing.
- 4.7 An external domed contact electrode ensures a positive contact with any terminal required to be tested.
- 4.8 An insulated earth cable is connected to the potential indicator section of the equipment through the handle. The earth cable is detachable. This earth cable is fitted with a suitable clamp that allows the operator to reference the potential indicator to a suitable earth.

**5.0 Electrical Specifications**

	PR15D	PR33D
Maximum System voltage	15kV	33kV
Maximum Voltage to earth	8.6kV	19kV
Measuring Range	0.00kV-8.6kV	0.0kV-19.0kV
Resolution	10V	100V
Sensitivity	AC/DC	AC/DC
Circuit current (IEC 61234-2)	0.5mA nominal @8.6kV	0.9mA nominal @19kV
Dielectric leakage current (IEC 61234-2)	7uA nominal @ 18kV	23uA nominal @ 40kV
Length (mm)	600	600
Diameter (mm)	25	25
Handle length (mm)	235	235
Hand guard height (mm)	23.5	23.5
Contact Electrode Type	Domed	Domed


**Extension Rods**

	1.5m Straight	90°	120°
Maximum System voltage	33kV	15kV	33kV
Dielectric leakage current	140uA nominal @ 40kV	50uA nominal @ 18kV	130uA nominal @ 40kV
Length (mm)	1500	780	780
Diameter (mm)	25	25	25
Contact Electrode Type	"V" form	Domed	Domed



**6.0 Operation****6.1 Potential Indicator/Voltage measurement**

6.1.1 The insulated earth cable, 3m in length, is connected by means of a plug and socket arrangement to the bottom of the handheld section of the potential indicator.



6.1.2 On connection of the insulated earth cable to the bottom of the handheld section the digital display is automatically powered up and zeroed ready for operation.



**Always screw up the plug and socket securely.**

6.1.3 Before use the digital unit must be proof tested on a suitable proving unit such as the supplied Seaward PH3 proving unit. Refer to section 9.0

6.1.4 The earth clamp attached to the free end of the insulated earth cable must be attached to a suitable earth point i.e. an earthed strip of frame or an earth electrode.

6.1.5 The contact electrode of the digital unit should be positioned such as to make contact with the voltage source to be measured. The digital display will indicate the value of the voltage present.



**Never hold the potential indicator between the hand guard and the exposed metal head.**

6.1.6 The potential indicator must be applied in turn to each phase of the system under test.


- 6.1.7 After use the potential indicator must be proof tested on a suitable proving unit such as the supplied Seaward PH3 proving unit. Refer to section 9. 0
- 6.1.8 Once testing is complete unclip the earth clamp from the reference earth point. Disconnect the earth cable from the bottom of the potential indicator and replace the protective cap over the plug of the potential indicator.



**Always ensure the earth cable is disconnected from the potential indicator when not in use to prevent the battery from being fully discharged.**

## 6.2 Phase Detection

- 6.2.1 The insulated earth cable, 2m in length, along with the 600mm linking cable permanently connected to the phasing rod are connected by means of a plug and socket arrangement to the bottom of the handheld section of the potential indicator.



- 6.2.2 On connection of the insulated earth cable to the bottom of the handheld section the digital display is automatically powered up and zeroed ready for operation.



**Always screw up the plug and socket securely.**

- 6.2.3 The earth clamp attached to the free end of the insulated earth cable needs to be attached to a suitable earth point i.e. an earthed strip of frame or an earth electrode.

- 6.2.4 Before use both the digital unit and phasing rod must be proof tested on a suitable proving unit such as the supplied Seaward PH3 proving unit. Refer to section 9.0
- 6.2.5 The contact electrode digital unit should be positioned such as to make contact with a conductor or terminal of the first circuit. The digital unit will display the value of any voltage present at the contact electrode.
- 6.2.6 The contact electrode of the phasing rod is then, applied, in turn, to each phase conductor or terminal on the second circuit.



**Never hold the potential indicator between the hand guard and the exposed contact electrode.**

- 6.2.6 The display will now indicate the potential difference between the two contact electrodes i.e. a reading proportional to phase angle difference and the rated voltage of the system when the digital unit and the phasing rod are between different phases. When the digital unit and phasing rod are connected to the same phase, the display will indicate a reading <900V depending on the capacitance to earth of the primary and secondary elements.
- 6.2.7 After use both the digital unit and phasing rod must be proof tested on a suitable proving unit such as the supplied Seaward PH3 proving unit. Refer to section 9.0
- 6.2.8 Once testing is complete unclip the earth clamp from the reference earth point. Disconnect the earth and linking cable from the bottom of the potential indicator element of the phase comparison equipment and replace the protective cap over the plug of the potential indicator



**Always ensure the earth and link cable are disconnected from the potential indicator when not in use to prevent the battery from being fully discharged.**

**7.0 Battery Charging**

**A “BAT” sign on the digital display of the potential indicator unit of the Phase Comparison Equipment denotes that the battery requires charging.**



**During prolonged storage periods the battery will discharge. In order to increase the battery life the instrument should be charged periodically.**

- 7.1 Remove the protective cap from the connector on the bottom of the hand held section of the digital unit.
- 7.2 Insert the 6 pin socket flying lead from the PSU100 battery charger – Seaward Part 124A912 into the connector and firmly screw into place. Connect the mains lead from the charger to a 240VAC 50Hz supply and switch on.
- 7.3 When mains power is applied to the battery charger, one LED is continuously illuminated and a second LED will flash approximately every 5 seconds to indicate the battery is being charged.
- 7.4 After approximately 14 hours the continuously illuminated LED will be extinguished indicating charging is completed.
- 7.5 On completion of the charging cycle, disconnect the battery charger supply from mains, disconnect the 6 pin socket from the base of the potential indicator and replace the protective cap over the plug.



**Do not use the potential indicator on a high voltage circuit while the battery is on charge.**

**8.0 Extension & Bent End Rods****8.1 Attachment**

- 8.1.1 Loosen but do not fully remove the knurled head on the extension rod.
- 8.1.2 Remove the domed head from the digital unit and / or phasing rod. Store the domed heads in a safe location.
- 8.1.3 Screw the extension rod onto either the digital unit or phasing rod and ensure that the two elements are fully mated without over tightening.
- 8.1.4 Tighten the knurled head at the end of the extension rod to secure the two elements together.



**At no time after the extension unit has been fully tightened to either the digital unit or phasing rod should any attempt be made to separate the two elements until all testing (including proof testing) has been completed.**

- 8.1.5 To remove an extension rod from either the digital unit or phasing rod, loosen the knurled head at the end of the extension rod before unscrewing the extension rod from either the digital unit or the phasing rod.
- 8.1.6 Replace the domed head on the digital unit and / or phasing rod and tighten the knurled head on the extension rod when complete.

**8.2 Operation of Extension and Bent end Rods on HV Systems**

- 8.2.1 Extension rods can be used on a HV system with either the digital unit or phasing rod. Extension rods cannot be used without first being connected to either a digital unit or phasing rod.
- 8.2.2 The digital unit and phasing rod can be used on a HV system up to the designated voltage levels without an extension rod.



**Always fit the forked head to extension rods when testing Overhead Lines.**

**8.3 Proof Testing**

- 8.3.1 Extension rods must be proof tested using the Seaward PH3 proving unit, both before and after use. For more detailed information see section 9.

**9.0 Proof Testing****9.1 Features of a PH3 Proving Unit**


- 9.1.1 The terminations on the unit comprise of a knurled earth terminal at one end and a small metal probe on top of the unit. The small metal probe on top of the unit is manufactured to accommodate a domed contact electrode.
- 9.1.2 A push switch operates the test voltage output.
- 9.1.3 The unit requires an alkaline PP3 type battery, also identified as a MN1604 and with the IEC identifier 6LR61.
- 9.1.4 Ensure that the red LED on the proving unit operates before and after the unit has been used.



**Warning – Do not touch the earth terminal and the brass tip on the proving unit simultaneously. When the push button is pressed a high voltage is generated between these points.**

**9.2 Proof testing as a potential indicator**

- 9.2.1 Connect the insulated earth cable, 3m in length, by means of a plug and socket arrangement to the bottom of the handheld section of the digital unit.
- 9.2.2 On connection of the insulated earth cable to the bottom of the handheld section the digital display is automatically powered up and zeroed ready for operation
- 9.2.3 The earth clamp attached to the free end of the insulated earth cable should be attached to the knurled earth terminal on the proving unit.
- 9.2.4 Push the digital unit contact electrode on to the brass contact on the PH3 proving unit.



- 9.2.5 Press the pushbutton on the proving unit. The display on the digital potential indicator will give a reading between 1000V and 1500V depending on the condition of the battery in the PH3.




**Warning – Do not touch the earth terminal and the brass tip on the proving unit simultaneously. When the push button is pressed a high voltage is generated between these points.**

- 9.2.6 On completion of the proving test, release the push button.


### 9.3 Proof testing as a phase comparator

- 9.3.1 Connect the insulated earth cable, 2m in length, along with the 600mm linking cable permanently connected to the phasing rod and connected by means of a plug and socket arrangement to the bottom of the handheld section of the potential indicator.
- 9.3.2 On connection of the insulated earth cable to the bottom of the handheld section the digital display is automatically powered up and zeroed ready for operation.
- 9.3.3 Push the digital unit contact electrode on to the brass contact on the PH3 proving unit.





- 9.3.4 Press the pushbutton on the proving unit. The display on the digital potential indicator will give a reading between 1000V and 1500V depending on the condition of the battery in the PH3.
- 9.3.5 Push the digital unit contact electrode on to the brass contact on the PH3 proving unit.



- 9.3.6 Press the pushbutton on the proving unit. The display on the digital potential indicator will give a reading between 1000V and 1500V depending on the condition of the battery in the PH3.



**Warning – If the readings between digital unit and phasing rod are >20% then DO NOT USE the phase comparison equipment**

- 9.3.7 On completion of the proving test, release the push button, disconnect the earth clamp from the knurled nut and remove the proving unit brass tip from the exposed metal head of the phasing rod.

**10.0 Maintenance**

- 10.1 The PR digital range of phase comparison equipment is extremely robust and should always be kept free from dust or any loose carbon particles.
- 10.2 Ensure the PR digital range of phase comparison equipment is kept dry with no surface moisture on either the body or housing / hand guard of the indicator or phasing rod.
- 10.3 The body of both the potential indicator and phasing rod should be regularly inspected to ensure no deep scratches or physical damage.
- 10.4 Ensure the insulation of the earth and linking cable is fully intact and that no sharp creases have occurred in the cable.
- 10.5 It is recommended that the phase comparison equipment should be regularly proof tested at scheduled maintenance intervals as well as before and after testing on energised circuits.
- 10.6 If any of the above conditions have been observed then the phase comparison equipment must be appropriately secured to prevent any further use.



**Always ensure the earth cable is disconnected from the potential indicator when not in use, to prevent the battery from being fully discharged.**

**11.0 Cleaning**

- 11.1 Clean the external case of the phase comparison equipment with a clean dry cloth.
- 11.2 Avoid using solvents and abrasive scouring agents to clean the external case of phase comparison equipment.
- 11.3 Check the battery contacts and mounting compartment are free of electrolytic contamination.
- 11.4 Any contamination of the battery contacts or compartment should be cleaned with a dry cloth.