

WÖHLER

Operating manual
Service Camera **US**

Wöhler VIS 200 / 250
Wöhler VIS 300 / 350



Order no. 23102 2016-07-13

The measure of technology

Contents

| | | |
|----------|--|---|
| 1 | General Information..... | 4 |
| 1.1 | Information about the operating instructions . | 4 |
| 1.2 | Notes..... | 4 |
| 1.3 | Proper use..... | 5 |
| 1.4 | Scope of supply..... | 5 |
| 1.5 | Transporting..... | 6 |
| 1.6 | Information on disposal..... | 6 |
| 1.7 | Manufacturer's address..... | 6 |
| 2 | Important information | 7 |
| 3 | Camera Models | 9 |
| 4 | Technical data | 10 |
| 4.1 | Monitor..... | 10 |
| 4.2 | Miniature Camera Head (Wöhler VIS 200/250)..... | 10 |
| 4.3 | Miniature Camera Head (Wöhler VIS 300/350)..... | 11 |
| 4.4 | Push rod..... | 12 |
| 4.5 | Electronic distance counter..... | 12 |
| 4.6 | Memory (Wöhler VIS 250 / 350)..... | Fehler! Textmarke nicht definiert. |
| 6 | Design and function | 13 |
| 6.1 | Video inspection system..... | 13 |
| 6.2 | Control panel..... | 15 |
| 6.3 | Monitor..... | 18 |
| 6.3.1 | Adjusting the Color..... | 18 |
| 6.3.2 | Transition from 16:9 Screen to 4:3 Screen.. | 19 |
| 7 | Getting started | 20 |
| 7.1 | Rechargeable battery status and recharging | 20 |
| 7.2 | Working position..... | 22 |
| 8 | Working with the camera | 22 |
| 8.1 | Switching on the system and monitor..... | 22 |
| 8.2 | Memory (Wöhler VIS 250 / 350)..... | 24 |
| 8.3 | Inspection..... | 27 |

| | | |
|-----------|--|-----------|
| 8.4 | Information displayed on the monitor | 27 |
| 8.4.1 | Displaying the position of the camera head (Wöhler VIS 250/350) | 27 |
| 8.5 | Home Function (only Wöhler VIS 350) | 28 |
| 8.6 | Video Record (Wöhler VIS 250 / 350)..... | 29 |
| 8.7 | Video playback (Wöhler VIS 250 / 350) | 29 |
| 9 | Images (Wöhler VIS 250 / 350)..... | 30 |
| 10 | Delete a Video (Wöhler VIS 250 / 350) | 30 |
| 11 | Transferring images and videos to a PC (Wöhler VIS 250/350) | 31 |
| 12 | Video Playback at PC (Wöhler VIS 250/350)..... | 32 |
| 12.1 | Installing the VLC viewer | 32 |
| 12.2 | Generating snapshots..... | 32 |
| 12.3 | Output directory for snapshots..... | 33 |
| 13 | Guide accessories | 34 |
| 14 | Faults | 35 |
| 15 | Maintenance | 36 |
| 15.1 | Regular maintenance..... | 36 |
| 15.2 | Changing the dome of the Camera Head Wöhler VIS 300/350..... | 36 |
| 15.3 | Camera head..... | 36 |
| 15.4 | Push rod | 36 |
| 15.5 | Monitor..... | 36 |
| 16 | Accessories..... | 37 |
| 17 | Warranty Wohler VIS Service Camera | 38 |
| | Points of sale and service | 41 |

1 General Information

1.1 Information about the operating instructions

Read these operating instructions carefully. They will enable you to operate the Wöhler VIS 200/250 and VIS 300/350 safely. Keep this manual for your information

This manual refers to different camera models. Therefore it may include instructions which do not apply to your camera. Those explanations which do not mention one or more camera models explicitly, refer to all four models.

The Wöhler VIS 200/250 and Wöhler VIS 300/350 should be used by trained professionals for its intended use only.

Liability is voided for any damages caused by not following this manual.

1.2 Notes



WARNING!

Not following this warning can cause injury or death.



ATTENTION!

Not following this note can cause permanent damage to the camera.



NOTE!

Useful information

1.3 Proper use

The Camera is designed to visually inspect and document the condition of pipes and shafts, for example in flue gas systems, ventilation systems as well as for inspecting underground pipes etc. The device is designed to be used by trained professionals only. Any other use is considered improper use.

1.4 Scope of supply

| Device | Scope of supply |
|--|--|
| Wöhler VIS 200 / 250 Wöhler VIS 300 / 350 | Case |
| | Push rod |
| | Monitor |
| | 1 anti-slide-mat |
| | NiMH battery |
| | mini USB cable (Wöhler VIS 250 / 350) |
| Wöhler VIS 200/250/300 | 1 rechargeable battery 12 V NiMH |
| Wöhler VIS 350 | 2 rechargeable batteries 12 V NiMH |
| Wöhler VIS 200 / 250 | Miniature Camera Head Color |
| Wöhler VIS 300 / 350 | Pan & tilt color camera head |
| | 5 replacement plastic domes |
| Wöhler VIS 250 / 350 | SD card 4 GB |

1.5 Transporting

To avoid damage occurring during transport it is imperative that the instrument is transported in the original case designed for the purpose.

1.6 Information on disposal



Do not dispose of electronic equipment in domestic waste. Dispose of electronic equipment in accordance with applicable environmental regulations.

You may hand in any defective batteries taken out of the unit to our company as well as to recycling places of public disposal systems or to selling points of new batteries or storage batteries.



1.7 Manufacturer's address **Wöhler Technik GmbH**

Schützenstr. 41
33181 Bad Wünnenberg
Tel.: +49 2953 73-100
Fax: +49 2953 73-96100
Email: info@woehler.com

2 Important information

Eye protection



WARNING!

Never point a connected camera head at your own or somebody else's eyes when the camera is switched on. The LEDs are extremely bright and can cause eye damage.



WARNING!

Guide the rod with due care and attention. As the rod is made of flexible material, it can make whipping movements if it slips. Protect your eyes in particular.

Working environment



WARNING!

Only place the camera on firm level ground and ensure a secure position of camera and user, especially when working in high altitude, e.g. when working on the roof.



WARNING!

Make sure that the parts that you are going to inspect are no live parts.



CAUTION!

Protect the camera head against oil and acid. Never use the camera head and rod to push obstructions.

Operating temperature



CAUTION!

Do not use the camera in temperatures above 40°C. High temperatures can damage the camera.

Important information

Resistance to water



CAUTION!

Only the camera head and the rod are waterproof. Keep the camera system dry and away from water!

Resistance to impacts



CAUTION!

The camera system is not impact resistant. Do not throw or allow the case to fall!

Accessories



CAUTION!

Use only original Wöhler accessories and spare parts!

Strong magnetic or electric fields



NOTE!

Do not use the camera near television towers, mobile radio equipment or other sources of magnetic or electric fields, as these may impair the quality of the displayed image.

Extraneous influences



NOTE!

Extraneous influences such as static discharges can cause the device to malfunction. If a malfunction occurs, switch the monitor off and on again.

3 Camera Models

Different camera models Wöhler VIS can be acquired. The difference between the models described in this version are as follows:

| | VIS 350 | VIS 300 | VIS 250 | VIS 200 |
|--------------------------|--|--------------------|---|----------------|
| Camera head | Ø 1 ½ " pan & tilt | Ø 1 ½ " pan & tilt | Ø 1 " | Ø 1 ½ " |
| integrated transmitter | ✓ ¹ | ✓ ² | ✓ ¹ | ✓ ² |
| Position indicator | ✓ | | ✓ | |
| Electronic meter counter | ✓ | ✓ | ✓ | ✓ |
| Record video | ✓ | | ✓ | |
| Menu | ✓ | | ✓ | |
| Home function | ✓ | | | |
| Control panel | 7 keys with shift | 5 keys | 7 keys | 1 key |
| Application | <ul style="list-style-type: none"> • Flue gas lines Ø 2,4" and larger with 87° bends (and smaller) • Waste water lines of Ø 2,8" and larger • Chimneys • Ventilation lines of Ø 2,4" and larger • Analyse damage in Waste water pipes of Ø 2,8 " and larger | | <ul style="list-style-type: none"> • Flue gas lines Ø 2 ½ " and larger • Ventilation lines of Ø 2 ½ " and larger • Analyse damage in Waste water pipes of Ø 2 ½ " up to Ø 4.9" | |

¹ The transmitter can be switched on and off in the menu, see chapter 8.2

² When the camera is switched on, the transmitter will be permanently active.

4 Technical data

4.1 Monitor



Fig. 1: Monitor

| Description | Details |
|---------------------------------------|--|
| TFT display | 7"/ 16:9 and 4:3 format (Default 16:9) |
| Weight | 14 oz |
| Dimensions housing | 6,9 x 4,5 x 1,3 " |
| Video output | FBAS signal |
| Power supply | via camera system |
| Voltage | 12 V |
| Operating temperature | 32 ... 104 °F - |
| Storage temperature | - 4 ... 122 °F |
| Connection cable to the camera system | 79" |

4.2 Miniature Camera Head (Wöhler VIS 200/250)



Fig. 2: Miniature Camera Head


| Description | Details |
|--|--|
| Type: | 1/3" COLOR CMOS |
| Light sensitivity | 12V, Lux sec |
| Lens: | f = 0.09", F = 0.10" |
| Viewing angle: | 120° |
| Light source: | 12 white LEDs |
| Dimensions | Ø 1" x 1 1/2 " |
| Frequency of the transmitter integrated in the camera head | 8.9 kHz |
| Water protection | Waterproof according to IP 68 (30 min, up to 30 m) |

4.3 Miniature Camera Head (Wöhler VIS 300/350)




Fig. 3: Camera Head pan & tilt

| Description | Details |
|--|---|
| Type: | 1/3" COLOR CMOS |
| Light sensitivity | 12 V, Lux sec |
| Lens: | f = 0.09", F = 0.10" |
| Viewing angle: | 120° |
| Light source: | 12 white LEDs |
| Dimensions | Ø 1 ½ " x 2.4 mm |
| Frequency of the transmitter integrated in the camera head | 8.9 kHz |
| Water protection | Waterproof according to IP 67 (30 min, up to 1 m) |



Ansicht Front

Fig. 4: Pan the camera head 360°



Ansicht Seite

Fig. 5: Tilt the camera head 180°

4.4 Push rod

| Description | Details |
|-------------|--------------------------------------|
| Length: | 787" optional 1181" |
| Diameter | 0.3 mm (VIS 3xx) 0.2 mm (VIS 2xx) |

4.5 Electronic distance counter

| Description | Details |
|-------------------|-----------------|
| Resolution: | 1.5" |
| Maximum Deviation | 10 % of reading |

4.6 Memory (Wöhler VIS 250 / 350)

| Description | Details |
|--------------------------------|--|
| Memory card | If you are using a memory card other than the one included in the scope of supply, you must format it first before you can use it on a PC. |
| Max. | 32 GB |
| Technology: | SD or SDHC |
| Velocity class: | 2 - 10 |
| Formatting: | For cards < 4 GB: FAT or FAT32, others: FAT 32 |
| Capacity | ca. 1h / GB |
| Resolution of the video | 640 x 480 (VGA)/ max. 30 fps |
| Video format | ASF (MPEG4) |

6 Design and function

6.1 Video inspection system




Fig. 6: Case (Wöhler VIS 350)

Legend

- 1** Monitor
- 2** Monitor controls
 - Brightness / contrast
 - Color
- 3** Camera control
 - with record and play - function (Wöhler VIS 250 / VIS 350)
 - home function aligns the camera head to a straight position and menu for the monitor settings (Wöhler VIS 350)
- 4** camera head, waterproof:
 - Wöhler VIS 300 / VIS 350: pan and tilt color camera head 40 mm Ø
 - Wöhler VIS 200 / 250 Miniature color camera head Ø 26 mm
- 5** Main power switch with the following functions:
 - ON /OFF (system)
 - Reset distance measurement
 - Escape
 - Delete (when SHIFT mode is activate)
- 6** Cardslot for memory card (Wöhler VIS 250 / 350)
- 7** Mini-USB-port (Wöhler VIS 250 / 350)
- 8** Power supply socket (18V/1,6A)
- 9** Video out
- 10** Accessory compartment 1
- 11** Rechargeable battery, extra (only Wöhler VIS 350)
- 12** Power supply
- 13** Rechargeable battery, in use
- 14** Accessory compartment 2

6.2 Control panel

VIS 200

Control Panel Wöhler VIS 200 with ON/OFF-key



Fig. 7: Control Panel
Wöhler VIS 200

VIS 300

Control Panel Wöhler VIS 300 with ON/OFF-key
and control keys for the pan and tilt camera head



Fig. 8: Control Panel
Wöhler VIS 300

Wöhler VIS 250 / 350

Control Panel
Wöhler VIS 250 / 350



















Fig. 9: Control Panel
Wöhler VIS 250 / 350

The keys on the control panel have the following functions:

| | | |
|---|---|-------------------------------|
|  | <p>Wöhler VIS 200/250/300/350</p> <p>ON/OFF key turns the whole camera system on/off (monitor and camera head).</p> <p> NOTE! <i>The ON/OFF key is framed by a green light when the system is switched on and the battery is charged.</i> <i>The lower half of the light framing the ON/OFF key flashes red during the recharging process.</i></p> | |
| <p>Functions The ON/OFF key</p> | <p>Press</p> | <p>Function</p> |
| | <p>When the system is switched off: Briefly</p> | <p>Switch system on</p> |
| | <p>When the system is switched on: Hold 2 seconds</p> | <p>Switch system off</p> |
| | <p>When the system is switched on: Briefly</p> | <p>Reset distance counter</p> |
| | <p>When the system is switched on: (Wöhler VIS 250 / 350)</p> | <p>Escape Exit menu</p> |
|  | <p>Camera head operating keys (Wöhler VIS 300/350)</p> <p>Tilt the camera head 180°</p> | |
|  | <p>Camera head operating keys (Wöhler VIS 300/350)</p> <p>Rotate the camera head 360°</p> | |

| Wöhler VIS 250 / 350 | |
|---|---|
|  | <p>VIDEO key</p> <p>Start/stop recording video</p> |
|  | <p>SHIFT key</p> <p>Activates the key functions depicted by green icons on the top right corners of the keys.</p> <p> NOTE! <i>When SHIFT MODE is activate, the SHIFT key lights up and an S is displayed in the bottom middle of the screen.</i></p> |
|  | <p>ILLUMINATION key</p> <p>Dimming function to set the brightness of the camera head lighting.</p> <p> NOTE! <i>There are three levels of brightness available to increase or dim the intensity of the camera head lighting. The brightness is increased each time the user presses the ILLUMINATION key three times in sequence. The fourth time the user presses the key, the lighting returns to the lowest level of brightness.</i></p> |
|  | <p>MENU key:</p> <p>Make settings</p> |
|  | <p>PLAY key</p> <p>Playback recorded videos</p> |
|  | <p>HOME key (only Wöhler VIS 350, Wöhler VIS 250: without function):</p> <p>Aligns the camera head to a straight position – displays view parallel to the ground above</p> |


| | |
|---|---|
|  | <p>IMAGE key</p> <p>Capture image / snapshot</p> <p> NOTE! <i>Images are saved in .jpg format. It is possible to display the images on a PC from the SD card.</i></p> |
|  | <p>DELETE key</p> <p>Delete an image or video selected in PLAY mode.</p> |

6.3 Monitor

6.3.1 Adjusting the Color






Fig. 10: Monitor

With the keys  the brightness can be adjusted.

  darker  : brighter

With the keys  the color intensity can be adjusted.

  decreasing color intensity up to black and white.

 : increasing color intensity

 **NOTE!**

We recommend not to change the monitor settings. It is also possible to do individual settings which have influence of the video quality in the menu of the Wöhler VIS 350/VIS 350 , see section 8.2.

6.3.2 Transition from 16:9 Screen to 4:3 Screen

The screen format of the monitor can be changed from 16:9 to 4:3 or vice versa.



+



- Switch off the camera system.
- Press the left monitor key and the ON/OFF-key of the camera at the same time.

The screen format of the monitor can be changed from 16:9 to 4:3 or vice versa.



NOTE!

When inspecting tubes the 4:3 screen is recommended, because the widescreen 16:9 may distort the image.

7 Getting started

7.1 Rechargeable battery status and recharging



WARNING!

Risk of injury when handling the rechargeable batteries improperly!

Never open the rechargeable battery housing.

Do not throw rechargeable batteries into a fire or expose to high temperatures. There is a risk of explosion!

If handled improperly, a liquid may emerge from rechargeable batteries that can cause skin irritation. Avoid contact with the liquid. Rinse skin with large amounts of water if it comes into contact with the liquid. If the liquid comes into contact with eyes, rinse with water immediately for 10 minutes and consult a doctor immediately!



WARNING!

Danger of death by electrocution!

Never touch an electrical outlet with wet hands!

Do not expose the power pack to moisture!

Never pull the cable to remove the power pack from the electrical outlet - it could rip out the cable!

Operate the power pack only when the mains power supply is the same as the voltage stated on the rating plate!



CAUTION!

Switch off the camera system before charging the battery.



CAUTION!

If the camera is not used regularly, we recommend to discharge the battery by powering on the camera. After that, charge the battery completely. Repeat this procedure after approx. 6 weeks.

Rechargeable battery status indicator



Fig. 11: Control panel of Wöhler VIS 250 / 350 - ON/OFF key framed by flashing light

When the camera is switched on, the battery status indicator displays the charge status of the rechargeable battery in the top right corner of the display. The indicator flashes when the charge level of the batteries is low. If the charge level continues to fall, the light framing the ON/OFF key flashes red and the camera switches off automatically.

It is only possible to switch on the camera again after the battery has been replaced with a charged battery or a power cable is connected to recharge the battery in use.

Charging rechargeable batteries




Fig. 12: Schematic overview of battery recharging

To recharge the battery, proceed as follows:

- Connect the power pack to the charger connection of the device and the main power supply.

The lower half of the light framing the ON/OFF key flashes red during the recharging process; when the battery is fully recharged it lights up red continuously as long as the power pack remains connected.



NOTE!

The operating time of the rechargeable battery is approx. 120 minutes.

7.2 Working position



Fig. 13: possible working position



WARNING!

Only place the camera on firm level ground and ensure a secure position of camera and user, especially when working in high altitude, e.g. when working on the roof. Because of its weight the case can cause considerable harm to persons and objects when falling down.

- Place the case so that the arrows on the blue clips show upwards.
- Pull the clips and open the case
- Place the monitor in the desired working position.



NOTE!

It is possible to pull the monitor out off the support and place it outside the case if your working position requires this. The connection cable to the case is 2 m long.

8 Working with the camera

8.1 Switching on the system and monitor

Wöhler VIS 250 / 350

- Insert a memory card (max. 32 GB).



NOTE!

If you are using a memory card other than the one included in the scope of supply, you must format it first (FAT32) before you can use it on a PC.

To format the card, proceed as follows:

- Insert the card into the card slot of your PC.
- In the Explorer, right-click the removable media memory card, then select "Format".
- Select FAT32 (default) and 32 kilobytes.





Fig. 14: ON/OFF key

- To switch on the device, briefly press the ON/OFF key at the bottom of the control panel.
- When the device is switched on, the light framing the ON/OFF key lights up green. The video image is displayed on the monitor after about 5 seconds.

8.2 Memory (Wöhler VIS 250 / 350)

- After switching on the device press the SHIFT key.

The green light framing the SHIFT key lights up and an **S** is displayed in the middle at the bottom of the monitor. This indicates that SHIFT mode is active and the second functions marked in green on the keys are enabled.

- Press the Menu key 

The menu opposite is displayed on the screen.

Below the menu, the serial number of the camera (S/N) the serial number of the camera head (CAM) and the Firmware version appear on screen.




Fig. 15: Menu



NOTE!

If you are using a camera head other than the one included in the scope of supply, the video menu may not be activate.

- Using the up/down arrows, navigate to the corresponding parameter. Select the desired setting using the left/right arrow keys.
- Press the ON/OFF key to confirm your selection and exit the menu.

The user can select the following parameter settings:

The user is able to switch between 3 pre-defined video settings. The settings for Video 1 and Video 2 cannot be altered.

| Video | Recommended |
|---------|--|
| Video 1 | Recommended for pipes, good long field of vision |
| Video 2 | Recommended for chimneys; dark areas are made to appear brighter |
| Video 3 | User-definable settings |

Video




Fig. 16: User-definable Video 3 settings

To define "Video 3" settings, proceed as follows:

- In the menu view, use the up arrow key to navigate to the MENU view and then use the right arrow key to select the Video tab.
- Adjust the following settings as required:
 - ☉ Brightness
 - Contrast
 - ┌┐ Contour sharpness
 - ▬▬ Color saturation
 - Gamma: Gamma curve setting (0-3)

 **NOTE!**

Adjustments to the gamma curve affects brightness curve settings.

- To save your settings, use the down arrow key to select the disc symbol below the parameter. Press the right or left arrow key.
- This saves the settings for Video 3. The disc symbol flashes during the write operation.
- Return to the menu view using the arrow keys.




Fig. 17: Menu
Loc OFF/ON

This command allows the user to switch the transmitter integrated in the camera head on and off. The Wöhler L 200 Locator is able to locate the camera head with the aid of signals transmitted by the transmitter.

ON: Transmitter is switched on

OFF: Transmitter is switched off

 **NOTE!**

After the Wöhler VIS 250/350 has been switched on, the transmitter will always be deactivated, because the camera consumes less power when the transmitter is switched off.

Therefore the transmitter must always be switched on before locating the camera with the Wöhler L 200 Locator.

OSD ON/OFF




Fig. 18: Setup menu

This command allows the user to switch the on-screen display On or Off. Select "ON" if you wish to display the battery status indicator and the date on-screen.

Use the arrow keys to navigate to the Setup menu. The following user-definable settings are available here:

Date

Set the date. The date the recording is made is displayed

Time

Set the time. The time the recording is made is displayed

Meter/feet

Set the distance displayed on the screen to meters or feet.

Date format

Set the date format to either Day.Month.Year or Month/Day/Year

Time 12h/24h

Set the time format to either 12 hour format or 24 hour format.

Exit menu

To exit the menu, press the ON/OFF key.

8.3 Inspection

- Pull the rod smoothly out of the case and push the camera head to the area to be inspected.

! CAUTION!

*Do not exceed rod end limit!
Do not bend or drag across sharp edges!*

! CAUTION!

Dry and clean the rod with a cloth before pulling it back, so that no dirt and soot can enter!

8.4 Information displayed on the monitor

8.4.1 Displaying the position of the camera head (Wöhler VIS 250/350)

Pointer symbol




Fig. 19: Display with pointer symbol and number of degrees

A **pointer symbol** displayed in the top left corner of the screen always indicates the direction of gravity, meaning, towards the bottom. This ensures the user is able to recognize where top and bottom are in the pipe.

A circle is displayed around the symbol if the camera head faces vertically upwards.

A cross is displayed in the middle of the symbol if the camera head faces vertically downwards.

Number of degrees

The number of degrees displayed underneath indicates the downward gradient of the pipe.

Example graphic: -13° corresponds to a downward grade of 13° .

👉 NOTE!

Example:

Camera head facing vertically upwards: $+90^\circ$

Camera head facing vertically downwards: -90°

Camera head is aligned parallel to the ground above: 0°

Distance counter

The distance indicated at the lower left shows how many feet of the rod are already pulled out of the case.

You can select the unit meter or feet in the menu,

see section 8.2.



NOTE!

Briefly press the ON/OFF key to reset the distance counter to zero. This may be reasonable at the beginning of the pipe.

Time and date

The time and date are displayed in the bottom right corner. The recorded time is displayed when the video is played back.

8.5 Home Function (only Wöhler VIS 350)




Fig. 20: Home function

The home function ensures the camera head is automatically aligned to a straight position, ensuring the camera "looks straight ahead".

Moreover, when the user presses the HOME key, the camera head aligns itself so that the display is parallel with the ground above (this function is deactivated if the camera head faces 90° upwards or downwards. Under these circumstances, the optics can only be guided forwards).



NOTE!

To determine the grade described under paragraph 8.4.1, the camera head must be aligned straight.



- To activate the home function, press the SHIFT key and then the HOME key.

8.6 Video Record (Wöhler VIS 250 / 350)

Record video



- To begin recording a video, press the Record video key.

The RECORD VIDEO key is framed by a red flashing light when recording is in process, and a red dot is displayed on the screen.

- To stop recording, press the Record video key again. The video is stored in ASF format on the memory card.



CAUTION!

Ensure the power supply is not interrupted when recording a video.


8.7 Video playback (Wöhler VIS 250 / 350)

Video playback



- To playback a recorded video, press the SHIFT key and then the PLAY key. The first image of the last video recorded is displayed on the screen.

Select the desired video using the right/left arrow keys.

- To begin playing back the video, press the Play key .

9 Images (Wöhler VIS 250 / 350)



- To capture an image, press the SHIFT key and then the PHOTO key.

The image is saved as a .jpg file on the memory card.

10 Delete a Video (Wöhler VIS 250 / 350)




- To select the file to be deleted, press the SHIFT key and then the PLAY key.

The first image of the last video recorded or the last image recorded is displayed on the monitor.



Note!

An Icon in the upper left side of the display will show if it is an image or a video.

- Select the video or image to be deleted using the right/left arrow keys.
- To delete the video or image, press the SHIFT key and then the DELETE key .



The prompt "DELETING FILE" is displayed on the screen for approximately 2 seconds. Once the file has been deleted, the image currently being transmitted from the camera head is displayed on the screen.

11 Transferring images and videos to a PC (Wöhler VIS 250/350)

Two options are available to transfer image files (.jpg) and video files (ASF):

- Read in the files on a PC from the SD memory card.
- Transfer the files to the PC using the USB cable.



NOTE!

Image files can only be viewed and deleted on a PC.

12 Video Playback at PC (Wöhler VIS 250/350)

12.1 Installing the VLC viewer

- Put the CD included in the camera system into the CD drive of the PC. (the VLC viewer is also available for download free of charge via the VLC web page).
- Click Index.html. The menu opens.
- Click the "Install" button.
- Videos recorded in ASF format can be viewed as soon as the viewer has been successfully installed.
- To generate a snapshot from a video, click the menu item Snapshot in the Video menu when the video is being played back.

12.2 Generating snapshots





Fig. 21: Generating snapshots

12.3 Output directory for snapshots



- After launching the VLC Media Player, click "Tools" and then "Preferences".
- Select the "Video" symbol on the left.
- In the "Take video snapshots" area, click the "Browse ..." button and choose the folder in which you wish to store the snapshots.
- You can also select the output format of the generated files (.png or .jpg) as well as your own prefix to be appended to the beginning of the file name.
- To save your "preferences", click save.

As the VLC Media Player is a free ("open source") software program, we are unable to offer any technical support. For further information about the program as well as the current version, visit the developers' website at www.videolan.org



NOTE!

You can also use "Daum PotPlayer" to view videos as an alternative to the VLC Media Player. This program is also available free of charge over the Internet.

13 Guide accessories

This section contains some recommendations based on our experience about the selection of guide accessories for the inspection in tubes and ducts.

As all pipes and chimney systems are different, the user has to decide about the guide accessory in every single case. For the selection of the correct tool it is important to consider that the guide accessory has to facilitate the introduction and the extraction of the camera head, as well as an adequate guidance. The danger of jamming or getting stuck in the tube has to be avoided.




NOTE!

The information given in this section only refers to the accessories.

| | |
|-----------------|---|
| Ø 1 ½ " – 2 " | Use the service camera without accessories. |
| Ø 2 " – 2,8 " | You can use the service camera without accessories. The lens can be protected by the guidance sleeve. If there is water and mud in the horizontal part, we recommend to use the roller guide. |
| Ø 2,8 " – 3,9 " | The inspection is possible with the roller guide and without it. Use the guidance weight for the vertical inspection or for the inspection of downpipes. |
| Ø 3,9 " – 6,1 " | A centering brush can be used with the roller guide or without it and with the lens protection. |

14 Faults

| Fault description | Possible cause | To rectify |
|---|--|---|
| Cannot start monitor. When the ON/OFF key is pressed, the light framing the key briefly lights up red. | Rechargeable battery has no charge left. | Recharge battery or connect monitor to electrical power supply. |
| Battery status indicator on the monitor indicates a low battery charge. | Rechargeable battery has no charge left. | Replace (only Wöhler VIS 350) or recharge batteries. |
| The monitor is off, but the LEDs of the camera head are shining. | The monitor is not connected correctly. | Plug in the monitor plug. |
| Monitor displays black and white | Minimal color intensity is set. | Adjust the color intensity of the monitor with key 4  |
| Wöhler VIS 300/350: bad image | Plastic dome scratched. | Replace the plastic dome; glass dome optional. |
| Camera head or monitor freezes | Battery / rechargeable battery flat. | Replace (only Wöhler VIS 350) or recharge batteries. |
| | Device is faulty. | Send camera system in for repair. |
| Blue screen, NO SIGNAL displayed on the monitor | Rod is broken. | Send camera system in for repair. |
| | Cable/plug connection at monitor not properly connected. | Reconnect the plug connection. Broken cables in plug connection. Send camera system in for repair. |

15 Maintenance

15.1 Regular maintenance

Proper operation of the camera system requires regular maintenance. The following maintenance works can be done by the user himself.

15.2 Changing the dome of the Camera Head Wöhler VIS 300/350




Fig. 22: Fitting the camera dome



NOTE!

The Wöhler Camera Head VIS 300/350 is supplied ex-works protected by a plastic dome, which can be replaced if necessary. If it becomes scratched, it is optional to fit this camera head with a glass dome for use in dry working environments.

Apply silicone grease before fitting the new dome. When fitting the replacement dome, make sure you cover all of the thread to ensure it is properly tightened. Otherwise, it cannot be guaranteed that the camera head is properly sealed, and malfunctions can occur as a result of water and dirt penetration.

15.3 Camera head

- Only use soft, damp cloth to clean the lens. Never use any cleanser.

15.4 Push rod

- Regularly pull the rod out of the case and clean it with a soft, damp cloth.

15.5 Monitor

- Clean the monitor using a soft cloth.

16 Accessories

| | |
|--|----------------------|
| Wöhler VIS Guidance Set 70 for miniature camera head Ø 26 mm | Order No. 3883 J |
| Wöhler VIS Centering Brush Extension | Order No. 3853 J |
| Camera Roller Guide | Order No. 3681 J |
| Wöhler Protection Sleeve for camera head Ø 40 mm | Order No. 2641 J |
| Wöhler Guidance Weight 740 g, stainless steel | Order No. 3857 J |
| Wöhler Guidance Ball | Order No. 3634 J |
| Wöhle Glass Dome for camera head Ø 40 mm | Order No. 3674 J |
| Wöhler Replacement Plastic Domes (10 pcs.) for camera head Ø 40 mm | Order No. 3675 J |
| Anti Slide mat | Order No. 56037 L |
| Guidance Sleeve with protection cage for Wöhler camera head Ø 26 mm | Order No. 3847 J |
| Wöhler additional glare protection for monitor | Order No. 6814 J |
| Wöhler L 200 Locator (Receiver) | Order No. 7430 J |
| Car charger Wöhler VIS 2xx/3xx | Order No. 3169 J |

17 Warranty Wohler VIS Service Camera

WohlerUSA Inc. Warranty – Please read fully!

Wohler VIS Service Camera: WohlerUSA Inc. warrants to the original end user (Customer) that this product will be free from defects in workmanship and materials, under normal use, for one year from the date of original purchase from WohlerUSA Inc. or its authorized reseller. WohlerUSA Inc.'s sole obligation under this express warranty shall be, at WohlerUSA Inc.'s option and expense, to replace the product or part with a comparable product or part or to repair the product or part. Replacement products or parts may be new or reconditioned. WohlerUSA Inc. warrants any repaired or replaced parts for a period of ninety (90) days from shipment or through the end of the original warranty obligation, whichever is longer. All parts or products that are replaced become the property of WohlerUSA Inc.

The serial number of the monitor and the camera head are printed and are needed for any warranty claim. Please retain your invoice as proof of your warranty.

Expressly excluded from this VIS Hardware warranty are the Glass dome that covers the lens mechanism and the camera cable.

Obtaining Warranty Service:

The Customer must contact WohlerUSA Inc. during the normal business hours of 9:00 and 4:00 EST Monday through Friday, excluding statutory and other noted holiday periods, within the applicable warranty period. Dated proof of purchase, the invoice, and the applicable serial numbers of the warranted products is required. WohlerUSA Inc. is not responsible for Customer products returned without prior return authorization. WohlerUSA Inc. may, at its sole option, provide advance shipment of replacement parts prior to receiving the original product or part (advance exchange). If advance exchange is not available, then the repaired product will be shipped as soon as possible. Repaired or replaced product or parts will be shipped at WohlerUSA Inc.'s expense. Products or parts returned by the Customer to WohlerUSA Inc are done at their risk and must be sent prepaid and packaged appropriately for safe shipment. It is recommended that they be insured or sent by a method that provides for the tracking of the package. When advance exchange is provided and the Customer fails to return the original product or part to WohlerUSA Inc. within fifteen (15) days from the date the warranty service authorization was issued, WohlerUSA Inc. will charge the Customer the then current published catalog price of such product or part. To obtain warranty service please call WohlerUSA Inc. at 978-750-9876 during the business hours mentioned above. You may also go to the Wohler USA website www.wohlerusa.com and submit an RMA request.

Warranties Exclusive:

If this product does not operate as warranted above, the Customer's sole remedy for breach of that warranty shall be replacement or repair of the product or part. To the full extent allowed by law, the foregoing warranties and remedies are exclusive and are in lieu of all other warranties, terms, or conditions, express or implied, either in fact or by operation of law, statutory or otherwise, including warranties, terms, or conditions of merchantability, fitness for a particular purpose, satisfactory quality, correspondence with description, and non-infringement, all of which are expressly disclaimed. WohlerUSA Inc. neither assumes nor authorizes any other person to assume for it any other liability in connection with the sale, maintenance or use of its products. WohlerUSA Inc shall not be liable under this warranty if its testing and examination of returned product shows that the alleged defect or malfunction does not exist or was caused by the Customer's or any third person's misuse, neglect, improper installation or testing, unauthorized attempts to open, repair or modify the product or any other cause beyond the range of intended use, or by accident, fire, or any other hazards or Acts of God. This warranty does not cover physical damage to the surface of the product including cracks or scratches on the LCD screen or outside casing or the leather protective case or to any cables or video rods. This warranty does not apply when the malfunction results from the use of this product outside of specified operating conditions or with accessories, other products, or peripheral equipment and WohlerUSA Inc. determines that there was no fault or failure of the product itself.

Warranty Wohler VIS Service Camera

Limitation of Liability: To the full extent allowed by law, WohlerUSA Inc. also excludes for itself and its suppliers any liability, whether based on contract or Tort (Including Negligence), for incidental, consequential, indirect, special, or punitive damages of any kind for loss of business, profits, information or data or images, or other financial loss arising out of or in connection with the sale, installation, maintenance, use, performance, failure or interruption of this product, even if WohlerUSA Inc. has been advised of the possibility of such damages, and limits its responsibility to the replacement or repair of the product or part. This Limited Warranty is governed by the Laws of the State of Delaware.

Wohler USA Inc.
5R Hutchinson Drive
Danvers, MA 01923
978-750-9876

Customer Name : _____.

Camera Case Serial # : _____.

Camera Head Serial # : _____.

Purchase Date. _____.

Invoice Number: _____.

Congratulations on your purchase of a Wohler VIS Service Camera. Please complete the information on this form and retain for Warranty purposes. A copy of this document and/or a copy of the original invoice must accompany any Warranty claim.

The serial number for the camera is located on the lower metal side of the camera. The serial number for the monitor is located on the right side of the monitor by the cable connector.

Points of sale and service

USA

Wohler USA Inc.
5 Hutchinson Drive
Danvers, MA 01923
Tel.: +1 978 750 9876
Fax.: +1 978 750 9799
www.wohlerusa.com

Germany

Wöhler Technik GmbH
Schützenstr. 41
33181 Bad Wünnenberg
Tel.: +49 2953 73-100
Fax: +49 2953 73-96100
info@woehler.de
www.woehler.de

Wöhler West

Castroper Str. 105
44791 Bochum
Tel.: +49 234 516993-0
Fax: +49 234 516993-99
west@woehler.de

Wöhler Süd

Gneisenastr.12
80992 München
Tel.: +49 89 1589223-0
Fax: +49 89 1589223-99
sued@woehler.de

Europe

Italy

Wöhler Italia srl
Corso Libertà 9
39100 Bolzano
Tel.: +390471402422
Fax: +39 0471
www.woehler.it

Czech Republic

Wöhler Bohemia s.r.o.
Za Naspem 1993
393 01 Pelhrimov
info@woehler.cz

France

Wöhler France SARL
16 Chemin de Fondeyre
31200 Toulouse
info@woehler.fr