



# ENVIRONMENTAL CLAIM VALIDATION SUMMARY

## Knauf Insulation

### Knauf Wall & Ceiling Liner M and Equipment Liner M with ECOSE® Technology

**Report Number:**

9505-4170

**Validation Period:**

04 Nov 2015 - 04 Nov 2023

---

**Claim:**

Validated by testing developed in compliance with ASTM D 6329-98 (2008), Standard Guide for Developing Methodology for Evaluating the Ability of indoor Materials to Support Microbial Growth Using Static Environmental Chambers

**Method:**

Mold Resistant per UL 2824

**Facility:**

Shelbyville, IN