

QUARTO

ASSEMBLY AND INSTALLATION

- This luminaire must be disconnected before insulation resistance testing of the lighting circuit.
- Suitable for use with 220-240V AC power supplies.
- Ensure outdoor connections are made to meet IP65 rating.



