

Wiring Instructions

1. Power Off

Before commencing work always isolate the power at the consumer unit

*Note – If your installation uses a four-lug metal mounting box, remove the top and bottom lugs or bend fully back.

2a. Replacing an existing accessory

- 1. Unscrew the accessory from the wall/mounting box. 2. Note the cable connections:
- The illustration shows 1 wire of each colour connected to each terminal.
 There should be an additional connection between the mounting box earth terminal and the accessory earth terminal.
- 3. Unscrew each terminal to release the wire.

2b. New installation

- 1. Install mounting box (metal or moulded) for either flush or surface mounting, ensuring appropriate size of product.
- Select the most suitable entry point of the mounting box (knock-out) and
 route the cables through. If a metal box is used, a cable grommet should
 be fitted to the entry point.
- Cables should be prepared so a sufficient conductor length reaches the terminals. Strip the ends of the individual conductors leaving an adequate length bare to enter terminals.

3. Connection (See diagram)

- Line up the new accessory to mounting box and take note of where each terminal is located.
- 2. Connect each wire to the matching terminal.
- An earth connection should always be made between the mounting box earth terminal and the accessory earth terminal, where fitted.
- All bare earth wires must be sheathed with green/yellow sleeving
- When connecting the new accessory ensure that only the bare end of the wire enters the terminal and no bare wires are visible.
- 3. Tighten terminal screws securely. (Do not over tighten)

4. Complete Installation & Test

- Carefully position the accessory into the mounting box, ensuring that no wires are trapped between the plate and the wall and secure with screws (do not over tighten) then insert screw covers (optional).
- 2. Once the installation has been completed correctly, replace the fuse/reset MCB (trip), switch the power back on at the consumer unit and test.

Switch types

One Way Switching

One way switching is used in installations that require just one switch to control a light (or circuit) i.e. on or off.

A two-way switch can be used for one way connection, use COM and L1 terminals. For multiple gang switches [2, 3 & 4 repeat wiring method for each switch]

Two Way Switching

Two way switching is used where a light is controlled by two switches. For multiple gang switches [2, 3 & 4 repeat wiring method for each switch].

Features

Overload Protection – This dimmer is fitted with an overload current protection device, in the event of an overload condition the dimmer will stop working until the overload is corrected. Please check the total load ratings before installing.

Soft Start – To prolong the life of the connected lighting this dimmer features a soft start function. Upon switching on, lighting will increase from 0 to 100% in 1.2 seconds.

Safety Warning

For your safety, this product must be installed in accordance with local Building Regulations. If in any doubt, or where required by the law, consult a competent person who is registered with an electrical self-certification scheme. Further information is available online or from your Local Authority

Please read carefully and use in accordance with these safety wiring instructions. Before commencing any electrical work ensure the supply is switched off at the mains. Either by switching off the consumer unit or by removing the appropriate fuse or turning off MCB (trip). Wiring should be in accordance with the latest edition of the IET regulations (BS 7671). To prevent fire hazard always use cable of the correct rating & type for the

Warning do not exceed the load rating of this device as stated on the rear

Wire Identification - Twin & Farth Cable

Note - As from 1st April 2004 new colour codes for hard wire installations were introduced.


EARTH = Green/Yellow Sleeving

of the product


NEUTRAL = Black (pre Apr 04) / Blue (after Apr 04) LIVE = Red (pre Apr 04) / Brown (after Apr 04)







Two Way Switching



Installation Notes

Only one dimmer is allowed in a two-way circuit.

If the installation uses a four lug metal mounting box, remove the top and bottom lugs or bend fully back.

For white moulded products, if the dimmer knob blocks the screw fixing holes, remove knobs, fix to wall and then reattach knobs.

Load Information

Lamp Type	Rating
Incandescent	5-200VA
Eco-halogen	20-200VA
Dimmable LED	5-100W
	1 to 10 Dimmable LEDs
Dimmable CFL	5-100W
	1 to 8 Dimmable CFLs
High Voltage Halogen	20-200VA

Incandescent and ECO Halogen Lamps

Plate size	No. of Dimmers	Max. each Dimmer	Max. total per plate
Square plates	1	200W	200W
86mm x 86mm	2	150W	300W
Rectangular plates	3	150W	450W
146mm x 86mm	4	150W	600W

LED Lamps

Plate size	No. of Dimmers	Load	Max. total	Max.	Max. total
		per Dimmer	per Dimmer	per plate	per plate
Square plates	1	5-100W	€10	100W	≤10
86mm x 86mm	2	5-100W	€10	200W	≤20
Rectangular plates	3	5-100W	€10	300W	≼30
146mm x 86mm	4	5-100W	≤10	400W	≤40

CFL Lamps

or a camps								
Plate size		Load	Load Max. total		Max. total			
		per Dimmer	per Dimmer	per plate	per plate			
Square plates	1	5-100W	≼8	100W	≼8			
86mm x 86mm	2	5-100W	≼8	200W	≤16			
Rectangular plates	3	5-100W	≼8	300W	≼24			
146mm x 86mm	4	5-100W	≤8	400W	≼32			

Technical

Voltage : 220-240V ac Frequency : 50/60Hz

Dimmer Type: Trailing Edge Rating : See charts

Rating : See charts

Terminal capacity: 2 x 1mm² 2 x 1.5mm²

Min box depth (profiled plates) : 1 & 2 gang switches 25mm 3, & 4 gang switches 35mm

Min box depth (flat plates) : 35mm

ASTA Approved

The ASTA quality mark is evidence that the product has been independently tested to comply with the relevant clauses of the applicable standards.



Additional Advice for Decorative Products

Fixing method varies depending on which product range is supplied. Always ensure wall surface is reasonably flat and smooth, with no bumps or projections. Metal frontplates WITH screw fixing holes, fix the unit to the back box using two fixing screws supplied. All Decorative products MUST have an earth connection between the frontplate and back box. Frontplates WITHOUT screw fixing holes. These products comprise main unit with integral gasket, and frontplate as separate item. Fix unit to back box using two fixing screws supplied. Clip frontplate onto main assembly, ensuring screwdriver notch is located bottom right hand

To remove plate, place medium size flat bladed screwdriver in notch and lever off against gasket.

Care

To maintain the high quality appearance of decorative finish switches and sockets, BG Electrical recommend the use of a soft cloth periodically to clean the front face. When installing a decorative product please ensure that the wall is decorated, finished and free of moisture prior to installa

BG Electrical recommends avoiding using, but not restricted to, these substances from becoming in contact with the decorative metal frontplates when cleaning or decorating:

- · Adhesive tape, including low tack masking tape
- Solvents
- White spirit
- Multi surface cleaners
- · Industrial multipurpose cleaning wipes
- Wet wines
- Wet Wipes Heina itoma li

Using items like those listed above may cause a degrading effect to the frontplates lacquer/plated finish, although the function will remain unaffected.

Batch Code explanation

yyWxx Manufacturing date code, year of manufacture (yy) and week of manufacture (Wxx)

Address/Helpline

 Luceco PLC
 [EU] Luceco SE

 Stafford Park 1
 C/ Bobinadora 1-5

 Telford TF3 3BD
 08302 Mataró, Barcelona

 ENGLAND
 SPAIN

If you have further technical assistance you can get in touch with our

Technical Helpline on: +44 (0)3300 249 279

technical.support@bgelectrical.co.uk

Environmental Protection



This symbol is known as the "Crossed-out Wheelie Bin Symbol". When this symbol is marked on a product or battery, it means that it should not be disposed of with your general household waste. Some chemicals contained within electrical/ electronic products or batteries can be harmful to health and the environment. Only dispose of electrical/electronic/ battery items in separate collection schemes, which cater for the recovery and recycling of materials contained within. Your co-operation is vital to ensure the success of these schemes and for the protection of the environment.