




MODBUS communication protocol

for RS485 MODBUS modules



November edition 2015

Limitation of Liability

The Manufacturer reserves the right to modify the specifications in this manual without previous warning. Any copy of this manual, in part or in full, whether by photocopy or by other means, even of electronic nature, without the manufacture giving written authorisation, breaches the terms of copyright and is liable to prosecution.

It is absolutely forbidden to use the device for different uses other than those for which it has been devised for, as inferred to in this manual. When using the features in this device, obey all laws and respect privacy and legitimate rights of others.

EXCEPT TO THE EXTENT PROHIBITED BY APPLICABLE LAW, UNDER NO CIRCUMSTANCES SHALL THE MANUFACTURER BE LIABLE FOR CONSEQUENTIAL DAMAGES SUSTAINED IN CONNECTION WITH SAID PRODUCT AND THE MANUFACTURER NEITHER ASSUMES NOR AUTHORIZES ANY REPRESENTATIVE OR OTHER PERSON TO ASSUME FOR IT ANY OBLIGATION OR LIABILITY OTHER THAN SUCH AS IS EXPRESSLY SET FORTH HEREIN.

All trademarks in this manual are property of their respective owners.

The information contained in this manual is for information purposes only, is subject to changes without previous warning and cannot be considered binding for the Manufacturer. The Manufacturer assumes no responsibility for any errors or incoherence possibly contained in this manual.

Index

1. Description	3
1.1 LRC generation.....	4
1.2 CRC generation	5
2. Read commands structure.....	8
2.1 MODBUS ASCII/RTU	8
2.2 Floating point as per IEEE Standard.....	9
3. Write commands structure	10
3.1 MODBUS ASCII/RTU	10
4. Exception codes	11
4.1 MODBUS ASCII/RTU	11
5. General information on register tables	12
6. Register set 0.....	13
6.1 READING registers (Function code \$01/\$03/\$04)	13
6.2 WRITING registers (Function code \$10)	21
7. Register set 1.....	22
7.1 READING registers (Function code \$01/\$03/\$04)	22
7.2 WRITING registers (Function code \$10)	30

1. Description

MODBUS ASCII/RTU is a master-slave communication protocol, able to support up to 247 slaves connected in a bus or a star network.

The protocol uses a simplex connection on a single line. In this way, the communication messages move on a single line in two opposite directions.

Master-slave messages can be:

- **Reading (Function code \$01 / \$03 / \$04)**: the communication is between the master and a single slave. It allows to read information about the queried counter
- **Writing (Function code \$10)**: the communication is between the master and a single slave. It allows to change the counter settings
- **Broadcast**: the communication is between the master and all the connected slaves. It is always a write command (Function code \$10) and required logical number \$00

In a multi-point type connection (MODBUS ASCII/RTU), **slave address** (called also **logical number**) allows to identify each counter during the communication. Each counter is preset with a default slave address (01) and the user can change it.

COMMUNICATION FRAME STRUCTURE

ASCII mode

Bit per byte: 1 Start, 7 Bit, Even, 1 Stop (7E1)

Name	Length	Function
START FRAME	1 char	Message start marker. Starts with colon ":" (\$3A)
ADDRESS FIELD	2 chars	Counter logical number
FUNCTION CODE	2 chars	Function code (\$01 / \$03 / \$04 / \$10)
DATA FIELD	n chars	Data + length will be filled depending on the message type
ERROR CHECK	2 chars	Error check (LRC)
END FRAME	2 chars	Carriage return - line feed (CRLF) pair (\$0D & \$0A)

RTU mode

Bit per byte: 1 Start, 8 Bit, None, 1 Stop (8N1)

Name	Length	Function
START FRAME	4 chars idle	At least 4 character time of silence (MARK condition)
ADDRESS FIELD	8 bits	Counter logical number
FUNCTION CODE	8 bits	Function code (\$01 / \$03 / \$04 / \$10)
DATA FIELD	n x 8 bits	Data + length will be filled depending on the message type
ERROR CHECK	16 bits	Error check (CRC)
END FRAME	4 chars idle	At least 4 character time of silence between frames

1.1 LRC generation

The Longitudinal Redundancy Check (LRC) field is one byte, containing an 8-bit binary value. The LRC value is calculated by the transmitting device, which appends the LRC to the message. The receiving device recalculates an LRC during receipt of the message, and compares the calculated value to the actual value it received in the LRC field. If the two values are not equal, an error results. The LRC is calculated by adding together successive 8-bit bytes in the message, discarding any carries, and then two's complementing the result. The LRC is an 8-bit field, therefore each new addition of a character that would result in a value higher than 255 decimal simply 'rolls over' the field's value through zero. Because there is no ninth bit, the carry is discarded automatically.

A procedure for generating an LRC is:

1. Add all bytes in the message, excluding the starting 'colon' and ending CR LF. Add them into an 8-bit field, so that carries will be discarded.
2. Subtract the final field value from \$FF, to produce the ones-complement.
3. Add 1 to produce the twos-complement.

PLACING THE LRC INTO THE MESSAGE

When the the 8-bit LRC (2 ASCII characters) is transmitted in the message, the high-order character will be transmitted first, followed by the low-order character. For example, if the LRC value is \$52 (0101 0010):

Colon ':'	Addr	Func	Data Count	Data	Data		Data	LRC Hi '5'	LRC Lo '2'	CR	LF
--------------	------	------	---------------	------	------	------	------	---------------	---------------	----	----

C-FUNCTION TO CALCULATE LRC

```
*pucFrame - pointer on "Addr" of message
usLen - length message from "Addr" to end "Data"

UCHAR prvucMBLRC( UCHAR * pucFrame, USHORT usLen )
{
    UCHAR          ucLRC = 0;  /* LRC char initialized */

    while( usLen-- )
    {
        ucLRC += *pucFrame++;  /* Add buffer byte without carry */
    }

    /* Return twos complement */
    ucLRC = ( UCHAR ) ( -( ( CHAR ) ucLRC ) );
    return ucLRC;
}
```

1.2 CRC generation

The Cyclical Redundancy Check (CRC) field is two bytes, containing a 16-bit value. The CRC value is calculated by the transmitting device, which appends the CRC to the message. The receiving device recalculates a CRC during receipt of the message, and compares the calculated value to the actual value it received in the CRC field. If the two values are not equal, an error results.

The CRC is started by first preloading a 16-bit register to all 1's. Then a process begins of applying successive 8-bit bytes of the message to the current contents of the register. Only the eight bits of data in each character are used for generating the CRC. Start and stop bits, and the parity bit, do not apply to the CRC.

During generation of the CRC, each 8-bit character is exclusive ORed with the register contents. Then the result is shifted in the direction of the least significant bit (LSB), with a zero filled into the most significant bit (MSB) position. The LSB is extracted and examined. If the LSB was a 1, the register is then exclusive ORed with a preset, fixed value. If the LSB was a 0, no exclusive OR takes place.

This process is repeated until eight shifts have been performed. After the last (eighth) shift, the next 8-bit character is exclusive ORed with the register's current value, and the process repeats for eight more shifts as described above. The final contents of the register, after all the characters of the message have been applied, is the CRC value.

A calculated procedure for generating a CRC is:

1. Load a 16-bit register with \$FFFF. Call this the CRC register.
2. Exclusive OR the first 8-bit byte of the message with the low-order byte of the 16-bit CRC register, putting the result in the CRC register.
3. Shift the CRC register one bit to the right (toward the LSB), zero-filling the MSB. Extract and examine the LSB.
4. (If the LSB was 0): Repeat Step 3 (another shift).
(If the LSB was 1): Exclusive OR the CRC register with the polynomial value \$A001 (1010 0000 0000 0001).
5. Repeat Steps 3 and 4 until 8 shifts have been performed. When this is done, a complete 8-bit byte will have been processed.
6. Repeat Steps 2 through 5 for the next 8-bit byte of the message. Continue doing this until all bytes have been processed.
7. The final contents of the CRC register is the CRC value.
8. When the CRC is placed into the message, its upper and lower bytes must be swapped as described below.

PLACING THE CRC INTO THE MESSAGE

When the 16-bit CRC (two 8-bit bytes) is transmitted in the message, the low-order byte will be transmitted first, followed by the high-order byte.

For example, if the CRC value is \$35F7 (0011 0101 1111 0111):

Addr	Func	Data Count	Data	Data		Data	CRC lo F7	CRC hi 35
------	------	---------------	------	------	------	------	--------------	--------------

CRC GENERATION FUNCTIONS - With Table

All of the possible CRC values are preloaded into two arrays, which are simply indexed as the function increments through the message buffer. One array contains all of the 256 possible CRC values for the high byte of the 16-bit CRC field, and the other array contains all of the values for the low byte. Indexing the CRC in this way provides faster execution than would be achieved by calculating a new CRC value with each new character from the message buffer.

```

/*CRC table for calculate with polynom 0xA001 with init value 0xFFFF, High half word*/
rom unsigned char CRC_Table_Hi[] = {
    0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x80, 0x41, 0x00, 0xC1, 0x81,
    0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0,
    0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01,
    0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41,
    0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81,
    0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0,
    0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01,
    0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40,
    0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81,
    0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0,
    0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01,
    0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41,
    0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81,
    0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0,
    0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01,
    0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81, 0x40, 0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41,
    0x00, 0xC1, 0x81, 0x40, 0x01, 0xC0, 0x80, 0x41, 0x01, 0xC0, 0x80, 0x41, 0x00, 0xC1, 0x81,
    0x40
};

/*CRC table for calculate with polynom 0xA001 with init value 0xFFFF, Low half word*/
rom unsigned char CRC_Table_Lo[] = {
    0x00, 0xC0, 0xC1, 0x01, 0xC3, 0x03, 0x02, 0xC2, 0xC6, 0x06, 0x07, 0xC7, 0x05, 0xC5, 0xC4,
    0x04, 0xCC, 0x0C, 0x0D, 0xCD, 0x0F, 0xCF, 0xCE, 0x0E, 0x0A, 0xCA, 0xCB, 0x0B, 0xC9, 0x09,
    0x08, 0xC8, 0xD8, 0x18, 0x19, 0xD9, 0x1B, 0xDE, 0xDA, 0x1A, 0x1E, 0xDE, 0xDF, 0x1F, 0xDD,
    0x1D, 0xDC, 0xDC, 0x14, 0xD4, 0xD5, 0x15, 0xD7, 0x17, 0x16, 0xD6, 0xD2, 0x12, 0x13, 0xD3,
    0x11, 0xD1, 0xD0, 0x10, 0xF0, 0x30, 0x31, 0xF1, 0x33, 0xF3, 0xF2, 0x32, 0x36, 0xF6, 0xF7,
    0x37, 0xF5, 0x35, 0x34, 0xF4, 0x3C, 0xFC, 0xFD, 0x3D, 0xFF, 0x3F, 0x3E, 0xFE, 0xFA, 0x3A,
    0x3B, 0xFB, 0x39, 0xF9, 0xF8, 0x38, 0x28, 0xE8, 0xE9, 0x29, 0xEB, 0x2B, 0x2A, 0xEA, 0xEE,
    0x2E, 0x2F, 0xEF, 0x2D, 0xED, 0xEC, 0x2C, 0xE4, 0x24, 0x25, 0xE5, 0x27, 0xE7, 0xE6, 0x26,
    0x22, 0xE2, 0xE3, 0x23, 0xE1, 0x21, 0x20, 0xE0, 0xA0, 0x60, 0x61, 0xA1, 0x63, 0xA3, 0xA2,
    0x62, 0x66, 0xA6, 0xA7, 0x67, 0xA5, 0x65, 0x64, 0xA4, 0x6C, 0xAC, 0xAD, 0x6D, 0xAF, 0x6F,
    0x6E, 0xAE, 0xAA, 0x6A, 0x6B, 0xAB, 0x69, 0xA9, 0xA8, 0x68, 0x78, 0xB8, 0xB9, 0x79, 0xBB,
    0x7B, 0x7A, 0xBA, 0xBE, 0x7E, 0x7F, 0xBF, 0x7D, 0xBD, 0xBC, 0x7C, 0xB4, 0x74, 0x75, 0xB5,
    0x77, 0xB7, 0xB6, 0x76, 0x72, 0xB2, 0xB3, 0x73, 0xB1, 0x71, 0x70, 0xB0, 0x50, 0x90, 0x91,
    0x51, 0x93, 0x53, 0x52, 0x92, 0x96, 0x56, 0x57, 0x97, 0x55, 0x95, 0x94, 0x54, 0x9C, 0x5C,
    0x5D, 0x9D, 0x5F, 0x9F, 0x9E, 0x5E, 0x5A, 0x9A, 0x9B, 0x5B, 0x99, 0x59, 0x58, 0x98, 0x88,
    0x48, 0x49, 0x89, 0x4B, 0x8B, 0x4A, 0x4E, 0x8E, 0x8F, 0x4F, 0x8D, 0x4D, 0x4C, 0x8C,
    0x44, 0x84, 0x85, 0x45, 0x87, 0x47, 0x46, 0x86, 0x82, 0x42, 0x43, 0x83, 0x41, 0x81, 0x80,
    0x40
};

};

unsigned short ModBus_CRC16( unsigned char * Buffer, unsigned short Length )
{
    unsigned char CRCHi = 0xFF;
    unsigned char CRCLo = 0xFF;
    int Index;
    unsigned short ret;

    while( Length-- )
    {
        Index = CRCLo ^ *Buffer++;
        CRCLo = CRCHi ^ CRC_Table_Hi[Index];
        CRCHi = CRC_Table_Lo[Index];
    }

    ret=((unsigned short)CRCHi << 8);
    ret|= (unsigned short)CRCLo;
    return ret;
}

```

CRC GENERATION FUNCTIONS - Without Table

```

unsigned short ModBus_CRC16( unsigned char * Buffer, unsigned short Length )
{
/* ModBus_CRC16 Calculatd CRC16 with polynome 0xA001 and init value 0xFFFF
Input *Buffer - pointer on data
Input Lenght - number byte in buffer
Output - calculated CRC16
*/
    unsigned int cur_crc;

    cur_crc=0xFFFF;
    do
    {
        unsigned int i = 8;
        cur_crc = cur_crc ^ *Buffer++;
        do
        {
            if (0x0001 & cur_crc)
            {
                cur_crc >>= 1;
                cur_crc ^= 0xA001;
            }
            else
            {
                cur_crc >>= 1;
            }
        }
        while (--i);
    }
    while (--Length);

    return cur_crc;
}

```

2. Read commands structure

The master communication device can send commands to the module to read its status and setup or to read the measured values, status and setup relevant to the counter.

More registers can be read, at the same time, sending a single command, only if the registers are consecutive (see chapter 5).

According to the used MODBUS protocol mode, the read command is structured as follows.

2.1 MODBUS ASCII/RTU

Values contained both in Query or Response messages are in hex format.

Query example in case of MODBUS RTU: 01030002000265CB

Example	Byte	Description	No. of bytes
01	-	Slave address	1
03	-	Function code	1
00	High	Starting register	2
02	Low		
00	High	No. of words to be read	2
02	Low		
65	High	Error check (CRC)	2
CB	Low		

Response example in case of MODBUS RTU: 01030400035571F547

Example	Byte	Description	No. of bytes
01	-	Slave address	1
03	-	Function code	1
04	-	Byte count	1
00	High	Requested data	4
03	Low		
55	High		
71	Low		
F5	High	Error check (CRC)	2
47	Low		

2.2 Floating point as per IEEE Standard


The basic format allows a IEEE standard floating-point number to be represented in a single 32 bit format, as shown below:

$$N.n = (-1)^S 2^{e'-127} (1.f)$$

where **S** is the sign bit, **e'** is the first part of the exponent and **f** is the decimal fraction placed next to 1. Internally the exponent is 8 bits in length and the stored fraction is 23 bits long.

A round to nearest method is applied to the calculated value of floating point.

The floating-point format is shown as follows:



where:

	bit length
Sign	1
Exponent	8
Fraction	23 + {1}
Total	m = 32 + {1}
Exponent	
Min e'	0
Max e'	255
Bias	127



NOTE

Fractions (decimals) are always shown while the leading 1 (hidden bit) is not stored.

EXAMPLE OF CONVERSION OF VALUE SHOWN WITH FLOATING POINT

Value read with floating point:

45AACC00₍₁₆₎

Value converted in binary format:

010001011 010101011001100000000000₍₂₎

exponent	fraction

sign

sign = 0

exponent = 10001011₍₂₎ = 139₍₁₀₎

fraction = 010101011001100000000000₍₂₎ / 8388608₍₁₀₎ =
= 2804736₍₁₀₎ / 8388608₍₁₀₎ = 0.334350585₍₁₀₎

$$N.n = (-1)^S 2^{e'-127} (1+f) =$$

$$= (-1)^0 2^{139-127} (1.334350585) =$$

$$= (+1) (4096) (1.334350585) =$$

$$= 5465.5$$

3. Write commands structure

The master communication device can send commands to the module to program itself or to program the counter.

More settings can be carried out, at the same time, sending a single command, only if the relevant registers are consecutive (see chapter 5).

According to the used MODBUS protocol type, the write command is structured as follows.

3.1 MODBUS ASCII/RTU

Values contained both in Request or Response messages are in hex format.

Query example in case of MODBUS RTU: 011005150001020008F053

Example	Byte	Description	No. of bytes
01	-	Slave address	1
10	-	Function code	1
05	High	Starting register	2
15	Low		
00	High	No. of words to be written	2
01	Low		
02	-	Data byte counter	1
00	High	Data for programming	2
08	Low		
F0	High	Error check (CRC)	2
53	Low		

Response example in case of MODBUS RTU: 01100515000110C1

Example	Byte	Description	No. of bytes
01	-	Slave address	1
10	-	Function code	1
05	High	Starting register	2
15	Low		
00	High	No. of written words	2
01	Low		
10	High	Error check (CRC)	2
C1	Low		

4. Exception codes

When the module receives a not-valid query, an error message (exception code) is sent. According to the used MODBUS protocol mode, possible exception codes are as follows.

4.1 MODBUS ASCII/RTU

Values contained in Response messages are in hex format.

Response example in case of MODBUS RTU: 01830131F0

Example	Byte	Description	No. of bytes
01	-	Slave address	1
83	-	Function code {80+03}	1
01	-	Exception code	1
31	High	Error check (CRC)	2
F0	Low		

Exception codes for MODBUS ASCII/RTU are following described:

- \$01 ILLEGAL FUNCTION:** the function code received in the query is not an allowable action.
- \$02 ILLEGAL DATA ADDRESS:** the data address received in the query is not an allowable address (i.e. the combination of register and transfer length is invalid).
- \$03 ILLEGAL DATA VALUE:** a value contained in the query data field is not an allowable value.
- \$04 ILLEGAL RESPONSE LENGTH:** the request would generate a response with size bigger than that available for MODBUS protocol.

5. General information on register tables

 NOTE

Highest number of registers (or bytes) which can be read with a single command:

- in ASCII mode: 63 registers
- in RTU mode: 127 registers

 NOTE

Highest number of registers which can be programmed with a single command:

- in ASCII mode: 13 registers
- in RTU mode: 29 registers

 NOTE

The register values are in hex format (\$).

TABLE HEADER	MEANING
Parameter	Measuring parameter to be read
Register description	Description of the register to be read / written
F. code (Hex)	Function code in hex format. It identifies the command type (reading / writing)
Sign	If this column is checked, the read register value can have positive or negative sign. The negative values are represented with 2's complement.
INTEGER	Details for INTEGER type registers
IEEE	Details for IEEE standard type registers
Register (Hex)	Register address in hex format
Words	Number of word to be read / written for the register (length)
M.U.	Measuring unit of parameter
Data meaning	Description of data received by a response of a reading command
Programmable data	Description of data which can be sent for a writing command

Two register set can be selected for communication, according to the module:

- **Register set 0**: even / odd words registers.
- **Register set 1**: even words registers. Available only for RS485 modules with firmware release 2.00 or higher.

It is possible to switch from Register set 0 to 1 and viceversa, function available only for RS485 modules with firmware release 2.00 or higher.

6. Register set 0

6.1 READING registers (Function code \$01/\$03/\$04)

Parameter	F. code (Hex)	Sign	INTEGER			IEEE		
			Register (Hex)	Words	M.U.	Register (Hex)	Words	M.U.
REAL TIME VALUES								
V1 • L-N voltage phase 1	03/04		0000	2	mV	1000	2	V
V2 • L-N voltage phase 2	03/04		0002	2	mV	1002	2	V
V3 • L-N voltage phase 3	03/04		0004	2	mV	1004	2	V
V12 • L-L voltage line 12	03/04		0006	2	mV	1006	2	V
V23 • L-L voltage line 23	03/04		0008	2	mV	1008	2	V
V31 • L-L voltage line 31	03/04		000A	2	mV	100A	2	V
VΣ • System voltage	03/04		000C	2	mV	100C	2	V
A1 • Phase 1 current	03/04	X	000E	2	mA	100E	2	A
A2 • Phase 2 current	03/04	X	0010	2	mA	1010	2	A
A3 • Phase 3 current	03/04	X	0012	2	mA	1012	2	A
AN • Neutral current	03/04	X	0014	2	mA	1014	2	A
AΣ • System current	03/04	X	0016	2	mA	1016	2	A
PF1 • Phase 1 power factor	03/04	X	0018	1	-	1018	2	-
PF2 • Phase 2 power factor	03/04	X	0019	1	-	101A	2	-
PF3 • Phase 3 power factor	03/04	X	001A	1	-	101C	2	-
PFΣ • System power factor	03/04	X	001B	1	-	101E	2	-
P1 • Phase 1 active power	03/04	X	001C	3	mW	1020	2	W
P2 • Phase 2 active power	03/04	X	001F	3	mW	1022	2	W
P3 • Phase 3 active power	03/04	X	0022	3	mW	1024	2	W
PΣ • System active power	03/04	X	0025	3	mW	1026	2	W
S1 • Phase 1 apparent power	03/04	X	0028	3	mVA	1028	2	VA
S2 • Phase 2 apparent power	03/04	X	002B	3	mVA	102A	2	VA
S3 • Phase 3 apparent power	03/04	X	002E	3	mVA	102C	2	VA
SΣ • System apparent power	03/04	X	0031	3	mVA	102E	2	VA
Q1 • Phase 1 reactive power	03/04	X	0034	3	mvar	1030	2	var
Q2 • Phase 2 reactive power	03/04	X	0037	3	mvar	1032	2	var
Q3 • Phase 3 reactive power	03/04	X	003A	3	mvar	1034	2	var
QΣ • System reactive power	03/04	X	003D	3	mvar	1036	2	var
F • Frequency	03/04		0040	1	mHz	1038	2	Hz
Phase sequence	03/04		0041	1	-	103A	2	-
INTEGER: \$00=123-CCW, \$01=321-CW, \$02=not defined								
IEEE: \$3DFBE76D=123-CCW, \$3E072B02=321-CW, \$0=not defined								

Parameter	F. code (Hex)	Sign	INTEGER			IEEE		
			Register (Hex)	Words	M.U.	Register (Hex)	Words	M.U.
TOTAL COUNTER VALUES								
+kWh1 • Phase 1 imported active energy	03/04		0100	3	0.1 Wh	1100	2	Wh
+kWh2 • Phase 2 imported active energy	03/04		0103	3	0.1 Wh	1102	2	Wh
+kWh3 • Phase 3 imported active energy	03/04		0106	3	0.1 Wh	1104	2	Wh
+kWhΣ • System imported active energy	03/04		0109	3	0.1 Wh	1106	2	Wh
-kWh1 • Phase 1 exported active energy	03/04		010C	3	0.1 Wh	1108	2	Wh
-kWh2 • Phase 2 exported active energy	03/04		010F	3	0.1 Wh	110A	2	Wh
-kWh3 • Phase 3 exported active energy	03/04		0112	3	0.1 Wh	110C	2	Wh
-kWhΣ • System exported active energy	03/04		0115	3	0.1 Wh	110E	2	Wh
+kVAh1-L • Phase 1 imported lagging apparent energy	03/04		0118	3	0.1 VAh	1110	2	VAh
+kVAh2-L • Phase 2 imported lagging apparent energy	03/04		011B	3	0.1 VAh	1112	2	VAh
+kVAh3-L • Phase 3 imported lagging apparent energy	03/04		011E	3	0.1 VAh	1114	2	VAh
+kVAhΣ-L • System imported lagging apparent energy	03/04		0121	3	0.1 VAh	1116	2	VAh
-kVAh1-L • Phase 1 exported lagging apparent energy	03/04		0124	3	0.1 VAh	1118	2	VAh
-kVAh2-L • Phase 2 exported lagging apparent energy	03/04		0127	3	0.1 VAh	111A	2	VAh
-kVAh3-L • Phase 3 exported lagging apparent energy	03/04		012A	3	0.1 VAh	111C	2	VAh
-kVAhΣ-L • System exported lagging apparent energy	03/04		012D	3	0.1 VAh	111E	2	VAh
+kVAh1-C • Phase 1 imported leading apparent energy	03/04		0130	3	0.1 VAh	1120	2	VAh
+kVAh2-C • Phase 2 imported leading apparent energy	03/04		0133	3	0.1 VAh	1122	2	VAh
+kVAh3-C • Phase 3 imported leading apparent energy	03/04		0136	3	0.1 VAh	1124	2	VAh
+kVAhΣ-C • System imported leading apparent energy	03/04		0139	3	0.1 VAh	1126	2	VAh
-kVAh1-C • Phase 1 exported leading apparent energy	03/04		013C	3	0.1 VAh	1128	2	VAh
-kVAh2-C • Phase 2 exported leading apparent energy	03/04		013F	3	0.1 VAh	112A	2	VAh
-kVAh3-C • Phase 3 exported leading apparent energy	03/04		0142	3	0.1 VAh	112C	2	VAh
-kVAhΣ-C • System exported leading apparent energy	03/04		0145	3	0.1 VAh	112E	2	VAh
+kvarh1-L • Phase 1 imported lagging reactive energy	03/04		0148	3	0.1 varh	1130	2	varh
+kvarh2-L • Phase 2 imported lagging reactive energy	03/04		014B	3	0.1 varh	1132	2	varh
+kvarh3-L • Phase 3 imported lagging reactive energy	03/04		014E	3	0.1 varh	1134	2	varh
+kvarhΣ-L • System imported lagging reactive energy	03/04		0151	3	0.1 varh	1136	2	varh
-kvarh1-L • Phase 1 exported lagging reactive energy	03/04		0154	3	0.1 varh	1138	2	varh
-kvarh2-L • Phase 2 exported lagging reactive energy	03/04		0157	3	0.1 varh	113A	2	varh
-kvarh3-L • Phase 3 exported lagging reactive energy	03/04		015A	3	0.1 varh	113C	2	varh
-kvarhΣ-L • System exported lagging reactive energy	03/04		015D	3	0.1 varh	113E	2	varh
+kvarh1-C • Phase 1 imported leading reactive energy	03/04		0160	3	0.1 varh	1140	2	varh
+kvarh2-C • Phase 2 imported leading reactive energy	03/04		0163	3	0.1 varh	1142	2	varh
+kvarh3-C • Phase 3 imported leading reactive energy	03/04		0166	3	0.1 varh	1144	2	varh
+kvarhΣ-C • System imported leading reactive energy	03/04		0169	3	0.1 varh	1146	2	varh
-kvarh1-C • Phase 1 exported leading reactive energy	03/04		016C	3	0.1 varh	1148	2	varh
-kvarh2-C • Phase 2 exported leading reactive energy	03/04		016F	3	0.1 varh	114A	2	varh
-kvarh3-C • Phase 3 exported leading reactive energy	03/04		0172	3	0.1 varh	114C	2	varh
-kvarhΣ-C • System exported leading reactive energy	03/04		0175	3	0.1 varh	114E	2	varh

Parameter	F. code (Hex)	Sign	INTEGER			IEEE		
			Register (Hex)	Words	M.U.	Register (Hex)	Words	M.U.

TARIFF 1 COUNTER VALUES

+kWh1 • Phase 1 imported active energy	03/04		0200	3	0.1 Wh	1200	2	Wh
+kWh2 • Phase 2 imported active energy	03/04		0203	3	0.1 Wh	1202	2	Wh
+kWh3 • Phase 3 imported active energy	03/04		0206	3	0.1 Wh	1204	2	Wh
+kWh Σ • System imported active energy	03/04		0209	3	0.1 Wh	1206	2	Wh
-kWh1 • Phase 1 exported active energy	03/04		020C	3	0.1 Wh	1208	2	Wh

TARIFF 1 COUNTER VALUES

-kWh2 • Phase 2 exported active energy	03/04		020F	3	0.1 Wh	120A	2	Wh
-kWh3 • Phase 3 exported active energy	03/04		0212	3	0.1 Wh	120C	2	Wh
-kWh Σ • System exported active energy	03/04		0215	3	0.1 Wh	120E	2	Wh
+kVAh1-L • Phase 1 imported lagging apparent energy	03/04		0218	3	0.1 VAh	1210	2	VAh
+kVAh2-L • Phase 2 imported lagging apparent energy	03/04		021B	3	0.1 VAh	1212	2	VAh
+kVAh3-L • Phase 3 imported lagging apparent energy	03/04		021E	3	0.1 VAh	1214	2	VAh
+kVAh Σ -L • System imported lagging apparent energy	03/04		0221	3	0.1 VAh	1216	2	VAh
-kVAh1-L • Phase 1 exported lagging apparent energy	03/04		0224	3	0.1 VAh	1218	2	VAh
-kVAh2-L • Phase 2 exported lagging apparent energy	03/04		0227	3	0.1 VAh	121A	2	VAh
-kVAh3-L • Phase 3 exported lagging apparent energy	03/04		022A	3	0.1 VAh	121C	2	VAh
-kVAh Σ -L • System exported lagging apparent energy	03/04		022D	3	0.1 VAh	121E	2	VAh
+kVAh1-C • Phase 1 imported leading apparent energy	03/04		0230	3	0.1 VAh	1220	2	VAh
+kVAh2-C • Phase 2 imported leading apparent energy	03/04		0233	3	0.1 VAh	1222	2	VAh
+kVAh3-C • Phase 3 imported leading apparent energy	03/04		0236	3	0.1 VAh	1224	2	VAh
+kVAh Σ -C • System imported leading apparent energy	03/04		0239	3	0.1 VAh	1226	2	VAh
-kVAh1-C • Phase 1 exported leading apparent energy	03/04		023C	3	0.1 VAh	1228	2	VAh
-kVAh2-C • Phase 2 exported leading apparent energy	03/04		023F	3	0.1 VAh	122A	2	VAh
-kVAh3-C • Phase 3 exported leading apparent energy	03/04		0242	3	0.1 VAh	122C	2	VAh
-kVAh Σ -C • System exported leading apparent energy	03/04		0245	3	0.1 VAh	122E	2	VAh
+kvarh1-L • Phase 1 imported lagging reactive energy	03/04		0248	3	0.1 varh	1230	2	varh
+kvarh2-L • Phase 2 imported lagging reactive energy	03/04		024B	3	0.1 varh	1232	2	varh
+kvarh3-L • Phase 3 imported lagging reactive energy	03/04		024E	3	0.1 varh	1234	2	varh
+kvarh Σ -L • System imported lagging reactive energy	03/04		0251	3	0.1 varh	1236	2	varh
-kvarh1-L • Phase 1 exported lagging reactive energy	03/04		0254	3	0.1 varh	1238	2	varh
-kvarh2-L • Phase 2 exported lagging reactive energy	03/04		0257	3	0.1 varh	123A	2	varh
-kvarh3-L • Phase 3 exported lagging reactive energy	03/04		025A	3	0.1 varh	123C	2	varh
-kvarh Σ -L • System exported lagging reactive energy	03/04		025D	3	0.1 varh	123E	2	varh
+kvarh1-C • Phase 1 imported leading reactive energy	03/04		0260	3	0.1 varh	1240	2	varh
+kvarh2-C • Phase 2 imported leading reactive energy	03/04		0263	3	0.1 varh	1242	2	varh
+kvarh3-C • Phase 3 imported leading reactive energy	03/04		0266	3	0.1 varh	1244	2	varh
+kvarh Σ -C • System imported leading reactive energy	03/04		0269	3	0.1 varh	1246	2	varh
-kvarh1-C • Phase 1 exported leading reactive energy	03/04		026C	3	0.1 varh	1248	2	varh
-kvarh2-C • Phase 2 exported leading reactive energy	03/04		026F	3	0.1 varh	124A	2	varh
-kvarh3-C • Phase 3 exported leading reactive energy	03/04		0272	3	0.1 varh	124C	2	varh
-kvarh Σ -C • System exported leading reactive energy	03/04		0275	3	0.1 varh	124E	2	varh

Parameter	F. code (Hex)	Sign	INTEGER			IEEE		
			Register (Hex)	Words	M.U.	Register (Hex)	Words	M.U.

TARIFF 2 COUNTER VALUES

+kWh1 • Phase 1 imported active energy	03/04		0300	3	0.1 Wh	1300	2	Wh
+kWh2 • Phase 2 imported active energy	03/04		0303	3	0.1 Wh	1302	2	Wh
+kWh3 • Phase 3 imported active energy	03/04		0306	3	0.1 Wh	1304	2	Wh
+kWh Σ • System imported active energy	03/04		0309	3	0.1 Wh	1306	2	Wh
-kWh1 • Phase 1 exported active energy	03/04		030C	3	0.1 Wh	1308	2	Wh
-kWh2 • Phase 2 exported active energy	03/04		030F	3	0.1 Wh	130A	2	Wh
-kWh3 • Phase 3 exported active energy	03/04		0312	3	0.1 Wh	130C	2	Wh
-kWh Σ • System exported active energy	03/04		0315	3	0.1 Wh	130E	2	Wh
+kVAh1-L • Phase 1 imported lagging apparent energy	03/04		0318	3	0.1 VAh	1310	2	VAh
+kVAh2-L • Phase 2 imported lagging apparent energy	03/04		031B	3	0.1 VAh	1312	2	VAh

TARIFF 2 COUNTER VALUES

+kVAh3-L • Phase 3 imported lagging apparent energy	03/04		031E	3	0.1 VAh	1314	2	VAh
+kVAh Σ -L • System imported lagging apparent energy	03/04		0321	3	0.1 VAh	1316	2	VAh
-kVAh1-L • Phase 1 exported lagging apparent energy	03/04		0324	3	0.1 VAh	1318	2	VAh
-kVAh2-L • Phase 2 exported lagging apparent energy	03/04		0327	3	0.1 VAh	131A	2	VAh
-kVAh3-L • Phase 3 exported lagging apparent energy	03/04		032A	3	0.1 VAh	131C	2	VAh
-kVAh Σ -L • System exported lagging apparent energy	03/04		032D	3	0.1 VAh	131E	2	VAh
+kVAh1-C • Phase 1 imported leading apparent energy	03/04		0330	3	0.1 VAh	1320	2	VAh
+kVAh2-C • Phase 2 imported leading apparent energy	03/04		0333	3	0.1 VAh	1322	2	VAh
+kVAh3-C • Phase 3 imported leading apparent energy	03/04		0336	3	0.1 VAh	1324	2	VAh
+kVAh Σ -C • System imported leading apparent energy	03/04		0339	3	0.1 VAh	1326	2	VAh
-kVAh1-C • Phase 1 exported leading apparent energy	03/04		033C	3	0.1 VAh	1328	2	VAh
-kVAh2-C • Phase 2 exported leading apparent energy	03/04		033F	3	0.1 VAh	132A	2	VAh
-kVAh3-C • Phase 3 exported leading apparent energy	03/04		0342	3	0.1 VAh	132C	2	VAh
-kVAh Σ -C • System exported leading apparent energy	03/04		0345	3	0.1 VAh	132E	2	VAh
+kvarh1-L • Phase 1 imported lagging reactive energy	03/04		0348	3	0.1 varh	1330	2	varh
+kvarh2-L • Phase 2 imported lagging reactive energy	03/04		034B	3	0.1 varh	1332	2	varh
+kvarh3-L • Phase 3 imported lagging reactive energy	03/04		034E	3	0.1 varh	1334	2	varh
+kvarh Σ -L • System imported lagging reactive energy	03/04		0351	3	0.1 varh	1336	2	varh
-kvarh1-L • Phase 1 exported lagging reactive energy	03/04		0354	3	0.1 varh	1338	2	varh
-kvarh2-L • Phase 2 exported lagging reactive energy	03/04		0357	3	0.1 varh	133A	2	varh
-kvarh3-L • Phase 3 exported lagging reactive energy	03/04		035A	3	0.1 varh	133C	2	varh
-kvarh Σ -L • System exported lagging reactive energy	03/04		035D	3	0.1 varh	133E	2	varh
+kvarh1-C • Phase 1 imported leading reactive energy	03/04		0360	3	0.1 varh	1340	2	varh
+kvarh2-C • Phase 2 imported leading reactive energy	03/04		0363	3	0.1 varh	1342	2	varh
+kvarh3-C • Phase 3 imported leading reactive energy	03/04		0366	3	0.1 varh	1344	2	varh
+kvarh Σ -C • System imported leading reactive energy	03/04		0369	3	0.1 varh	1346	2	varh
-kvarh1-C • Phase 1 exported leading reactive energy	03/04		036C	3	0.1 varh	1348	2	varh
-kvarh2-C • Phase 2 exported leading reactive energy	03/04		036F	3	0.1 varh	134A	2	varh
-kvarh3-C • Phase 3 exported leading reactive energy	03/04		0372	3	0.1 varh	134C	2	varh
-kvarh Σ -C • System exported leading reactive energy	03/04		0375	3	0.1 varh	134E	2	varh

Parameter	F. code (Hex)	Sign	INTEGER			IEEE		
			Register (Hex)	Words	M.U.	Register (Hex)	Words	M.U.

PARTIAL COUNTER VALUES

+kWh Σ • System imported active energy	03/04		0400	3	0.1 Wh	1400	2	Wh
-kWh Σ • System exported active energy	03/04		0403	3	0.1 Wh	1402	2	Wh
+kVAh Σ -L • System imported lagging apparent energy	03/04		0406	3	0.1 VAh	1404	2	VAh
-kVAh Σ -L • System exported lagging apparent energy	03/04		0409	3	0.1 VAh	1406	2	VAh
+kVAh Σ -C • System imported leading apparent energy	03/04		040C	3	0.1 VAh	1408	2	VAh
-kVAh Σ -C • System exported leading apparent energy	03/04		040F	3	0.1 VAh	140A	2	VAh
+kvarh Σ -L • System imported lagging reactive energy	03/04		0412	3	0.1 varh	140C	2	varh
-kvarh Σ -L • System exported lagging reactive energy	03/04		0415	3	0.1 varh	140E	2	varh
+kvarh Σ -C • System imported leading reactive energy	03/04		0418	3	0.1 varh	1410	2	varh
-kvarh Σ -C • System exported leading reactive energy	03/04		041B	3	0.1 varh	1412	2	varh

BALANCE VALUES

kWh Σ • System active energy	03/04	X	041E	3	0.1 Wh	1414	2	Wh
kVAh Σ -L • System lagging apparent energy	03/04	X	0421	3	0.1 VAh	1416	2	VAh
kVAh Σ -C • System leading apparent energy	03/04	X	0424	3	0.1 VAh	1418	2	VAh
kvarh Σ -L • System lagging reactive energy	03/04	X	0427	3	0.1 varh	141A	2	varh
kvarh Σ -C • System leading reactive energy	03/04	X	042A	3	0.1 varh	141C	2	varh

Register description	F. code (Hex)	INTEGER		Data meaning
		Register (Hex)	Words	
COUNTER & COMMUNICATION DATA				
Counter serial number	03/04	0500	5	10 ASCII chars. (\$00÷\$FF)
Counter model	03/04	0505	1	\$03=6A 3phases \$08=80A 3phases \$0C=80A 1phase
Counter type	03/04	0506	1	\$02=MID \$09=with wiring selection, MID
Counter firmware release 1	03/04	0507	1	Convert the read Hex value in Decimal value. e.g. \$66=102 → rel. 1.02
Counter hardware version	03/04	0508	1	Convert the read Hex value in Decimal value. e.g. \$64=100 → rev. 1.00
Reserved	03/04	0509	2	
Tariff in use	03/04	050B	1	\$01=tariff 1 \$02=tariff 2
Primary/secondary value	03/04	050C	1	\$00=primary \$01=secondary
Error code	03/04	050D	1	\$00=none \$01=phase sequence error
CT value (only for counter 6A 3phase model)	03/04	050E	1	\$0001÷\$2710
Reserved	03/04	050F	2	
FSA value	03/04	0511	1	\$00=1A \$01=5A \$02=80A
Wiring mode	03 / 04	0512	1	\$01=3phases, 4 wires, 3 currents \$02=3phases, 3 wires, 2 currents \$03=1phase \$04=3phases, 3 wires, 3 currents
MODBUS address	03 / 04	0513	1	\$01÷\$F7
MODBUS mode	03 / 04	0514	1	\$00=7E2 (ASCII) \$01=8N1 (RTU)

Register description	F. code (Hex)	Register (Hex)	Data meaning
COILS			
Alarm events	01	0000	40 coils Byte 1 - voltage out of range UV3 UV2 UV1 UVΣ OV3 OV2 OV1 OVΣ Byte 2 - line voltage out of range COM RES UV31 UV23 UV12 OV31 OV23 OV12 Byte 3/4 - current out of range RES RES RES RES RES RES UI1 UI3 UI2 UI1 UIΣ OI1 OI3 OI2 OI1 OIΣ Byte 5 - frequency out of range RES RES RES RES RES RES RES F LEGEND UV=undervoltage OV=overvoltage UI=undercurrent OI=overcurrent F=frequency out of range COM=IR communication error RES=reserved bit to 0 NOTE: the voltage, current and frequency threshold values can change according to the counter. Please refer to the table shown below.

PARAMETER THRESHOLDS			
PHASE VOLTAGE not available for 3 wire connection	LINE VOLTAGE not available for 1phase counter	CURRENT	FREQUENCY
UV _{L-N} : 230V -20% OV _{L-N} : 240V +20%	UV _{L-L} : 400V -20% OV _{L-L} : 415V +20%	UI: Start current value (Ist) OI: Full scale value (FS)	F low: 45Hz F high: 65Hz

6.2 WRITING registers (Function code \$10)

Register description	F. code (Hex)	INTEGER		Programmable data
		Register (Hex)	Words	
COUNTER & COMMUNICATION DATA				
MODBUS address	10	0513	1	\$01÷\$F7
MODBUS mode	10	0514	1	\$00=7E2 (ASCII) \$01=8N1 (RTU)
Communication speed	10	0515	1	\$01=300 bps \$02=600 bps \$03=1200 bps \$04=2400 bps \$05=4800 bps \$06=9600 bps \$07=19200 bps \$08=38400 bps \$09=57600 bps
Partial counters status	10	0517	1	Byte 1 - partial counter selection: \$00=+kWh∑ PAR \$01=-kWh∑ PAR \$02=+kVAh∑-L PAR \$03=-kVAh∑-L PAR \$04=+kVAh∑-C PAR \$05=-kVAh∑-C PAR \$06=+kvarh∑-L PAR \$07=-kvarh∑-L PAR \$08=+kvarh∑-C PAR \$09=-kvarh∑-C PAR \$0A=all partial counters Byte 2 - partial counter/s operation: \$01=start \$02=stop \$03=reset e.g. start +kWh∑ PAR counter 00=+kWh∑ PAR 01=start final value to be set: 0001
Switch to register set 1 (not available for RS485 modules with firmware release lower than 2.00)	10	100B	1	\$01=switch to register set 1



NOTE

\$0513, \$0514, \$0515 writing registers allow to program the communication parameters.

7. Register set 1



NOTE

The following registers ARE NOT AVAILABLE for RS485 modules with firmware release lower than 2.00

7.1 READING registers (Function code \$01/\$03/\$04)

Parameter	F. code (Hex)	Sign	INTEGER			IEEE		
			Register (Hex)	Words	M.U.	Register (Hex)	Words	M.U.
REAL TIME VALUES								
V1 • L-N voltage phase 1	03/04		0000	2	mV	1000	2	V
V2 • L-N voltage phase 2	03/04		0002	2	mV	1002	2	V
V3 • L-N voltage phase 3	03/04		0004	2	mV	1004	2	V
V12 • L-L voltage line 12	03/04		0006	2	mV	1006	2	V
V23 • L-L voltage line 23	03/04		0008	2	mV	1008	2	V
V31 • L-L voltage line 31	03/04		000A	2	mV	100A	2	V
VΣ • System voltage	03/04		000C	2	mV	100C	2	V
A1 • Phase 1 current	03/04	X	000E	2	mA	100E	2	A
A2 • Phase 2 current	03/04	X	0010	2	mA	1010	2	A
A3 • Phase 3 current	03/04	X	0012	2	mA	1012	2	A
AN • Neutral current	03/04	X	0014	2	mA	1014	2	A
AΣ • System current	03/04	X	0016	2	mA	1016	2	A
PF1 • Phase 1 power factor	03/04	X	0018	2	-	1018	2	-
PF2 • Phase 2 power factor	03/04	X	001A	2	-	101A	2	-
PF3 • Phase 3 power factor	03/04	X	001C	2	-	101C	2	-
PFΣ • System power factor	03/04	X	001E	2	-	101E	2	-
P1 • Phase 1 active power	03/04	X	0020	4	mW	1020	2	W
P2 • Phase 2 active power	03/04	X	0024	4	mW	1022	2	W
P3 • Phase 3 active power	03/04	X	0028	4	mW	1024	2	W
PΣ • System active power	03/04	X	002C	4	mW	1026	2	W
S1 • Phase 1 apparent power	03/04	X	0030	4	mVA	1028	2	VA
S2 • Phase 2 apparent power	03/04	X	0034	4	mVA	102A	2	VA
S3 • Phase 3 apparent power	03/04	X	0038	4	mVA	102C	2	VA
SΣ • System apparent power	03/04	X	003C	4	mVA	102E	2	VA
Q1 • Phase 1 reactive power	03/04	X	0040	4	mvar	1030	2	var
Q2 • Phase 2 reactive power	03/04	X	0044	4	mvar	1032	2	var
Q3 • Phase 3 reactive power	03/04	X	0048	4	mvar	1034	2	var
QΣ • System reactive power	03/04	X	004C	4	mvar	1036	2	var
F • Frequency	03/04		0050	2	mHz	1038	2	Hz
Phase sequence INTEGER: \$00=123-CCW, \$01=321-CW, \$02=not defined IEEE: \$3DFBE76D=123-CCW, \$3E072B02=321-CW, \$0=not defined	03/04		0052	2	-	103A	2	-
TOTAL COUNTER VALUES								
+kWh1 • Phase 1 imported active energy	03/04		0100	4	0.1 Wh	1100	2	Wh
+kWh2 • Phase 2 imported active energy	03/04		0104	4	0.1 Wh	1102	2	Wh
+kWh3 • Phase 3 imported active energy	03/04		0108	4	0.1 Wh	1104	2	Wh
+kWhΣ • System imported active energy	03/04		010C	4	0.1 Wh	1106	2	Wh

Parameter	F. code (Hex)	Sign	INTEGER			IEEE		
			Register (Hex)	Words	M.U.	Register (Hex)	Words	M.U.

TOTAL COUNTER VALUES

-kWh1 • Phase 1 exported active energy	03/04		0110	4	0.1 Wh	1108	2	Wh
-kWh2 • Phase 2 exported active energy	03/04		0114	4	0.1 Wh	110A	2	Wh
-kWh3 • Phase 3 exported active energy	03/04		0118	4	0.1 Wh	110C	2	Wh
-kWh Σ • System exported active energy	03/04		011C	4	0.1 Wh	110E	2	Wh
+kVAh1-L • Phase 1 imported lagging apparent energy	03/04		0120	4	0.1 VAh	1110	2	VAh
+kVAh2-L • Phase 2 imported lagging apparent energy	03/04		0124	4	0.1 VAh	1112	2	VAh
+kVAh3-L • Phase 3 imported lagging apparent energy	03/04		0128	4	0.1 VAh	1114	2	VAh
+kVAh Σ -L • System imported lagging apparent energy	03/04		012C	4	0.1 VAh	1116	2	VAh
-kVAh1-L • Phase 1 exported lagging apparent energy	03/04		0130	4	0.1 VAh	1118	2	VAh
-kVAh2-L • Phase 2 exported lagging apparent energy	03/04		0134	4	0.1 VAh	111A	2	VAh
-kVAh3-L • Phase 3 exported lagging apparent energy	03/04		0138	4	0.1 VAh	111C	2	VAh
-kVAh Σ -L • System exported lagging apparent energy	03/04		013C	4	0.1 VAh	111E	2	VAh
+kVAh1-C • Phase 1 imported leading apparent energy	03/04		0140	4	0.1 VAh	1120	2	VAh
+kVAh2-C • Phase 2 imported leading apparent energy	03/04		0144	4	0.1 VAh	1122	2	VAh
+kVAh3-C • Phase 3 imported leading apparent energy	03/04		0148	4	0.1 VAh	1124	2	VAh
+kVAh Σ -C • System imported leading apparent energy	03/04		014C	4	0.1 VAh	1126	2	VAh
-kVAh1-C • Phase 1 exported leading apparent energy	03/04		0150	4	0.1 VAh	1128	2	VAh
-kVAh2-C • Phase 2 exported leading apparent energy	03/04		0154	4	0.1 VAh	112A	2	VAh
-kVAh3-C • Phase 3 exported leading apparent energy	03/04		0158	4	0.1 VAh	112C	2	VAh
-kVAh Σ -C • System exported leading apparent energy	03/04		015C	4	0.1 VAh	112E	2	VAh
+kvarh1-L • Phase 1 imported lagging reactive energy	03/04		0160	4	0.1 varh	1130	2	varh
+kvarh2-L • Phase 2 imported lagging reactive energy	03/04		0164	4	0.1 varh	1132	2	varh
+kvarh3-L • Phase 3 imported lagging reactive energy	03/04		0168	4	0.1 varh	1134	2	varh
+kvarh Σ -L • System imported lagging reactive energy	03/04		016C	4	0.1 varh	1136	2	varh
-kvarh1-L • Phase 1 exported lagging reactive energy	03/04		0170	4	0.1 varh	1138	2	varh
-kvarh2-L • Phase 2 exported lagging reactive energy	03/04		0174	4	0.1 varh	113A	2	varh
-kvarh3-L • Phase 3 exported lagging reactive energy	03/04		0178	4	0.1 varh	113C	2	varh
-kvarh Σ -L • System exported lagging reactive energy	03/04		017C	4	0.1 varh	113E	2	varh
+kvarh1-C • Phase 1 imported leading reactive energy	03/04		0180	4	0.1 varh	1140	2	varh
+kvarh2-C • Phase 2 imported leading reactive energy	03/04		0184	4	0.1 varh	1142	2	varh
+kvarh3-C • Phase 3 imported leading reactive energy	03/04		0188	4	0.1 varh	1144	2	varh
+kvarh Σ -C • System imported leading reactive energy	03/04		018C	4	0.1 varh	1146	2	varh
-kvarh1-C • Phase 1 exported leading reactive energy	03/04		0190	4	0.1 varh	1148	2	varh
-kvarh2-C • Phase 2 exported leading reactive energy	03/04		0194	4	0.1 varh	114A	2	varh
-kvarh3-C • Phase 3 exported leading reactive energy	03/04		0198	4	0.1 varh	114C	2	varh
-kvarh Σ -C • System exported leading reactive energy	03/04		019C	4	0.1 varh	114E	2	varh

Parameter	F. code (Hex)	Sign	INTEGER			IEEE		
			Register (Hex)	Words	M.U.	Register (Hex)	Words	M.U.

TARIFF 1 COUNTER VALUES

+kWh1 • Phase 1 imported active energy	03/04		0200	4	0.1 Wh	1200	2	Wh
+kWh2 • Phase 2 imported active energy	03/04		0204	4	0.1 Wh	1202	2	Wh
+kWh3 • Phase 3 imported active energy	03/04		0208	4	0.1 Wh	1204	2	Wh
+kWh Σ • System imported active energy	03/04		020C	4	0.1 Wh	1206	2	Wh
-kWh1 • Phase 1 exported active energy	03/04		0210	4	0.1 Wh	1208	2	Wh
-kWh2 • Phase 2 exported active energy	03/04		0214	4	0.1 Wh	120A	2	Wh
-kWh3 • Phase 3 exported active energy	03/04		0218	4	0.1 Wh	120C	2	Wh
-kWh Σ • System exported active energy	03/04		021C	4	0.1 Wh	120E	2	Wh

TARIFF 1 COUNTER VALUES

+kVAh1-L • Phase 1 imported lagging apparent energy	03/04		0220	4	0.1 VAh	1210	2	VAh
+kVAh2-L • Phase 2 imported lagging apparent energy	03/04		0224	4	0.1 VAh	1212	2	VAh
+kVAh3-L • Phase 3 imported lagging apparent energy	03/04		0228	4	0.1 VAh	1214	2	VAh
+kVAh Σ -L • System imported lagging apparent energy	03/04		022C	4	0.1 VAh	1216	2	VAh
-kVAh1-L • Phase 1 exported lagging apparent energy	03/04		0230	4	0.1 VAh	1218	2	VAh
-kVAh2-L • Phase 2 exported lagging apparent energy	03/04		0234	4	0.1 VAh	121A	2	VAh
-kVAh3-L • Phase 3 exported lagging apparent energy	03/04		0238	4	0.1 VAh	121C	2	VAh
-kVAh Σ -L • System exported lagging apparent energy	03/04		023C	4	0.1 VAh	121E	2	VAh
+kVAh1-C • Phase 1 imported leading apparent energy	03/04		0240	4	0.1 VAh	1220	2	VAh
+kVAh2-C • Phase 2 imported leading apparent energy	03/04		0244	4	0.1 VAh	1222	2	VAh
+kVAh3-C • Phase 3 imported leading apparent energy	03/04		0248	4	0.1 VAh	1224	2	VAh
+kVAh Σ -C • System imported leading apparent energy	03/04		024C	4	0.1 VAh	1226	2	VAh
-kVAh1-C • Phase 1 exported leading apparent energy	03/04		0250	4	0.1 VAh	1228	2	VAh
-kVAh2-C • Phase 2 exported leading apparent energy	03/04		0254	4	0.1 VAh	122A	2	VAh
-kVAh3-C • Phase 3 exported leading apparent energy	03/04		0258	4	0.1 VAh	122C	2	VAh
-kVAh Σ -C • System exported leading apparent energy	03/04		025C	4	0.1 VAh	122E	2	VAh
+kvarh1-L • Phase 1 imported lagging reactive energy	03/04		0260	4	0.1 varh	1230	2	varh
+kvarh2-L • Phase 2 imported lagging reactive energy	03/04		0264	4	0.1 varh	1232	2	varh
+kvarh3-L • Phase 3 imported lagging reactive energy	03/04		0268	4	0.1 varh	1234	2	varh
+kvarh Σ -L • System imported lagging reactive energy	03/04		026C	4	0.1 varh	1236	2	varh
-kvarh1-L • Phase 1 exported lagging reactive energy	03/04		0270	4	0.1 varh	1238	2	varh
-kvarh2-L • Phase 2 exported lagging reactive energy	03/04		0274	4	0.1 varh	123A	2	varh
-kvarh3-L • Phase 3 exported lagging reactive energy	03/04		0278	4	0.1 varh	123C	2	varh
-kvarh Σ -L • System exported lagging reactive energy	03/04		027C	4	0.1 varh	123E	2	varh
+kvarh1-C • Phase 1 imported leading reactive energy	03/04		0280	4	0.1 varh	1240	2	varh
+kvarh2-C • Phase 2 imported leading reactive energy	03/04		0284	4	0.1 varh	1242	2	varh
+kvarh3-C • Phase 3 imported leading reactive energy	03/04		0288	4	0.1 varh	1244	2	varh
+kvarh Σ -C • System imported leading reactive energy	03/04		028C	4	0.1 varh	1246	2	varh
-kvarh1-C • Phase 1 exported leading reactive energy	03/04		0290	4	0.1 varh	1248	2	varh
-kvarh2-C • Phase 2 exported leading reactive energy	03/04		0294	4	0.1 varh	124A	2	varh
-kvarh3-C • Phase 3 exported leading reactive energy	03/04		0298	4	0.1 varh	124C	2	varh
-kvarh Σ -C • System exported leading reactive energy	03/04		029C	4	0.1 varh	124E	2	varh

Parameter	F. code (Hex)	Sign	INTEGER			IEEE		
			Register (Hex)	Words	M.U.	Register (Hex)	Words	M.U.

TARIFF 2 COUNTER VALUES

+kWh1 • Phase 1 imported active energy	03/04		0300	4	0.1 Wh	1300	2	Wh
+kWh2 • Phase 2 imported active energy	03/04		0304	4	0.1 Wh	1302	2	Wh
+kWh3 • Phase 3 imported active energy	03/04		0308	4	0.1 Wh	1304	2	Wh
+kWh Σ • System imported active energy	03/04		030C	4	0.1 Wh	1306	2	Wh
-kWh1 • Phase 1 exported active energy	03/04		0310	4	0.1 Wh	1308	2	Wh
-kWh2 • Phase 2 exported active energy	03/04		0314	4	0.1 Wh	130A	2	Wh
-kWh3 • Phase 3 exported active energy	03/04		0318	4	0.1 Wh	130C	2	Wh
-kWh Σ • System exported active energy	03/04		031C	4	0.1 Wh	130E	2	Wh
+kVAh1-L • Phase 1 imported lagging apparent energy	03/04		0320	4	0.1 VAh	1310	2	VAh
+kVAh2-L • Phase 2 imported lagging apparent energy	03/04		0324	4	0.1 VAh	1312	2	VAh
+kVAh3-L • Phase 3 imported lagging apparent energy	03/04		0328	4	0.1 VAh	1314	2	VAh
+kVAh Σ -L • System imported lagging apparent energy	03/04		032C	4	0.1 VAh	1316	2	VAh

TARIFF 2 COUNTER VALUES

-kVAh1-L • Phase 1 exported lagging apparent energy	03/04		0330	4	0.1 VAh	1318	2	VAh
-kVAh2-L • Phase 2 exported lagging apparent energy	03/04		0334	4	0.1 VAh	131A	2	VAh
-kVAh3-L • Phase 3 exported lagging apparent energy	03/04		0338	4	0.1 VAh	131C	2	VAh
-kVAh Σ -L • System exported lagging apparent energy	03/04		033C	4	0.1 VAh	131E	2	VAh
+kVAh1-C • Phase 1 imported leading apparent energy	03/04		0340	4	0.1 VAh	1320	2	VAh
+kVAh2-C • Phase 2 imported leading apparent energy	03/04		0344	4	0.1 VAh	1322	2	VAh
+kVAh3-C • Phase 3 imported leading apparent energy	03/04		0348	4	0.1 VAh	1324	2	VAh
+kVAh Σ -C • System imported leading apparent energy	03/04		034C	4	0.1 VAh	1326	2	VAh
-kVAh1-C • Phase 1 exported leading apparent energy	03/04		0350	4	0.1 VAh	1328	2	VAh
-kVAh2-C • Phase 2 exported leading apparent energy	03/04		0354	4	0.1 VAh	132A	2	VAh
-kVAh3-C • Phase 3 exported leading apparent energy	03/04		0358	4	0.1 VAh	132C	2	VAh
-kVAh Σ -C • System exported leading apparent energy	03/04		035C	4	0.1 VAh	132E	2	VAh
+kvarh1-L • Phase 1 imported lagging reactive energy	03/04		0360	4	0.1 varh	1330	2	varh
+kvarh2-L • Phase 2 imported lagging reactive energy	03/04		0364	4	0.1 varh	1332	2	varh
+kvarh3-L • Phase 3 imported lagging reactive energy	03/04		0368	4	0.1 varh	1334	2	varh
+kvarh Σ -L • System imported lagging reactive energy	03/04		036C	4	0.1 varh	1336	2	varh
-kvarh1-L • Phase 1 exported lagging reactive energy	03/04		0370	4	0.1 varh	1338	2	varh
-kvarh2-L • Phase 2 exported lagging reactive energy	03/04		0374	4	0.1 varh	133A	2	varh
-kvarh3-L • Phase 3 exported lagging reactive energy	03/04		0378	4	0.1 varh	133C	2	varh
-kvarh Σ -L • System exported lagging reactive energy	03/04		037C	4	0.1 varh	133E	2	varh
+kvarh1-C • Phase 1 imported leading reactive energy	03/04		0380	4	0.1 varh	1340	2	varh
+kvarh2-C • Phase 2 imported leading reactive energy	03/04		0384	4	0.1 varh	1342	2	varh
+kvarh3-C • Phase 3 imported leading reactive energy	03/04		0388	4	0.1 varh	1344	2	varh
+kvarh Σ -C • System imported leading reactive energy	03/04		038C	4	0.1 varh	1346	2	varh
-kvarh1-C • Phase 1 exported leading reactive energy	03/04		0390	4	0.1 varh	1348	2	varh
-kvarh2-C • Phase 2 exported leading reactive energy	03/04		0394	4	0.1 varh	134A	2	varh
-kvarh3-C • Phase 3 exported leading reactive energy	03/04		0398	4	0.1 varh	134C	2	varh
-kvarh Σ -C • System exported leading reactive energy	03/04		039C	4	0.1 varh	134E	2	varh

Parameter	F. code (Hex)	Sign	INTEGER			IEEE		
			Register (Hex)	Words	M.U.	Register (Hex)	Words	M.U.

PARTIAL COUNTER VALUES

+kWh Σ • System imported active energy	03/04		0400	4	0.1 Wh	1400	2	Wh
-kWh Σ • System exported active energy	03/04		0404	4	0.1 Wh	1402	2	Wh
+kVAh Σ -L • System imported lagging apparent energy	03/04		0408	4	0.1 VAh	1404	2	VAh
-kVAh Σ -L • System exported lagging apparent energy	03/04		040C	4	0.1 VAh	1406	2	VAh
+kVAh Σ -C • System imported leading apparent energy	03/04		0410	4	0.1 VAh	1408	2	VAh
-kVAh Σ -C • System exported leading apparent energy	03/04		0414	4	0.1 VAh	140A	2	VAh
+kvarh Σ -L • System imported lagging reactive energy	03/04		0418	4	0.1 varh	140C	2	varh
-kvarh Σ -L • System exported lagging reactive energy	03/04		041C	4	0.1 varh	140E	2	varh
+kvarh Σ -C • System imported leading reactive energy	03/04		0420	4	0.1 varh	1410	2	varh
-kvarh Σ -C • System exported leading reactive energy	03/04		0424	4	0.1 varh	1412	2	varh

BALANCE VALUES

kWh Σ • System active energy	03/04	X	0428	4	0.1 Wh	1414	2	Wh
kVAh Σ -L • System lagging apparent energy	03/04	X	042C	4	0.1 VAh	1416	2	VAh
kVAh Σ -C • System leading apparent energy	03/04	X	0430	4	0.1 VAh	1418	2	VAh
kvarh Σ -L • System lagging reactive energy	03/04	X	0434	4	0.1 varh	141A	2	varh
kvarh Σ -C • System leading reactive energy	03/04	X	0438	4	0.1 varh	141C	2	varh

Register description	F. code (Hex)	INTEGER		Data meaning
		Register (Hex)	Words	
COUNTER & COMMUNICATION DATA				
Counter serial number	03/04	0500	6	10 ASCII chars. (\$00÷\$FF) (LSB)
Counter model	03/04	0506	2	\$03=6A 3phases \$08=80A 3phases \$0C=80A 1phase
Counter type	03/04	0508	2	\$02=MID \$09=with wiring selection, MID
Counter firmware release 1	03/04	050A	2	Convert the read Hex value in Decimal value. e.g. \$66=102 → rel. 1.02
Counter hardware version	03/04	050C	2	Convert the read Hex value in Decimal value. e.g. \$64=100 → rev. 1.00
Reserved	03/04	050E	2	
Tariff in use	03/04	0510	2	\$01=tariff 1 \$02=tariff 2
Primary/secondary value	03/04	0512	2	\$00=primary \$01=secondary
Error code	03/04	0514	2	\$00=none \$01=phase sequence error
CT value (only for counter 6A 3phase model)	03/04	0516	2	\$0001÷\$2710
Reserved	03/04	0518	2	
FSA value	03/04	051A	2	\$00=1A \$01=5A \$02=80A
Wiring mode	03/04	051C	2	\$01=3phases, 4 wires, 3 currents \$02=3phases, 3 wires, 2 currents \$03=1phase \$04=3phases, 3 wires, 3 currents
MODBUS address	03/04	051E	2	\$01÷\$F7
MODBUS mode	03/04	0520	2	\$00=7E2 (ASCII) \$01=8N1 (RTU)
Communication speed	03/04	0522	2	\$01=300 bps \$02=600 bps \$03=1200 bps \$04=2400 bps \$05=4800 bps \$06=9600 bps \$07=19200 bps \$08=38400 bps \$09=57600 bps
Reserved	03/04	0524	2	

Register description	F. code (Hex)	INTEGER		Data meaning
		Register (Hex)	Words	
COUNTER & COMMUNICATION DATA				
Partial counters status	03/04	0526	2	Consider only the last word (e.g. \$00000003→\$0003) Convert the read Hex value in Binary. e.g. \$0003=0000000000000011 Each bit corresponds to the status of a partial counter. 0=inactive 1=active 0000000000000011 ← Start to read bit string following the arrow. The first bit corresponds to the status of the first counter in the list: 1) +kWhΣ PAR 2) -kWhΣ PAR 3) +kVAhΣ-L PAR 4) -kVAhΣ-L PAR 5) +kVAhΣ-C PAR 6) -kVAhΣ-C PAR 7) +kvarhΣ-L PAR 8) -kvarhΣ-L PAR 9) +kvarhΣ-C PAR 10) -kvarhΣ-C PAR The last six bits of the string are reserved. In the example, only +kWhΣ PAR and -kWhΣ PAR counters are active.
Module serial number	03 / 04	0528	6	10 ASCII chars. (\$00÷\$FF) (LSB)
Signed value representation	03 / 04	052E	2	\$00=sign bit \$01=2’s complement
Reserved	03 / 04	0530	2	
Module firmware release	03 / 04	0532	2	Convert the read Hex value in Decimal value. e.g. \$66=102 → rel. 1.02
Module hardware version	03 / 04	0534	2	Convert the read Hex value in Decimal value. e.g. \$64=100 → rev. 1.00
Reserved	03 / 04	0536	2	
Register set type	03 / 04	0538	2	01=register set 1
Counter firmware release 2	03 / 04	0600	2	Convert the read Hex value in Decimal value. e.g. \$C8=200 → rel. 2.00

Register description	F. code (Hex)	Register (Hex)	Data meaning
COILS			
Alarm events	01	0000	40 coils Byte 1 - voltage out of range UV3 UV2 UV1 UVΣ OV3 OV2 OV1 OVΣ Byte 2 - line voltage out of range COM RES UV31 UV23 UV12 OV31 OV23 OV12 Byte 3/4 - current out of range RES RES RES RES RES RES UI1 UI3 UI2 UI1 UIΣ OI1 OI3 OI2 OI1 OIΣ Byte 5 - frequency out of range RES RES RES RES RES RES RES F LEGEND UV=undervoltage OV=overvoltage UI=undercurrent OI=overcurrent F=frequency out of range COM=IR communication error RES=reserved bit to 0 NOTE: the voltage, current and frequency threshold values can change according to the counter. Please refer to the table shown below.

PARAMETER THRESHOLDS			
PHASE VOLTAGE not available for 3 wire connection	LINE VOLTAGE not available for 1phase counter	CURRENT	FREQUENCY
UV _{L-N} : 230V -20% OV _{L-N} : 240V +20%	UV _{L-L} : 400V -20% OV _{L-L} : 415V +20%	UI: Start current value (Ist) OI: Full scale value (FS)	F low: 45Hz F high: 65Hz

7.2 WRITING registers (Function code \$10)

Register description	F. code (Hex)	INTEGER		Programmable data
		Register (Hex)	Words	
COUNTER & COMMUNICATION DATA				
MODBUS address	10	051E	2	\$01÷\$F7
MODBUS mode	10	0520	2	\$00=7E2 (ASCII) \$01=8N1 (RTU)
Communication speed	10	0522	2	\$01=300 bps \$02=600 bps \$03=1200 bps \$04=2400 bps \$05=4800 bps \$06=9600 bps \$07=19200 bps \$08=38400 bps \$09=57600 bps
Partial counters status	10	0526	2	Set the MS word always to 0000. The LS word must be structured as follows: Byte 1 - partial counter selection: \$00=+kWh∑ PAR \$01=-kWh∑ PAR \$02=+kVAh∑-L PAR \$03=-kVAh∑-L PAR \$04=+kVAh∑-C PAR \$05=-kVAh∑-C PAR \$06=+kvarh∑-L PAR \$07=-kvarh∑-L PAR \$08=+kvarh∑-C PAR \$09=-kvarh∑-C PAR \$0A=all partial counters Byte 2 - partial counter/s operation: \$01=start \$02=stop \$03=reset e.g. start +kWh∑ PAR counter 00=+kWh∑ PAR 01=start final value to be set: 00000001
Switch to register set 0	10	1010	2	\$00=switch to register set 0



NOTE

\$051E, \$0520, \$0522 writing registers allow to program the communication parameters.

ekinex

EKINEX S.p.A.

Via Novara, 37 • 28010 VAPRIO D'AGOGNA (NO) Italy • Tel. +39 0321.1828980