



3933 US ROUTE 11, CORTLAND, NEW YORK 13045
Phone Number: 1-800-345-3851 Fax Number: 607-758-3648

REPORT OF TEST

RENDERED TO:
Panduit Corporation
10500 167th Street
Orland Park, IL 60467

The products described in this Report were tested and examined by Intertek for compliance to the standards listed below. The products listed below are not part of an Intertek Verification Program. The results are provided to the client as a one time performance test and shall not be utilized to imply compliance to the standard as part of an on-going program.

Reference Intertek Report No.: 100165321CRT-001

Date: September 20, 2010

Test:

Electrical performance testing of a 100 Ω 4-Pair telecommunication cable to the standard requirements of ISO/IEC 11801 for Category 7 cable.

Standard used:

IEC 61156-5 Edition 2.0, Multicore and symmetrical pair/quad cables for digital communications - Part 5: Symmetrical pair/quad cables with transmission characteristics up to 600MHZ - Horizontal floor wiring - Sectional specification, dated February 2009

Section used:

6.2.1, 6.2.2, 6.2.5, 6.2.6, 6.3.1 to 6.3.6, 6.3.10 to 6.3.11

Sample description:

The client supplied 100 meters of a Category 7, 4-Pair, 23 AWG, S/FTP,LSHF-FR, Horizontal Cable, identified as part number PSM7004. The sample was received on July 12, 2010 and was in good condition.

Conclusion:

The 100 Ω , 4-Pair telecommunication cable, as previously described and supplied by the client, was tested in accordance with the standard referred to on page 1, and did comply with the indicated applicable transmission requirements. The testing was performed at Intertek located in Cortland, New York.

Reviewed and approved by:

John Cash
Technician
Global Cabling Products Testing

Antoine Pelletier
Engineer
Global Cabling Products Testing