LIMIT SWITCH, K SERIES, HINGE OPERATING, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, METAL BODY, CONTACTS 1NO+2NC SLOW ACTION. LONG SOLID SHAFT WITH REDUCTION




Doctor between				I Paragraphic
Product designation Product type designati	on.			Hinge operating KMP
General characteristics				KIVIP
General characteristics				
				Aluminium-zinc
Housing Material				alloy
Rod material				Long solid
Contact characteristics				
Type of contact				1NO+2NC Slow action
Thermal current Ith			Α	10
IEC/EN 60947-5-1 des	signation			A300 Q300
Rated insulation voltag			V	440
Rated impulse withstar	nd voltage Uimp		kV	4
Short-circuit protection	with fuse		Class/A	10 gG/SC QUICK FUSE
Switching speed				
		min	m/s	0.5
		max	m/s	1.5
IEC Conventional free			Α	10
Resistance per pole (a	verage value)		mΩ	<10
Operations			a elec	400000
Mechanical life			cycles	100000
B10d			cycles	100000
Mechanical operation Output characteristics			cycles/h	3600
Mechanical life			cycles	100000
Mechanical features			Cycles	100000
				Locking bayonet
Operating head fixing				insert
Operating torque				
			Ncm	15
			ozin	21.2
Tightening torque (Max	<b>(</b> )			
	Switch fixing			
			Nm	2.5
			lbin	22.1
	Contact terminals			
			Nm	0.8
			lbin	7
	Body lid screw fixing			
			Nm	0.8
			lbin	7
Conductor section	1110/16			

AWG/Kcmil



LIMIT SWITCH, K SERIES, HINGE OPERATING, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, METAL BODY, CONTACTS 1NO+2NC SLOW ACTION. LONG SOLID SHAFT WITH REDUCTION

		min		16
		max		14
	IEC			
		min	mm²	1or 2
		max	mm²	2.5
Cable connection				Self-releasing screw terminal
Cable entry				M20 on the bottom
Ambient conditions				
Pollution degree				3
Temperature				
	Operating temperature			
		min	°C	-25
		max	°C	+70
	Storage temperature			
		min	°C	-40
		max	°C	+70
Dimensions				




Wiring diagrams

**ENERGY AND AUTOMATION** 

LIMIT SWITCH, K SERIES, HINGE OPERATING, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, METAL BODY, CONTACTS 1NO+2NC SLOW ACTION. LONG SOLID SHAFT WITH REDUCTION

## Slow action



## Certifications and compliance

Compliar	nce
----------	-----

CSA C22.2 n° 14

EN 50047

IEC/EN 60204-1

IEC/EN 60947-1

IEC/EN 60947-5-1

**UL508** 

Certificates

CCC

cULus

EAC

## ETIM classification

ETIM 8.0

EC000030 - End switch