


Einbauöffnung

Technische Änderungen vorbehalten

| | 16A 3pol. | 16A 4pol. | 16A 5pol. | 32A 3/4pol. | 32A 5pol. |
|-----------------------------|-----------|-----------|-----------|-------------|-----------|
| a | 85 | 85 | 85 | 85 | 85 |
| b | 85 | 85 | 85 | 85 | 85 |
| c | 70 | 70 | 70 | 70 | 70 |
| d | 70 | 70 | 70 | 70 | 70 |
| Øe | 5,5 | 5,5 | 5,5 | 5,5 | 5,5 |
| f | 8 | 8 | 8 | 8 | 8 |
| h | 46 | 46 | 46 | 61 | 61 |
| i | 54 | 58 | 60 | 68 | 69 |
| ØI | 57 | 65 | 70 | 78 | 78 |
| Leiter mm ² min. | 1,5 | 1,5 | 1,5 | 2,5 | 2,5 |
| Leiter mm ² max. | 4 | 4 | 4 | 10 | 10 |

| | | | | | | | | | | | |
|--|--|----------|--|---|--|--|--|------------------|--|-----------------------------|--|
| CAD-Zg. ! Keine manuellen Änderungen ! | | | |  | | Burgweg 22 57399 Kirchhundem Tel.: 02723/771- 132 Fax: 02723/771- 178 E-Mail Mareike.Bankstahl@Bals.com | | Werkstoff | | Oberfläche | |
| | | | | | | Blatt 1 | | Anzahl d. Bl. 1 | | Format A3 | |
| | | | | Datum Name Gez.: 26.03.07 Bank | | Anbausteckdose QC IP55 schräg FI.85x85 | | | | Freim. Toler. Maßstab | |
| | | | | Gepr.: | | | | | | Ers.f.Zg.: gl.Nr.v.20.01.00 | |
| | | | | Norm: | | Zg.-Nummer: 4MB108 | | Ers.d.Zg.: | | | |
| 2 | | 117/06 | | 26.03.07 | | Bank | | Dos Name: 4MB108 | | | |
| Ausgabe | | Änderung | | Datum | | Name | | Auftrags-Nr.: | | Typ-Nummer: | |
| | | | | | | | | Werkzeug-Nr.: | | | |