

Test Verification of Conformity

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced standard and sections at the time the tests were carried out. This verification is part of the full test report(s) and should be read in conjunction with them.


Applicant Name & Address: Panduit Corporation
 6200 175th Street
 Tinley Park IL 60477
 USA

Product Description: Class E_A 4-conductor unshielded channel as illustrated below

Standard(s): *ISO/IEC 11801-1 Information Technology - Generic cabling for customer premises – Part 1: General requirements, First edition dated November 2017* (Section 6.3: Balanced Cabling Transmission Performance, for internal parameters)

Verification Issuing Office Name & Address: Intertek Testing Services NA, Inc.
 3933 US Route 11,
 Cortland, NY 13045

Test Report Number(s): 103490101CRT-001c



Component Id	Manufacturer	Description	Part number
1	Panduit	Equipment Cord	STP6X5M**
2	Panduit	Outlet	CJS6X88TG**
3	Panduit	U/FTP Horizontal Solid Cable	PUFY6X04**
4	Panduit	Field Terminable Plug	ISPS688FA
5	Panduit	Cross Connect	STP6X2M**
6	Panduit	Equipment Cord	STP6X3M**

Signature

Name: Antoine Pelletier
Position: Project Engineer
Date: 30-April-2018

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.