

## BRE Global Ireland

### Notified Body No. 2831

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance

### 2831-CPR-F0858

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### DOFA3000 Intelligent Analogue Addressable Photoelectric Smoke Detector with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of: and produced in the manufacturing plant(s):

**Cooper Securite SAS**  
**Parc Européen d'Entreprises II**  
**Rue Beethoven**  
**BP 10184**  
**63204 Riom Cedex**  
**France**

**SC Cooper Industries Romania SRL**  
**Zona Industrială NV.**  
**Str. III, NR 12**  
**Arad**  
**310510**  
**Romania**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

#### EN 54-7:2018 Smoke detectors - Point smoke detectors EN 54-17:2005 Short Circuit Isolators

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.

This certificate was first issued on 05 November 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 5 November 2020

Date of Issue: 21 October 2022

Issue number 2

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

**BRE Global Ireland**

**Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland

T: +353 (0) 18824344

E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F0858**

**DOFA3000 Intelligent Analogue Addressable Photoelectric Smoke Detector with Short Circuit Isolator**

**Bases:**

NUG30256 Single contact standard analogue addressable mounting base  
NUG30258 Double contact standard analogue addressable mounting base



P Halligan, Certification Manager,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 5 November 2020

Date of issue: 21 October 2022

Issue number: 2

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)