



## Einbauöffnung

Technische Änderungen vorbehalten

	16A 3pol.	16A 4pol.	16A 5pol.	32A 3/4pol.	32A 5pol.
a	85	85	85	85	85
b	85	85	85	85	85
c	70	70	70	70	70
d	70	70	70	70	70
Øe	5,5	5,5	5,5	5,5	5,5
f	8	8	8	8	8
h	43	45	46	53	53
i	53	55	60	69	70
l	57	65	70	78	78
x	88	90	96	102	111
y	85	85	87	94	102
z	96	99	101	122	123
α	20°	20°	20°	20°	20°
Leiter mm <sup>2</sup> min.	1,5	1,5	1,5	2,5	2,5
Leiter mm <sup>2</sup> max.	4	4	4	10	10

CAD-Zg. ! Keine manuellen Änderungen !					Burgweg 22 57399 Kirchhundem Tel.: 02723/771- 132 Fax: 02723/771- 178 E-Mail Mareike.Bankstahl@Bals.com		Werkstoff	Oberfläche	
					Blatt	Anzahl d. Bl.	Format		
				Datum Name		Anbausteckdose QC IP67		Freim. Toler.	
				Gez.: 26.03.07 Bank		schräg		Maßstab	
				Gepr.:		Zg.-Nummer: 4MB114		Ers.f.Zg.: gl.Nr.v.24.01.00	
				Norm:		Ers.d.Zg.:			
				Dos Name: 4MB114		Typ-Nummer:			
				Auftrags-Nr.:		Ers.d.Zg.:			
				Werkzeug-Nr.:					
Ausgabe	Änderung	Datum	Name						