



	16A 3pol.	16A 4pol.	16A 5pol.
a	68	87	87
b	62	71	71
c	47	70	70
d	47	52	52
Øe	5,5	5,5	5,5
f	8	5,5	5,5
h	46	46	46
i	50	54	54
k	-	9,5	9,5
l	56	65	72
m	51	58	64
α	20°	20°	20°
Leiter mm ² min.	1,5	1,5	1,5
Leiter mm ² max.	4	4	4

Technische Änderungen vorbehalten

CAD-Zg. ! Keine manuellen Änderungen !						Burgweg 22 57399 Kirchhundem Tel.: 02723/771- 132 Fax: 02723/771- 178 E-Mail Mareike.Bankstahl@Bals.com		Werkstoff		Oberfläche	
9						Blatt	1	Anzahl d. Bl.	1	Format	A3
8				Datum	21.03.07	Name	Bank	QC-Anbausteckdose 16A3-5pol.		Freim. Toler.	Maßstab
7				Gez.:	21.03.07	Gepr.:					
6				Norm:				Zg.-Nummer: 4MB111 Typ-Nummer:		Ers.f.Zg.: gl.Nr.v.21.03.07 Ers.d.Zg.:	
5				Dos Name:	4MB111						
4				Auftrags-Nr.:				Zg.-Nummer: 4MB111 Typ-Nummer:		Ers.f.Zg.: gl.Nr.v.21.03.07 Ers.d.Zg.:	
3				Werkzeug-Nr.:							
2								Zg.-Nummer: 4MB111 Typ-Nummer:		Ers.f.Zg.: gl.Nr.v.21.03.07 Ers.d.Zg.:	
1	117/06	21.03.07	Bank								
Ausgabe	Änderung	Datum	Name					Zg.-Nummer: 4MB111 Typ-Nummer:		Ers.f.Zg.: gl.Nr.v.21.03.07 Ers.d.Zg.:	