

## BRE Global Ireland

**Notified Body No. 2831**  
BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland  
T: +353 (0) 18824344  
E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

## Certificate of constancy of performance

### 2831-CPR-F2268

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

#### DTVA3000 Intelligent Analogue Addressable Category P Heat Detector with Short Circuit Isolator

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of: and produced in the manufacturing plant(s):

**Cooper Securite SAS**  
Parc Européen d'Entreprises II  
Rue Beethoven , BP 10184  
63204 Riom  
Cedex  
France

**Digital Lighting (Dongguan) Co Ltd**  
No.57 Jian'an Road, Xinmin District  
Chang'an Town  
Dongguan City, Guangdong Province  
523879  
China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

**EN 54-5: 2017 + A1: 2018 Heat detectors – Point heat detectors**  
**EN 54-17: 2005 Short Circuit Isolators**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

### the constancy of performance of the construction product.

This certificate was first issued on 16 October 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2020

Date of Issue: 8 December 2022

Issue number 2

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)

**BRE Global Ireland****Notified Body No. 2831**

BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road  
Glasnevin, Dublin, D11 KXN4  
Ireland

T: +353 (0) 18824344

E: [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)  
[www.breglobalireland.ie](http://www.breglobalireland.ie)

**APPENDIX to Certificate of constancy of performance: 2831-CPR-F2268****DTVA3000 Intelligent Analogue Addressable Category P Heat Detector with Short Circuit Isolator****Heat Classifications:**

Category A1R

Category BS

Category CS

**Bases:**

NUG30256 Single Contact Standard Base

NUG30258 Double Contact Standard Base



P Halligan, Certification Manager,

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2020

Date of issue: 8 December 2022

Issue number: 2

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email [enquiries@breglobalireland.ie](mailto:enquiries@breglobalireland.ie)