

# Test Verification of Conformity

On the basis of the tests undertaken, the sample(s) of the below product have been found to comply with the requirements of the referenced standard and sections at the time the tests were carried out. This verification is part of the full test report(s) and should be read in conjunction with them.


Applicant Name & Address: Panduit Corporation  
6200 175<sup>th</sup> Street  
Tinley Park IL 60477  
USA

Product Description: Category 6A (Class E<sub>A</sub>) 4-connector shielded channel as illustrated below

Standard: ISO/IEC 11801-1 Information Technology – Generic cabling for customer premises, Part 1: General requirements, First edition dated November 2017 (Section 6.3: Balanced Cabling Transmission Performance, for internal parameters)

Verification Issuing Office Name & Address: Intertek Testing Services NA, Inc.  
3933 US Route 11,  
Cortland, NY 13045

Test Report Number(s): 103862642CRT-001b



Component Id	Manufacturer	Description	Part number
1	Panduit	Patch Cord	STP6C5M**
2	Panduit	Outlet	KJS6X88TC**
3	Panduit	Horizontal Solid Cable	PSW7004**
4	Panduit	Field Terminable Plug	FPS6X88MTG
5	Panduit	Patch Cord	STP6C2M**
6	Panduit	Patch Cord	STP6C3M**

*Antoine Pelletier*

**Signature**

**Name: Antoine Pelletier**  
**Position: Project Engineer**  
**Date: 6-March-2019**

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.