

**FXMQ-MB**

TC: Total capacity;kW – SHC: Sensible capacity;kW

| Unit Size | Nominal capacity | Outdoor air temp. | Indoor air temperature |        |        |        |        |        |        |        |        |        |        |        |        |      |
|-----------|------------------|-------------------|------------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|------|
|           |                  |                   | 14.0WB                 |        | 16.0WB |        | 18.0WB |        | 19.0WB |        | 20.0WB |        | 22.0WB |        | 24.0WB |      |
|           |                  | 20.0DB            |                        | 23.0DB |        | 26.0DB |        | 27.0DB |        | 28.0DB |        | 30.0DB |        | 32.0DB |        |      |
|           |                  | °CDB              | TC                     | SHC    | TC     | SHC    | TC     | SHC    | TC     | SHC    | TC     | SHC    | TC     | SHC    | TC     | SHC  |
| 200       | 22.4             | 35.0              | 15.1                   | 13.4   | 18.0   | 14.9   | 21.0   | 16.3   | 22.4   | 16.8   | 23.6   | 17.0   | 24.2   | 16.1   | 24.6   | 15.4 |
| 250       | 28.0             | 35.0              | 18.9                   | 16.9   | 22.5   | 18.5   | 26.2   | 20.4   | 28.0   | 20.9   | 29.5   | 21.1   | 30.2   | 20.2   | 30.8   | 19.4 |