



LIMIT SWITCH, K SERIES, CERAMIC ROD LEVER, 2 SIDE CABLE ENTRY. DIMENSIONS COMPATIBLE TO EN 50047, METAL BODY, CONTACTS 1NO+1NC SLOW ACTION MAKE BEFORE BREAK. CERAMIC ROD



Product designation	Ceramic rod lever
Product type designation	KNH


$\sim$	
(-anara	characteristics
Ochela	Gialacicionos

Material				
		Housing		Aluminium-zinc
		· ·		alloy
		Rod		Ceramic
Contact characteristic	CS			4110 4110 01
Type of contact				1NO+1NC Slow action make before break
Thermal current Ith			Α	10
IEC/EN 60947-5-1 de	esignation			A300 Q300
Rated insulation volta	ige Ui		V	440
Rated impulse withsta	and voltage Uimp		kV	4
Short-circuit protection	on with fuse		Class/A	10 gG/SC QUICK FUSE
Switching speed				
		min	m/s	0.5
		max	m/s	1.5
IEC Conventional free	e air thermal current Ith		Α	10
Resistance per pole (	(average value)		mΩ	<10
Mechanical features				
Operating head fixing	J			Locking bayone insert
Operating torque				
			Ncm	3
			ozin	4.25
Tightening torque (Ma	ax)			
	Switch fixing			
			Nm	2.5
			lbin	22.1
	Contact terminals			
			Nm	0.8
			lbin	7
	Body lid screw fixing			
			Nm	0.8
			lbin	7
Conductor section				
	AWG/Kcmil			
		min		16
		max		14
	IEC			
		min	mm²	1or 2
		max	mm²	2.5



LIMIT SWITCH, K SERIES, CERAMIC ROD LEVER, 2 SIDE CABLE ENTRY. DIMENSIONS COMPATIBLE TO EN 50047, METAL BODY, CONTACTS 1NO+1NC SLOW ACTION MAKE BEFORE BREAK. CERAMIC ROD

Cable connection			Self-releasing screw terminal
Cable entry			M20 on the sides
Operations			
Mechanical life		cycles	<10000000
Mechanical operation		cycles/h	3600
Ambient conditions			
Temperature			
Operating temperature			
	min	°C	-25
	max	°C	+70
Storage temperature			
	min	°C	-40
	max	°C	+70
Resistance & Protection			
IP degree			
	Terminals		IP20
	Body housing		IP65
Pollution degree		•	3
Dimensions			




Wiring diagrams



LIMIT SWITCH, K SERIES, CERAMIC ROD LEVER, 2 SIDE CABLE ENTRY. DIMENSIONS COMPATIBLE TO EN 50047, METAL BODY, CONTACTS 1NO+1NC SLOW ACTION MAKE BEFORE BREAK. CERAMIC ROD

## Slow action



## 1NO + 1NC make before break

Certifications and cor	mpliance
Compliance	
	CSA C22.2 n° 14
	EN 50047
	IEC/EN 60204-1
	IEC/EN 60947-1
	IEC/EN 60947-5-1
	UL508
Certificates	
	CCC
	cULus
	EAC
ETIM elegation	

ETIM classification

ETIM 8.0 EC000030 - End switch