



LIMIT SWITCH, K SERIES, ADJUSTABLE ROLLER LEVER, 2 SIDE CABLE ENTRY. DIMENSIONS COMPATIBLE TO EN 50047, METAL BODY, CONTACTS 1NO+1NC SLOW ACTION MAKE BEFORE BREAK. PLASTIC PLUNGER




Product designation	Adjustable roller
Froduct designation	lever
Product type designation	KNF

General	_ ch	aracı	PILO	tics:
Contola	011	iaiaoi		1100

Material		
Material		Aluminium-zinc
	Housing	alloy
	Roller	Plastic
Contact characteristics		
		1NO+1NC Slow
Type of contact		action make
		before break
Thermal current Ith	A	10
IEC/EN 60947-5-1 designation		A300 Q300
Rated insulation voltage Ui	V	440
Rated impulse withstand voltage Uimp	kV	4
Insulation class		II
Short-circuit protection with fuse	Class/A	10 gG/SC QUICK FUSE
Switching speed		
	min m/s	0.5
	max m/s	1.5
IEC Conventional free air thermal current Ith	A	10
Resistance per pole (average value)	mΩ	<10
Mechanical features		
Operating head fixing		Locking bayonet insert
Operating torque		
	Ncm	3
	ozin	4.25
Tightening torque (Max)		
Switch fixing		
	Nm	2.5
	lbin	22.1
Contact terminals		
	Nm	0.8
	lbin	7
Body lid screw fixing		
	Nm	0.8
	lbin	7
Conductor section		
Conductor section AWG/Kcmil		
	min	16
AWG/Kcmil	min max	16 14

LIMIT SWITCH, K SERIES, ADJUSTABLE ROLLER LEVER, 2 SIDE CABLE ENTRY. DIMENSIONS COMPATIBLE TO EN 50047, METAL BODY, CONTACTS 1NO+1NC SLOW ACTION MAKE BEFORE BREAK. PLASTIC PLUNGER

	max	mm²	2.5
Cable connection			Self-releasing
			screw terminal
Cable entry			M20 on the sides
Operations			
Mechanical life		cycles	<10000000
Mechanical operation		cycles/h	3600
Ambient conditions			
Temperature			
Operating temperature			
	min	°C	-25
	max	°C	+70
Storage temperature			
	min	°C	-40
	max	°C	+70
Resistance & Protection			
IP degree			
	Terminals		IP20
	Body housing		IP65
Pollution degree			3
Dimensions			




Wiring diagrams



LIMIT SWITCH, K SERIES, ADJUSTABLE ROLLER LEVER, 2 SIDE CABLE ENTRY.
DIMENSIONS COMPATIBLE TO EN 50047, METAL BODY, CONTACTS 1NO+1NC SLOW
ACTION MAKE BEFORE BREAK. PLASTIC PLUNGER

Slow action



1NO + 1NC make before break

Certifications and com	npliance
Compliance	
	CSA C22.2 n° 14
	EN 50047
	IEC/EN 60204-1
	IEC/EN 60947-1
	IEC/EN 60947-5-1
	UL508
Certificates	
	CCC
	cULus
	EAC
ETIM alassitisation	

ETIM classification

ETIM 8.0 EC000030 - End switch