


**Project:** Gripple Hangers  
**Client:** Gripple Ltd  
**Client's Order No:** 3061  
**Inspection Date:**  
**First:** 25/03/2009

**Certificate No:** COV 0919097  
**Office:** Sheffield  
**Date:** 20/02/2009  
**Order Status:** Complete  
**Final:** 25/03/2009

This certificate is issued to Gripple Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

### TEST CONFIGURATION



M Cobb  
 Surveyor of Lloyd's Register




Gripple Model	Rope Construction	Gripple Rated Load	Gripple Load Limit 5:1	Result		
				Tested Load	Passing Load	Breaking Load
No 1 Y-Fit Accessory Snap-Hook	7 x 7 (6/1)	0-10 kg 0-22 lbs	50 kg 100 lbs	245.8 kg 540.7 lbs	232.8 kg 512.2 lbs	236.7 kg 520.7 lbs

**Project:** GripplE Hangers  
**Client:** GripplE Ltd  
**Client's Order No:** 8624  
**Inspection Date:**  
**First:** 19/12/2007



**Certificate No:** COV 0719796  
**Office:** Sheffield  
**Date:** 19/01/2008  
**Order Status:** Complete  
**Final:** 21/01/2008

This certificate is issued to GripplE Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

### TEST CONFIGURATION



M Cobb  
 Surveyor of Lloyd's Register

  
  
 26/1/08


GripplE Model	Rope Construction	GripplE Rated Load	GripplE Load Limit 5:1	Result		
No.2 Y-Fit Accessory Snap Hook	7x7 (6/1)	10 – 45 kg 22 – 100 lbs	225kg 500 lbs	670.3 kg 1474.7 lbs	671.1 kg 1486.4 lbs	683.2 kg 1503.0 lbs

**Project:** Gripple Hangers  
**Client:** Gripple Ltd  
**Client's Order No:** 3061  
**Inspection Date:**  
**First:** 25/03/2009


**Certificate No:** COV 0919097  
**Office:** Sheffield  
**Date:** 20/02/2009  
**Order Status:** Complete  
**Final:** 25/03/2009

This certificate is issued to Gripple Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

**TEST CONFIGURATION**



M Cobb  
 Surveyor of Lloyd's Register



Gripple Model	Rope Construction	Gripple Rated Load	Gripple Load Limit 5:1	Result		
3mm Y-fit Accessory Snap-hook	7 x 7 (6/ 1)	45-90 Kg 100-200 lbs	450 Kg 990 lbs	888.0 Kg 1953.7 lbs	883.7 Kg 1944.1 lbs	841.7 Kg 1851.8 lbs