

UKCA DECLARATION OF CONFORMITY No. 22.3189.06.22

We Hager Electro SAS
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)

Designation

MCCB H1000 ELE

Type reference(s)

HEE970H_HEE970U_HEE971H_HEE971U_HNE970H
HNE970U_HNE971H_HNE971U_HNE700U

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
 - SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
 - SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
-
-

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN 60947-2:2017-10+A1:2020-02

BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS - BP3 - 67215 OBERNAI CEDEX - FRANCE

Name of signatory

Mr Eric Boivin

Function of signatory

Certification Manager

Place and date of issue

Obernai, 22th June 2022

Signature



UKCA DECLARATION OF CONFORMITY

No. 22.3189.06.22

Type references

Type reference	Description
HEE970H	MCCB H1000 3 poles 1000 A Icu/Ics= 70/50 kA LSI
HEE970U	MCCB H1000 3 poles 1000 A Icu/Ics= 70/50 kA LSI
HEE971H	MCCB H1000 4 poles 1000 A Icu/Ics= 70/50 kA LSI
HEE971U	MCCB H1000 4 poles 1000 A Icu/Ics= 70/50 kA LSI
HNE970H	MCCB H1000 3 poles 1000 A Icu/Ics= 50/50 kA LSI
HNE970U	MCCB H1000 3 poles 1000 A Icu/Ics= 50/50 kA LSI
HNE971H	MCCB H1000 4 poles 1000 A Icu/Ics= 50/50 kA LSI
HNE971U	MCCB H1000 4 poles 1000 A Icu/Ics= 50/50 kA LSI
HNE700U	MCCB H800/1000 3 poles 700 A Icu/Ics= 50/50 kA LSI

UKCA DECLARATION OF CONFORMITY

No. 22.3189.06.22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Evidences approved by: Site:	Engineering Quality / Certification Obernai
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used:	Yes
Scope and classification fully covers the product (case 1 of Hager Group risk analysis):	Yes
Comments :	
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document DMS034433 - Hager Group risk analysis)	Risk analysis 22.1875.06.22
Certificate(s) / test report(s):	CB Test Certificate No. NL-65146 TR-2243599.66 EU DofC No. KRC 5917-1c Supplier Compliance Certificat KRC15235
Mark approval(s):	No marks
Product documentation :	See on Hager website
Comments:	BS EN Standard requirements are identical to EN Standard