



3933 US ROUTE 11, CORTLAND, NEW YORK 13045
 Phone Number: 1-800-345-3851 Fax Number: 607-758-3648

REPORT OF TEST


Panduit Corporation
 10500 167th Street
 Orland Park, IL 60467

The products described in this Report were tested for compliance to the standard(s) listed below. The products listed below are not part of an Intertek Verification Program and the results are provided to the client as a one time performance test.

Reference Intertek Report No.: 102062030CRT-001c

Date: March 26, 2015

Test:
 Electrical performance testing of a 4-connector channel configuration, as illustrated below, to the standard requirements of ISO/IEC 11801 for Class E_A channel



Component Id	Manufacturer	Description	Part number
1	Panduit	Equipment Cord	UTP6ASDL5M
2	Panduit	Face Plate / Wall Outlet	CFPF12IW-2G / CJ6X88TG
3	Panduit	Zone Cord	UXJLWH5MBL
4	Panduit	Horizontal Solid Cable	PUL6ASD04WH
5	Panduit	Patch Panel / Outlet	UICMPP24BLY / CJ6X88TG
6	Panduit	Cross Connect	UTP6ASDL2M
7	Panduit	Equipment Cord	UTP6ASDL3M


Standard and sections used:

ISO/IEC 11801 Information Technology - Generic cabling for customer premises, Second edition dated September 2002 including amendments up to Amendment 2, dated April 2010 (Sections 6.4.2 to 6.4.8, 6.4.12 to 6.4.14.3 and 6.4.15)

Conclusion:

The channel cabling configuration, as described above, was tested in accordance with the ISO/IEC 11801 standard, and did comply with the indicated applicable transmission requirements. The channel was assembled by Intertek from samples that were submitted by the client. The testing was performed at Intertek located in Cortland, New York.

Reviewed and approved by:


 John Cash
 Associate Engineer
 Global Cabling Products Testing


 Antoine Pelletier
 Project Engineer
 Global Cabling Products Testing

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.