Housing, Controlled stop pushbuttons/emergency-stop buttons, Mushroom-shaped, 38 mm, Non-illuminated, Pull-to-release function, 1 NC, 1 N/O, Cage Clamp, Red, Yellow



Part no. M22-PV/CKC11/IY 187799

Product name	Eaton Moeller® series M22 Housing
Part no.	M22-PV/CKC11/IY
EAN	4015081854837
Product Length/Depth	100 millimetre
Product height	80 millimetre
Product width	72 millimetre
Product weight	0.192 kilogram
Certifications	CSA-C22.2 No. 14-05 UL File No.: E29184 CE CSA-C22.2 No. 94-91 UL VDE 0660 CSA IEC/EN 60947 UL 508 UL Category Control No.: NKCR IEC/EN 60947-5 CSA File No.: 012528 CSA Class No.: 3211-03
Product Tradename	M22
Product Type	Housing
Product Sub Type	None
Catalog Notes	Cage Clamp is a registered trademark of Wago Kontakttechnik GmbH/Minden, Germany Contacts with safety function, by positive opening to IEC/EN 60947-5-1 Tamper-proof according to ISO 13850/EN 418
Design	Mushroom-shaped
Enclosure color	Yellow
Enclosure material	Plastic
Illumination	Non-illuminated
Degree of protection	IP Other NEMA 4X, 13
Lifespan	100,000 mechanical Operations
Operating frequency	600 Operations/h
Product category	RMQ-Titan
Size	Front dimensions: 35 mm
Suitable for	Emergency stop
Туре	Controlled stop pushbutton/emergency-stop button Housing
Mounting position	As required
Shock resistance	50 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms Mechanical, According to IEC/EN 60068-2-27
Ambient operating temperature - min	-25 °C
	70 °C
Ambient operating temperature - max	
Ambient operating temperature - max Climatic proofing	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78

Rated cantrol supply veltage (Usi at DC - min Rated cantrol supply v	Rated control supply voltage (Us) at AC, 60 Hz - min	115 V
Rated contral supply veltage III/ol at III C max Rated conditional short-circuit carrent (III) Research conditional short-circuit carrent (III) Connection to Based/Wire DT Reduction to Connection (III) Reduction (III) Reduction to Connection (III) Reduction (III) Reduction (III) Reduction to Connection (III) Reduction (III)	111	
Rated continued supply voltage (Uk) at DC - max Rated conditional shart circuit current (II) Carnetction to Smart/Niso DT Red Actuated function Red Actuated function Publi-orcoloase Carnet disease Actuated function Publi-orcoloase Carnet function in Carnet (II) Red Carnet function in Carnet (II) Red Carnet provide and actuation function (III) Routed or Countable (Invariance) Carnet provide and actuation function (III) Routed or Countable (Invariance) Publi-orcoloase (Invariance) Carnet provide countable (Invariance) Carnet provide countable (Invariance) Carnet (III) Carn		
Rand conditional shart circuit current ligi Connection to SmartWire-OT Red Actuating force Actuating force	11.1	
Connection to SmartWire-OT Connection Connection to SmartWire-OT Connection Connection to SmartWire-OT Connection Conne		
Connection to SmartWire OT Connection to SmartWi	Rated conditional short-circuit current (Ig)	1 kA
Careaction type Actuating force Actuating claim Actuat	.,,	
Actuator color Actuator function Actuator functi	Connection to SmartWire-DT	No
Actuator color Actuator favineter Actuator A	Connection type	Cage Clamp
Actuator color Actuator favineter Actuator A		
Actuator diameter Actuator function Actuator function Actuator function Actuator fure of an actuation force (DIN EN 6947-5-1) Actuator fure of an actuation force (DIN EN 6947-5-1) Actuator fure of an actuation force (DIN EN 6947-5-1) Actuator fure of an actuation force (DIN EN 6947-5-1) Actuator fure of an actuation force (DIN EN 6947-5-1) Actuator function Actuator fun	Actuating force	50 N
Actuator function Actuator favel and actuation force (DIN EN 86947-5-1) Actuator favel and actuator (change-oper contacts) Number of contacts (change-oper contacts) Neats (product standard's requirements. Neats the product st	Actuator color	Red
Actuator traval and actuation force DIN EN 80947-5-1) Knob traval Force for positive opening - min Number of contacts (change-over contacts) Number of contacts (change-over contacts) Number of contacts (change-over contacts) Number of contacts (normally closed contacts) Number of contacts (normally closed contacts) Paginipment heat dissipation, current-dependent Pvid Read dissipation capacity Pdiss Pully Read dissipation capacity Pdiss Number of contacts (normally closed contacts) Number of contacts (normally closed (normally closed (normally closed) Number of contacts (normally closed (normally closed) Number of contacts (normally closed) Neats the product standard's requirements. Number of contacts (normally closed) Neats the product standard's requirements (normally closed) Number of contacts (normally closed) Number of contacts (normally closed) Neats the product standard's requirements (normally closed) Number of products of a contact (normally closed) Number of contacts (no	Actuator diameter	38 mm
Knob travel Force for positive opening - min Number of contacts (change-over contacts) Number of contacts (change-over contacts) Number of contacts (normally closed contacts) Number of contacts (normally closed contacts) Number of contacts (normally closed contacts) Fullyment heat dissipation, current-dependent Pvid OW Heat dissipation, current-dependent Pvid OW Heat dissipation capacity Pdiss OW Heat dissipation (arrent for specified heat dissipation (in) Static head dissipation, one-current-dependent Pvid OU Static head dissipation, one-current-dependent Pvid OU 10.22 Cornsion resistance OW 10.23 Verification of thermal stability of enclosures OU 10.23.3 Weish, or insul, mate to abnormal head/fire by internal elect. effects OU 10.23.4 Resistance to ultre-violet (UV) radiation 10.25.4 Hing Obes not apply, since the entire switchgear needs to be evaluated. Ouch sont apply, since the entire switchgear needs to be evaluated. Ouch sont apply, since the entire switchgear needs to be evaluated. Ouch sont apply, since the entire switchgear needs to be evaluated. Ouch sont apply, since the entire switchgear needs to be evaluated. Ouch canances and creepage distances Ouch sont apply, since the entire switchgear needs to be evaluated. Ouch canances and creepage distances Ouch sont apply, since the entire switchgear needs to be evaluated. Ouch canances and creepage distances Ouch sont apply, since the entire switchgear needs to be evaluated. Ouch canances and creepage distances Ouch and apply, since the entire switchgear needs to be evaluated. Ouch canances and creepage distances Ouch sont apply, since the entire switchgear needs to be evaluated. Ouch canances and creepage distances Ouch and apply, since the entire switchgear needs to be evaluated. Ouch canances and creepage distances Ouch and apply, since the entire switchgear needs to be evaluated. Ouch canances and creepage distances Ouch and apply, since the entire switchgear needs to be evaluated. Ouch and apply, since	Actuator function	Pull-to-release
Force for positive opening - min Number of contacts (change-over contacts) Number of contacts (change-over contacts) Number of contacts (normally closed contacts) Number of contacts (normal closed contacts) Number of contacts (normal closed contacts) Number of contacts (normal closed contacts) Number	Actuator travel and actuation force (DIN EN 60947-5-1)	4.8 mm
Number of contacts (change-over contacts) Number of contacts (normally closed contacts) Number of contacts (normally closed contacts) Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation capacity Pdiss Heat dissipation capacity Pdiss Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (III) Rated apprational current for specified heat dissipation (III) Rated apprational current dependent Pvid 10.22 Corrosion resistance 10.23.1 Verification of Themal stability of enclosures 10.23.2 Verification of tremal stability of enclosures 10.23.3 Resist, of insul, mat. to abnormal heat/fire by internal elect. effects 10.23.3 Resist, of insul, mat. to abnormal heat/fire by internal elect. effects 10.24.6 Resistance to ultra-violat (IVI) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Incriptions 10.28 Mechanical impact 10.29 Topic product standard's requirements. 10.20 Does not apply, since the entire switchgear needs to be evaluated. 10.27 Incriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incriptions and connections 10.7 Internal electrical circuits and connections 10.8 Incriptions for external conductors 10.9 January and the external conductors 10.9 January and the external conductors 10.1 Internal electrical circuits and connections 10.2 Internal electrical stream of enclustric strength 10.3 Internal electrical stream of enclustric strength 10.4 Internal electrical circuits and connections 10.5 Internal electrical stream of enclustric strength 10.	Knob travel	5.7 mm
Number of contacts (change-over contacts) Number of contacts (normally closed contacts) Number of contacts (normally closed contacts) Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Heat dissipation capacity Pdiss Heat dissipation capacity Pdiss Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (III) Rated apprational current for specified heat dissipation (III) Rated apprational current dependent Pvid 10.22 Corrosion resistance 10.23.1 Verification of Themal stability of enclosures 10.23.2 Verification of tremal stability of enclosures 10.23.3 Resist, of insul, mat. to abnormal heat/fire by internal elect. effects 10.23.3 Resist, of insul, mat. to abnormal heat/fire by internal elect. effects 10.24.6 Resistance to ultra-violat (IVI) radiation 10.25 Lifting 10.26 Mechanical impact 10.27 Incriptions 10.28 Mechanical impact 10.29 Topic product standard's requirements. 10.20 Does not apply, since the entire switchgear needs to be evaluated. 10.27 Incriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incriptions and connections 10.7 Internal electrical circuits and connections 10.8 Incriptions for external conductors 10.9 January and the external conductors 10.9 January and the external conductors 10.1 Internal electrical circuits and connections 10.2 Internal electrical stream of enclustric strength 10.3 Internal electrical stream of enclustric strength 10.4 Internal electrical circuits and connections 10.5 Internal electrical stream of enclustric strength 10.		
Number of contacts (normally closed contacts) Number of contacts (normally open contacts) Requirement heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Neat dissipation capacity Pdiss Neat dissipation per pole, current-dependent Pvid Neat dissipation per pole, current-dependent Pvid Neat dissipation non-current-dependent Pvid Neat dissipation non-current-dependent Pvis Neat classipation of resistance Neats the product standard's requirements. Neats the product standard's responsibility. Neats the product standard's responsibility. Neats the product standard's responsibility. Neats the product s	Force for positive opening - min	20 N
Number of contacts (normally open contacts) Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Rated operational current for specified heat dissipation (In) Rated operational current for specified heat dissipation (In) Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvis 10.22.3.1 Verification of thermal stability of enclosures 10.23.2.2 Verification of thermal stability of enclosures 10.23.2 Verification of resistance or insulating materials to normal heat 10.23.2 Verification of resistance or insulating materials to normal heat 10.24.2 Resistance to ultra-violet (IV) radiation 10.25.1 Litting 10.26. Meets the product standard's requirements. 10.27.1 Inscriptions 10.28.1 Meets the product standard's requirements. 10.29.2 Mechanical impact 10.29.2 Inscriptions 10.20.2 Inscriptions 10.20.2 Inscriptions 10.20.2 Inscriptions 10.20.2 Inscriptions 10.21.2 Inscriptions 10.22.2 Inscriptions 10.25.3 Insurance and croepage distances 10.26.1 Insurance and croepage distances 10.27.1 Insural electric shock 10.28.1 Insurance and croepage distances 10.29.2 Insurance and croepage distances 10.29.2 Power-frequency electric shock 10.20.2 Insurance and croepage distances 10.20.2 Power-frequency electric strength 10.3 Insurance and croepage of insurance and components 10.4 Clearances and croepage of insurance and components 10.5 Fortection against electric shock 10.6 Incorporation of switching devices and components 10.7 Insurance and croepage of insurance and components 10.8 Comporation of switching devices and components 10.9 Insurance and croepage of insurance	Number of contacts (change-over contacts)	0
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss Hoat dissipation capacity Pdiss Hoat dissipation per pole, current-dependent Pvid Hoat dissipation per pole, current-dependent Pvid Hoat dissipation, non-current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures 10.23.2 Verification of treistance of insulating materials to normal heat 10.23.2 Verification of treistance of insulating materials to normal heat 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.23.2 Near the product standard's requirements. 10.23.2 Near the product standard's requirements. 10.23.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.25. Litting 10.26 Mochanical impact 10.27 Inscriptions 10.28 Mochanical impact 10.29 Inscriptions 10.30 agree of protection of assemblies 10.40 Clearances and creepage distances 10.50 Frotection against electric shock 10.60 son on apply, since the entire switchgear needs to be evaluated. 10.61 Internal electrical circuits and connections 10.71 Internal electrical circuits and connections 10.80 son on apply, since the entire switchgear needs to be evaluated. 10.71 Internal electrical circuits and connections 10.72 Internal electrical circuits and connections 10.73 Internal electrical circuits and connections 10.74 Tenternal electrical circuits and connections 10.75 Internal electrical circuits and connections 10.76 Internal electrical circuits and connections 10.77 Internal electrical circuits and connections 10.78 Internal electric strength 10.79	Number of contacts (normally closed contacts)	1
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resistance of insulating materials to normal heat 10.2.3.3 Resistance of insulating materials to normal heat 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Meets the product standard's requirements. 10.2.6 Meets the product standard's requirements. 10.2.7 Inscriptions 10.2.8 Meets the product standard's requirements. 10.2.9 Lifting 10.2.9 Lifting 10.2.9 Lifting 10.2.9 Loos not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.2.7 Inscriptions 10.2.8 Meets the product standard's requirements. 10.2.9 Lifting 10.3.0 Lifting 10.4.1 Lifting 10.4.1 Lifting 10.5.1 L	Number of contacts (normally open contacts)	1
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resistance of insulating materials to normal heat 10.2.3.3 Resistance of insulating materials to normal heat 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Meets the product standard's requirements. 10.2.6 Meets the product standard's requirements. 10.2.7 Inscriptions 10.2.8 Meets the product standard's requirements. 10.2.9 Lifting 10.2.9 Lifting 10.2.9 Lifting 10.2.9 Loos not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.2.7 Inscriptions 10.2.8 Meets the product standard's requirements. 10.2.9 Lifting 10.3.0 Lifting 10.4.1 Lifting 10.4.1 Lifting 10.5.1 L		
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Rated operational current for specified heat dissipation (In) Rated operational current for specified heat dissipation (In) Rated perational current for specified heat dissipation (In) Rated dissipation, non-current-dependent Pvs 10.2.3 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resists of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Mechanical impact 10.2.7 Inscriptions 10.3.0 Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.3.0 Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Internal electrical circuits and connections 10.9 Inte	Equipment heat dissipation, current-dependent Pvid	
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mt. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting		
Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.5 Insul. mat. to abnormal heat/fire by internal elect. effects 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.8 Mechanical impact 10.2.9 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.1 Temperature rise 10.1 Short-circuit rating 10.1 Short-circuit rating 10.2 Lift is the panel builder's responsibility. The specifications for the switchgear must observed. 10.1 Step panel builder's responsibility. The specifications for the switchgear must observed. 10.1 Step panel builder's responsibility. The specifications for the switchgear must observed.		
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist, of insul, mat to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Is the panel builder's responsibility. 10.9.1 Temperature rise 10.1 Temperature rise 10.2 The panel builder's responsibility. The specifications for the switchgear must observed. 10.1 The panel builder's responsibility. The specifications for the switchgear must observed. 10.1 Temperature rise calculation in the instruction observed.		
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.8 Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.15 Mechanical function 10.16 Meets the product standard's requirements. 10.16 Meets the product standard's requirements. 10.17 Internal electrical circuits and connections 10.8 Internal electrical circuits and connections 10.9 Does not apply, since the entire switchgear needs to be evaluated. 10.16 Internal electrical circuits and connections 10.17 Internal electrical circuits and connections 10.18 Internal electrical circuits and connections 10.19 Internal electrical circuits and connections 10.19 Internal electrical circuits and connections 10.10 Internal electrical circuits and connections 10.10 Internal electrical circuits and connections 10.10 Internal electrical circuits and connections 10.11 Internal electrical circuits and connections 10.12 Internal electrical circuits and connections 10.13 Internal electrical circuits and connections 10.15 Internal electrical circuits and connections 10.16 Internal electrical circuits and connections 10.17 Internal electrical circuits and connections 10.18 Internal electrical circuits and co		
10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.7 Inscriptions 10.2.8 Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.2.8 Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.15 Mechanical function 10.16 Meets the product standard's requirements. 10.16 Meets the product standard's requirements. 10.16 Meets the product standard's requirements. 10.17 Internal electrical standard's requirements. 10.18 Meets the product standard's requirements. 10.19 Does not apply, since the entire switchgear needs to be evaluated. 10.19 Does not apply, since the entire switchgear needs to be evaluated. 10.10 Internal electrical circuits and connections 10.11 Internal electrical circuits and connections 10.12 Feeting of enclosures made of insulating material 10.13 Internal electrical circuits and connections 10.15 Internal electrical circuits and connections 10.16 Internal electrical circuits and connections 10.17 Internal electrical circuits and connections 10.18 Internal electrical circuits and connections 10.18 I		
10.2.3.3 Resists of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. 10.6 we not apply, since the entire switchgear needs to be evaluated. 10.6 neorphy since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections 10.8 the panel builder's responsibility. 10.9.1 Protection against electric strength 10.9.2 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Meets the product standard's requirements. 10.15 Meets the entire switchgear needs to be evaluated. 10.16 meets the entire switchgear needs to be evaluated. 10.17 the panel builder's responsibility. 10.18 the panel builder's responsibility. 10.19 the panel builder's responsibility. 10.20 the panel builder's responsibility. 10.30 the panel builder's responsibility. The specifications for the switchgear must to observed. 10.10 the panel builder's responsibility. The specifications for the switchgear must to observed. 10.19 the panel builder's responsibility. 10.19 the panel builder's respo	· ·	· · · · · · · · · · · · · · · · · · ·
10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.9 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.24 Resistance to ultra-violet the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Is the panel builder's responsibility. 10.9.1 Internal electrical circuits and connections 10.8 Legislation of external conductors 10.9 Is the panel builder's responsibility. 10.9 Internal electrical circuits and connections 10.8 Legislation death of the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.15 Mechanical function 10.16 Meets the product standard's requirements to evaluated. 10.16 Meets the product standard's requirements. 10.17 Desperature rise entire switchgear needs to be evaluated. 10.18 Desperation of switchgear needs to be evaluated. 10.19 Meets the product standard's requirements. 10.19 Legislation of switchgear needs to be evaluated. 10.19 Legis	·	
10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Is the panel builder's responsibility. 10.9.1 Internal electrical circuits and voltage 10.9 Is the panel builder's responsibility. 10.9 Internal electrical circuits and connections 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Meets the product standard's requirements, provided the information in the instruction	· ·	
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Instruction of existent and voltage 10.9 In the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		· ·
10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. In the panel builder's responsibility. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. In the panel builder's responsibility. Does not apply, since the entire switchgear needs to be evaluated. In the device meets the requirements, provided the information in the instruction.	•	***
10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. In panel builder's responsibility. In panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. In panel builder's responsibility. The specifications for the switchgear must to observed. In the panel builder's responsibility. The specifications for the switchgear must to observed.	·	
Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. The panel builder is responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction.		
Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.10 Temperature rise ponesibility. The specifications for the switchgear must to observed. 10.13 Mechanical function 10.16 Incorporation of switching devices and components 10.17 Internal electrical circuits and connections 10.18 Is the panel builder's responsibility. 10.19 Is the panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Electromagnetic report in the entire switchgear meeds to be evaluated. 10.15 Power apply, since the entire switchgear needs to be evaluated. 10.16 Incorporation of switchgear needs to be evaluated. 10.17 Internal electrical circuits and connections 10.18 He panel builder's responsibility. 10.19 Incorporation of the entire switchgear needs to be evaluated. 10.19 Incorporation of switchgear needs to be evaluated. 10.10 Temperature rise entire switchgear needs to be evaluated. 10.10 Temperature rise entire switchgear needs to be evaluated. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility. 10.13 Mechanical function 10.14 February of the entire switchgear needs to be evaluated. 10.15 Incorporation of the entire switchgear needs to be evaluated. 10.19 Incorporation of the entire switchgear needs to be evaluated. 10.10 Incorporation of the entire switchgear ne		11.1
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.10 The device meets the requirements, provided the information in the instruction 10.10 The device meets the requirements, provided the information in the instruction 10.11 Short-circuit requirements, provided the information in the instruction		
10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.10 Temperature fixe Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.11 Short-circuit patients of the switchgear must be observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Electromagnetic provided the information in the instruction of the device meets the requirements, provided the information in the instruction of the suitchgear must be observed.	•	****
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Strength builder's responsibility. The specifications for the switchgear must to observed. 10.15 At the panel builder's responsibility. The specifications for the switchgear must to observed. 10.15 At the panel builder's responsibility. The specifications for the switchgear must to observed. 10.15 At the panel builder's responsibility. The specifications for the switchgear must to observed. 10.16 At the panel builder's responsibility. The specifications for the switchgear must to observed. 10.17 At the panel builder's responsibility. The specifications for the switchgear must to observed. 10.19 At the panel builder's responsibility. The specifications for the switchgear must to observed.		
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Strength builder's responsibility. The specifications for the switchgear must to observed. 10.15 At the panel builder's responsibility. The specifications for the switchgear must to observed. 10.15 At the panel builder's responsibility. The specifications for the switchgear must to observed. 10.15 At the panel builder's responsibility. The specifications for the switchgear must to observed. 10.16 At the panel builder's responsibility. The specifications for the switchgear must to observed. 10.17 At the panel builder's responsibility. The specifications for the switchgear must to observed. 10.19 At the panel builder's responsibility. The specifications for the switchgear must to observed.		· · · ·
10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder is responsibility. 10.10 Temperature rise The panel builder is responsibile for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction		
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Testing of enclosures made of insulating material 10.15 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Testing of enclosures made of insulating material 11.15 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 12.15 The device meets the requirements, provided the information in the instruction of the switchgear must be observed.		
10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	•	
observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function observed. The device meets the requirements, provided the information in the instruction		The panel builder is responsible for the temperature rise calculation. Eaton will
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must b observed.
	10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must b observed.
	10.13 Mechanical function	

Technical data ETIM 8.0

Low-voltage industrial components (EG000017) / Control circuit devices combination in enclosure (EC000225)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Command and alarm device combination in housing (ecl@ss10.0.1-27-37-12-16 [AKF034014])

	1
	0
	0
	0
	0
	1
	Yes
V	V 115 - 500
V	V 115 - 500
V	V 24 - 220
	Yellow
	Plastic
	1
	1
	0
	Other
	4X, 13
	,