

UKCA DECLARATION OF CONFORMITY No. 23.3606.04.23

We Hager Electro SAS
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)

Designation

Air Circuit Breaker HW4, HU4

Type reference(s)

HW4, HU4 (see next pages)

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)

- SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)

.....

.....

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN IEC 60947-2: 2017 + A1: 2020
BS EN IEC 63000: 2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS

Name of signatory

Eric Boivin

Function of signatory

Certification Mandatee

Place and date of issue

Obernai, 6th April 2023

Signature



UKCA DECLARATION OF CONFORMITY

No. 23.3606.04.23

Type references

HW4C3EH	Chassis HW4 66kA 3P (CHA)
HW4C3PH	Chassis HW4 120kA 3P (CHA)
HW4C3SH	Chassis HW4 85kA 3P (CHA)
HW4C4EH	Chassis HW4 66kA 4P (CHA)
HW4C4PH	Chassis HW4 120kA 4P (CHA)
HW4C4SH	Chassis HW4 85kA 4P (CHA)
HW4E310DB	ACB HW4 66kA 1000A 3P D/O sentinel TU
HW4E310DE	ACB HW4 66kA 1000A 3P Drawout Energy TU
HW4E310FB	ACB HW4 66kA 1000A 3P Fixed sent. TU
HW4E310FE	ACB HW4 66kA 1000A 3P Fixed Energy TU
HW4E312DB	ACB HW4 66kA 1250A 3P D/O sentinel TU
HW4E312DE	ACB HW4 66kA 1250A 3P Drawout Energy TU
HW4E312FB	ACB HW4 66kA 1250A 3P Fixed sent. TU
HW4E312FE	ACB HW4 66kA 1250A 3P Fixed Energy TU
HW4E316DB	ACB HW4 66kA 1600A 3P D/O sentinel TU
HW4E316DE	ACB HW4 66kA 1600A 3P Drawout Energy TU
HW4E316FB	ACB HW4 66kA 1600A 3P Fixed sent. TU
HW4E316FE	ACB HW4 66kA 1600A 3P Fixed Energy TU
HW4E320DB	ACB HW4 66kA 2000A 3P D/O sentinel TU
HW4E320DE	ACB HW4 66kA 2000A 3P Drawout Energy TU
HW4E320FB	ACB HW4 66kA 2000A 3P Fixed sent. TU
HW4E320FE	ACB HW4 66kA 2000A 3P Fixed Energy TU
HW4E325DB	ACB HW4 66kA 2500A 3P D/O sentinel TU
HW4E325DE	ACB HW4 66kA 2500A 3P Drawout Energy TU
HW4E325FB	ACB HW4 66kA 2500A 3P Fixed sent. TU
HW4E325FE	ACB HW4 66kA 2500A 3P Fixed Energy TU
HW4E332DB	ACB HW4 66kA 3200A 3P D/O sentinel TU
HW4E332DE	ACB HW4 66kA 3200A 3P Drawout Energy TU
HW4E332FB	ACB HW4 66kA 3200A 3P Fixed sent. TU
HW4E332FE	ACB HW4 66kA 3200A 3P Fixed Energy TU
HW4E340DB	ACB HW4 66kA 4000A 3P D/O sentinel TU
HW4E340DE	ACB HW4 66kA 4000A 3P Drawout Energy TU
HW4E340FB	ACB HW4 66kA 4000A 3P Fixed sent. TU
HW4E340FE	ACB HW4 66kA 4000A 3P Fixed Energy TU
HW4E410DB	ACB HW4 66kA 1000A 4P D/O sentinel TU
HW4E410DE	ACB HW4 66kA 1000A 4P Drawout Energy TU
HW4E410FB	ACB HW4 66kA 1000A 4P Fixed sent. TU
HW4E410FE	ACB HW4 66kA 1000A 4P Fixed Energy TU
HW4E412DB	ACB HW4 66kA 1250A 4P D/O sentinel TU
HW4E412DE	ACB HW4 66kA 1250A 4P Drawout Energy TU
HW4E412FB	ACB HW4 66kA 1250A 4P Fixed sent. TU
HW4E412FE	ACB HW4 66kA 1250A 4P Fixed Energy TU
HW4E416DB	ACB HW4 66kA 1600A 4P D/O sentinel TU
HW4E416DE	ACB HW4 66kA 1600A 4P Drawout Energy TU
HW4E416FB	ACB HW4 66kA 1600A 4P Fixed sent. TU
HW4E416FE	ACB HW4 66kA 1600A 4P Fixed Energy TU
HW4E420DB	ACB HW4 66kA 2000A 4P D/O sentinel TU
HW4E420DE	ACB HW4 66kA 2000A 4P Drawout Energy TU
HW4E420FB	ACB HW4 66kA 2000A 4P Fixed sent. TU
HW4E420FE	ACB HW4 66kA 2000A 4P Fixed Energy TU
HW4E425DB	ACB HW4 66kA 2500A 4P D/O sentinel TU
HW4E425DE	ACB HW4 66kA 2500A 4P Drawout Energy TU
HW4E425FB	ACB HW4 66kA 2500A 4P Fixed sent. TU
HW4E425FE	ACB HW4 66kA 2500A 4P Fixed Energy TU

UKCA DECLARATION OF CONFORMITY

No. 23.3606.04.23

Type references

HW4E432DB	ACB HW4 66kA 3200A 4P D/O sentinel TU
HW4E432DE	ACB HW4 66kA 3200A 4P Drawout Energy TU
HW4E432FB	ACB HW4 66kA 3200A 4P Fixed sent. TU
HW4E432FE	ACB HW4 66kA 3200A 4P Fixed Energy TU
HW4E440DB	ACB HW4 66kA 4000A 4P D/O sentinel TU
HW4E440DE	ACB HW4 66kA 4000A 4P Drawout Energy TU
HW4E440FB	ACB HW4 66kA 4000A 4P Fixed sent. TU
HW4E440FE	ACB HW4 66kA 4000A 4P Fixed Energy TU
HW4P310DB	ACB HW4 120kA 1000A 3P D/O sentinel TU
HW4P310DE	ACB HW4 120kA 1000A 3P D/O Energy TU
HW4P310FB	ACB HW4 120kA 1000A 3P Fixed sent. TU
HW4P310FE	ACB HW4 120kA 1000A 3P Fixed Energy TU
HW4P312DB	ACB HW4 120kA 1250A 3P D/O sentinel TU
HW4P312DE	ACB HW4 120kA 1250A 3P D/O Energy TU
HW4P312FB	ACB HW4 120kA 1250A 3P Fixed sent. TU
HW4P312FE	ACB HW4 120kA 1250A 3P Fixed Energy TU
HW4P316DB	ACB HW4 120kA 1600A 3P D/O sentinel TU
HW4P316DE	ACB HW4 120kA 1600A 3P D/O Energy TU
HW4P316FB	ACB HW4 120kA 1600A 3P Fixed sent. TU
HW4P316FE	ACB HW4 120kA 1600A 3P Fixed Energy TU
HW4P320DB	ACB HW4 120kA 2000A 3P D/O sentinel TU
HW4P320DE	ACB HW4 120kA 2000A 3P D/O Energy TU
HW4P320FB	ACB HW4 120kA 2000A 3P Fixed sent. TU
HW4P320FE	ACB HW4 120kA 2000A 3P Fixed Energy TU
HW4P325DB	ACB HW4 120kA 2500A 3P D/O sentinel TU
HW4P325DE	ACB HW4 120kA 2500A 3P D/O Energy TU
HW4P325FB	ACB HW4 120kA 2500A 3P Fixed sent. TU
HW4P325FE	ACB HW4 120kA 2500A 3P Fixed Energy TU
HW4P332DB	ACB HW4 120kA 3200A 3P D/O sentinel TU
HW4P332DE	ACB HW4 120kA 3200A 3P D/O Energy TU
HW4P332FB	ACB HW4 120kA 3200A 3P Fixed sent. TU
HW4P332FE	ACB HW4 120kA 3200A 3P Fixed Energy TU
HW4P340DB	ACB HW4 120kA 4000A 3P D/O sentinel TU
HW4P340DE	ACB HW4 120kA 4000A 3P D/O Energy TU
HW4P340FB	ACB HW4 120kA 4000A 3P Fixed sent. TU
HW4P340FE	ACB HW4 120kA 4000A 3P Fixed Energy TU
HW4P410DB	ACB HW4 120kA 1000A 4P D/O sentinel TU
HW4P410DE	ACB HW4 120kA 1000A 4P D/O Energy TU
HW4P410FB	ACB HW4 120kA 1000A 4P Fixed sent. TU
HW4P410FE	ACB HW4 120kA 1000A 4P Fixed Energy TU
HW4P412DB	ACB HW4 120kA 1250A 4P D/O sentinel TU
HW4P412DE	ACB HW4 120kA 1250A 4P D/O Energy TU
HW4P412FB	ACB HW4 120kA 1250A 4P Fixed sent. TU
HW4P412FE	ACB HW4 120kA 1250A 4P Fixed Energy TU
HW4P416DB	ACB HW4 120kA 1600A 4P D/O sentinel TU
HW4P416DE	ACB HW4 120kA 1600A 4P D/O Energy TU
HW4P416FB	ACB HW4 120kA 1600A 4P Fixed sent. TU
HW4P416FE	ACB HW4 120kA 1600A 4P Fixed Energy TU
HW4P420DB	ACB HW4 120kA 2000A 4P D/O sentinel TU
HW4P420DE	ACB HW4 120kA 2000A 4P D/O Energy TU
HW4P420FB	ACB HW4 120kA 2000A 4P Fixed sent. TU
HW4P420FE	ACB HW4 120kA 2000A 4P Fixed Energy TU
HW4P425DB	ACB HW4 120kA 2500A 4P D/O sentinel TU
HW4P425DE	ACB HW4 120kA 2500A 4P D/O Energy TU
HW4P425FB	ACB HW4 120kA 2500A 4P Fixed sent. TU

UKCA DECLARATION OF CONFORMITY

No. 23.3606.04.23

Type references

HW4P425FE	ACB HW4 120kA 2500A 4P Fixed Energy TU
HW4P432DB	ACB HW4 120kA 3200A 4P D/O sentinel TU
HW4P432DE	ACB HW4 120kA 3200A 4P D/O Energy TU
HW4P432FB	ACB HW4 120kA 3200A 4P Fixed sent. TU
HW4P432FE	ACB HW4 120kA 3200A 4P Fixed Energy TU
HW4P440DB	ACB HW4 120kA 4000A 4P D/O sentinel TU
HW4P440DE	ACB HW4 120kA 4000A 4P D/O Energy TU
HW4P440FB	ACB HW4 120kA 4000A 4P Fixed sent. TU
HW4P440FE	ACB HW4 120kA 4000A 4P Fixed Energy TU
HW4S310DB	ACB HW4 85kA 1000A 3P D/O sentinel TU
HW4S310DE	ACB HW4 85kA 1000A 3P Drawout Energy TU
HW4S310FB	ACB HW4 85kA 1000A 3P Fixed sent. TU
HW4S310FE	ACB HW4 85kA 1000A 3P Fixed Energy TU
HW4S312DB	ACB HW4 85kA 1250A 3P D/O sentinel TU
HW4S312DE	ACB HW4 85kA 1250A 3P Drawout Energy TU
HW4S312FB	ACB HW4 85kA 1250A 3P Fixed sent. TU
HW4S312FE	ACB HW4 85kA 1250A 3P Fixed Energy TU
HW4S316DB	ACB HW4 85kA 1600A 3P D/O sentinel TU
HW4S316DE	ACB HW4 85kA 1600A 3P Drawout Energy TU
HW4S316FB	ACB HW4 85kA 1600A 3P Fixed sent. TU
HW4S316FE	ACB HW4 85kA 1600A 3P Fixed Energy TU
HW4S320DB	ACB HW4 85kA 2000A 3P D/O sentinel TU
HW4S320DE	ACB HW4 85kA 2000A 3P Drawout Energy TU
HW4S320FB	ACB HW4 85kA 2000A 3P Fixed sent. TU
HW4S320FE	ACB HW4 85kA 2000A 3P Fixed Energy TU
HW4S325DB	ACB HW4 85kA 2500A 3P D/O sentinel TU
HW4S325DE	ACB HW4 85kA 2500A 3P Drawout Energy TU
HW4S325FB	ACB HW4 85kA 2500A 3P Fixed sent. TU
HW4S325FE	ACB HW4 85kA 2500A 3P Fixed Energy TU
HW4S332DB	ACB HW4 85kA 3200A 3P D/O sentinel TU
HW4S332DE	ACB HW4 85kA 3200A 3P Drawout Energy TU
HW4S332FB	ACB HW4 85kA 3200A 3P Fixed sent. TU
HW4S332FE	ACB HW4 85kA 3200A 3P Fixed Energy TU
HW4S340DB	ACB HW4 85kA 4000A 3P D/O sentinel TU
HW4S340DE	ACB HW4 85kA 4000A 3P Drawout Energy TU
HW4S340FB	ACB HW4 85kA 4000A 3P Fixed sent. TU
HW4S340FE	ACB HW4 85kA 4000A 3P Fixed Energy TU
HW4S410DB	ACB HW4 85kA 1000A 4P D/O sentinel TU
HW4S410DE	ACB HW4 85kA 1000A 4P Drawout Energy TU
HW4S410FB	ACB HW4 85kA 1000A 4P Fixed sent. TU
HW4S410FE	ACB HW4 85kA 1000A 4P Fixed Energy TU
HW4S412DB	ACB HW4 85kA 1250A 4P D/O sentinel TU
HW4S412DE	ACB HW4 85kA 1250A 4P Drawout Energy TU
HW4S412FB	ACB HW4 85kA 1250A 4P Fixed sent. TU
HW4S412FE	ACB HW4 85kA 1250A 4P Fixed Energy TU
HW4S416DB	ACB HW4 85kA 1600A 4P D/O sentinel TU
HW4S416DE	ACB HW4 85kA 1600A 4P Drawout Energy TU
HW4S416FB	ACB HW4 85kA 1600A 4P Fixed sent. TU
HW4S416FE	ACB HW4 85kA 1600A 4P Fixed Energy TU
HW4S420DB	ACB HW4 85kA 2000A 4P D/O sentinel TU
HW4S420DE	ACB HW4 85kA 2000A 4P Drawout Energy TU
HW4S420FB	ACB HW4 85kA 2000A 4P Fixed sent. TU
HW4S420FE	ACB HW4 85kA 2000A 4P Fixed Energy TU
HW4S425DB	ACB HW4 85kA 2500A 4P D/O sentinel TU
HW4S425DE	ACB HW4 85kA 2500A 4P Drawout Energy TU

UKCA DECLARATION OF CONFORMITY

No. 23.3606.04.23

Type references

HW4S425FB	ACB HW4 85kA 2500A 4P Fixed sent. TU
HW4S425FE	ACB HW4 85kA 2500A 4P Fixed Energy TU
HW4S432DB	ACB HW4 85kA 3200A 4P D/O sentinel TU
HW4S432DE	ACB HW4 85kA 3200A 4P Drawout Energy TU
HW4S432FB	ACB HW4 85kA 3200A 4P Fixed sent. TU
HW4S432FE	ACB HW4 85kA 3200A 4P Fixed Energy TU
HW4S440DB	ACB HW4 85kA 4000A 4P D/O sentinel TU
HW4S440DE	ACB HW4 85kA 4000A 4P Drawout Energy TU
HW4S440FB	ACB HW4 85kA 4000A 4P Fixed sent. TU
HW4S440FE	ACB HW4 85kA 4000A 4P Fixed Energy TU
HU4C3EH	Chassis HU4 66kA 3P (CHA)
HU4C3PH	Chassis HU4 120kA 3P (CHA)
HU4C3SH	Chassis HU4 85kA 3P (CHA)
HU4C4EH	Chassis HU4 66kA 4P (CHA)
HU4C4PH	Chassis HU4 120kA 4P (CHA)
HU4C4SH	Chassis HU4 85kA 4P (CHA)
HU4E310DB	ACB HU4 66kA 1000A 3P D/O sentinel TU
HU4E310DE	ACB HU4 66kA 1000A 3P Drawout Energy TU
HU4E310FB	ACB HU4 66kA 1000A 3P Fixed sent. TU
HU4E310FE	ACB HU4 66kA 1000A 3P Fixed Energy TU
HU4E312DB	ACB HU4 66kA 1250A 3P D/O sentinel TU
HU4E312DE	ACB HU4 66kA 1250A 3P Drawout Energy TU
HU4E312FB	ACB HU4 66kA 1250A 3P Fixed sent. TU
HU4E312FE	ACB HU4 66kA 1250A 3P Fixed Energy TU
HU4E316DB	ACB HU4 66kA 1600A 3P D/O sentinel TU
HU4E316DE	ACB HU4 66kA 1600A 3P Drawout Energy TU
HU4E316FB	ACB HU4 66kA 1600A 3P Fixed sent. TU
HU4E316FE	ACB HU4 66kA 1600A 3P Fixed Energy TU
HU4E320DB	ACB HU4 66kA 2000A 3P D/O sentinel TU
HU4E320DE	ACB HU4 66kA 2000A 3P Drawout Energy TU
HU4E320FB	ACB HU4 66kA 2000A 3P Fixed sent. TU
HU4E320FE	ACB HU4 66kA 2000A 3P Fixed Energy TU
HU4E325DB	ACB HU4 66kA 2500A 3P D/O sentinel TU
HU4E325DE	ACB HU4 66kA 2500A 3P Drawout Energy TU
HU4E325FB	ACB HU4 66kA 2500A 3P Fixed sent. TU
HU4E325FE	ACB HU4 66kA 2500A 3P Fixed Energy TU
HU4E332DB	ACB HU4 66kA 3200A 3P D/O sentinel TU
HU4E332DE	ACB HU4 66kA 3200A 3P Drawout Energy TU
HU4E332FB	ACB HU4 66kA 3200A 3P Fixed sent. TU
HU4E332FE	ACB HU4 66kA 3200A 3P Fixed Energy TU
HU4E340DB	ACB HU4 66kA 4000A 3P D/O sentinel TU
HU4E340DE	ACB HU4 66kA 4000A 3P Drawout Energy TU
HU4E340FB	ACB HU4 66kA 4000A 3P Fixed sent. TU
HU4E340FE	ACB HU4 66kA 4000A 3P Fixed Energy TU
HU4E410DB	ACB HU4 66kA 1000A 4P D/O sentinel TU
HU4E410DE	ACB HU4 66kA 1000A 4P Drawout Energy TU
HU4E410FB	ACB HU4 66kA 1000A 4P Fixed sent. TU
HU4E410FE	ACB HU4 66kA 1000A 4P Fixed Energy TU
HU4E412DB	ACB HU4 66kA 1250A 4P D/O sentinel TU
HU4E412DE	ACB HU4 66kA 1250A 4P Drawout Energy TU
HU4E412FB	ACB HU4 66kA 1250A 4P Fixed sent. TU
HU4E412FE	ACB HU4 66kA 1250A 4P Fixed Energy TU
HU4E416DB	ACB HU4 66kA 1600A 4P D/O sentinel TU
HU4E416DE	ACB HU4 66kA 1600A 4P Drawout Energy TU
HU4E416FB	ACB HU4 66kA 1600A 4P Fixed sent. TU

UKCA DECLARATION OF CONFORMITY

No. 23.3606.04.23

Type references

HU4E416FE	ACB HU4 66kA 1600A 4P Fixed Energy TU
HU4E420DB	ACB HU4 66kA 2000A 4P D/O sentinel TU
HU4E420DE	ACB HU4 66kA 2000A 4P Drawout Energy TU
HU4E420FB	ACB HU4 66kA 2000A 4P Fixed sent. TU
HU4E420FE	ACB HU4 66kA 2000A 4P Fixed Energy TU
HU4E425DB	ACB HU4 66kA 2500A 4P D/O sentinel TU
HU4E425DE	ACB HU4 66kA 2500A 4P Drawout Energy TU
HU4E425FB	ACB HU4 66kA 2500A 4P Fixed sent. TU
HU4E425FE	ACB HU4 66kA 2500A 4P Fixed Energy TU
HU4E432DB	ACB HU4 66kA 3200A 4P D/O sentinel TU
HU4E432DE	ACB HU4 66kA 3200A 4P Drawout Energy TU
HU4E432FB	ACB HU4 66kA 3200A 4P Fixed sent. TU
HU4E432FE	ACB HU4 66kA 3200A 4P Fixed Energy TU
HU4E440DB	ACB HU4 66kA 4000A 4P D/O sentinel TU
HU4E440DE	ACB HU4 66kA 4000A 4P Drawout Energy TU
HU4E440FB	ACB HU4 66kA 4000A 4P Fixed sent. TU
HU4E440FE	ACB HU4 66kA 4000A 4P Fixed Energy TU
HU4P310DB	ACB HU4 120kA 1000A 3P D/O sentinel TU
HU4P310DE	ACB HU4 120kA 1000A 3P D/O Energy TU
HU4P310FB	ACB HU4 120kA 1000A 3P Fixed sent. TU
HU4P310FE	ACB HU4 120kA 1000A 3P Fixed Energy TU
HU4P312DB	ACB HU4 120kA 1250A 3P D/O sentinel TU
HU4P312DE	ACB HU4 120kA 1250A 3P D/O Energy TU
HU4P312FB	ACB HU4 120kA 1250A 3P Fixed sent. TU
HU4P312FE	ACB HU4 120kA 1250A 3P Fixed Energy TU
HU4P316DB	ACB HU4 120kA 1600A 3P D/O sentinel TU
HU4P316DE	ACB HU4 120kA 1600A 3P D/O Energy TU
HU4P316FB	ACB HU4 120kA 1600A 3P Fixed sent. TU
HU4P316FE	ACB HU4 120kA 1600A 3P Fixed Energy TU
HU4P320DB	ACB HU4 120kA 2000A 3P D/O sentinel TU
HU4P320DE	ACB HU4 120kA 2000A 3P D/O Energy TU
HU4P320FB	ACB HU4 120kA 2000A 3P Fixed sent. TU
HU4P320FE	ACB HU4 120kA 2000A 3P Fixed Energy TU
HU4P325DB	ACB HU4 120kA 2500A 3P D/O sentinel TU
HU4P325DE	ACB HU4 120kA 2500A 3P D/O Energy TU
HU4P325FB	ACB HU4 120kA 2500A 3P Fixed sent. TU
HU4P325FE	ACB HU4 120kA 2500A 3P Fixed Energy TU
HU4P332DB	ACB HU4 120kA 3200A 3P D/O sentinel TU
HU4P332DE	ACB HU4 120kA 3200A 3P D/O Energy TU
HU4P332FB	ACB HU4 120kA 3200A 3P Fixed sent. TU
HU4P332FE	ACB HU4 120kA 3200A 3P Fixed Energy TU
HU4P340DB	ACB HU4 120kA 4000A 3P D/O sentinel TU
HU4P340DE	ACB HU4 120kA 4000A 3P D/O Energy TU
HU4P340FB	ACB HU4 120kA 4000A 3P Fixed sent. TU
HU4P340FE	ACB HU4 120kA 4000A 3P Fixed Energy TU
HU4P410DB	ACB HU4 120kA 1000A 4P D/O sentinel TU
HU4P410DE	ACB HU4 120kA 1000A 4P D/O Energy TU
HU4P410FB	ACB HU4 120kA 1000A 4P Fixed sent. TU
HU4P410FE	ACB HU4 120kA 1000A 4P Fixed Energy TU
HU4P412DB	ACB HU4 120kA 1250A 4P D/O sentinel TU
HU4P412DE	ACB HU4 120kA 1250A 4P D/O Energy TU
HU4P412FB	ACB HU4 120kA 1250A 4P Fixed sent. TU
HU4P412FE	ACB HU4 120kA 1250A 4P Fixed Energy TU
HU4P416DB	ACB HU4 120kA 1600A 4P D/O sentinel TU
HU4P416DE	ACB HU4 120kA 1600A 4P D/O Energy TU

UKCA DECLARATION OF CONFORMITY

No. 23.3606.04.23

Type references

HU4P416FB	ACB HU4 120kA 1600A 4P Fixed sent. TU
HU4P416FE	ACB HU4 120kA 1600A 4P Fixed Energy TU
HU4P420DB	ACB HU4 120kA 2000A 4P D/O sentinel TU
HU4P420DE	ACB HU4 120kA 2000A 4P D/O Energy TU
HU4P420FB	ACB HU4 120kA 2000A 4P Fixed sent. TU
HU4P420FE	ACB HU4 120kA 2000A 4P Fixed Energy TU
HU4P425DB	ACB HU4 120kA 2500A 4P D/O sentinel TU
HU4P425DE	ACB HU4 120kA 2500A 4P D/O Energy TU
HU4P425FB	ACB HU4 120kA 2500A 4P Fixed sent. TU
HU4P425FE	ACB HU4 120kA 2500A 4P Fixed Energy TU
HU4P432DB	ACB HU4 120kA 3200A 4P D/O sentinel TU
HU4P432DE	ACB HU4 120kA 3200A 4P D/O Energy TU
HU4P432FB	ACB HU4 120kA 3200A 4P Fixed sent. TU
HU4P432FE	ACB HU4 120kA 3200A 4P Fixed Energy TU
HU4P440DB	ACB HU4 120kA 4000A 4P D/O sentinel TU
HU4P440DE	ACB HU4 120kA 4000A 4P D/O Energy TU
HU4P440FB	ACB HU4 120kA 4000A 4P Fixed sent. TU
HU4P440FE	ACB HU4 120kA 4000A 4P Fixed Energy TU
HU4S310DB	ACB HU4 85kA 1000A 3P D/O sentinel TU
HU4S310DE	ACB HU4 85kA 1000A 3P Drawout Energy TU
HU4S310FB	ACB HU4 85kA 1000A 3P Fixed sent. TU
HU4S310FE	ACB HU4 85kA 1000A 3P Fixed Energy TU
HU4S312DB	ACB HU4 85kA 1250A 3P D/O sentinel TU
HU4S312DE	ACB HU4 85kA 1250A 3P Drawout Energy TU
HU4S312FB	ACB HU4 85kA 1250A 3P Fixed sent. TU
HU4S312FE	ACB HU4 85kA 1250A 3P Fixed Energy TU
HU4S316DB	ACB HU4 85kA 1600A 3P D/O sentinel TU
HU4S316DE	ACB HU4 85kA 1600A 3P Drawout Energy TU
HU4S316FB	ACB HU4 85kA 1600A 3P Fixed sent. TU
HU4S316FE	ACB HU4 85kA 1600A 3P Fixed Energy TU
HU4S320DB	ACB HU4 85kA 2000A 3P D/O sentinel TU
HU4S320DE	ACB HU4 85kA 2000A 3P Drawout Energy TU
HU4S320FB	ACB HU4 85kA 2000A 3P Fixed sent. TU
HU4S320FE	ACB HU4 85kA 2000A 3P Fixed Energy TU
HU4S325DB	ACB HU4 85kA 2500A 3P D/O sentinel TU
HU4S325DE	ACB HU4 85kA 2500A 3P Drawout Energy TU
HU4S325FB	ACB HU4 85kA 2500A 3P Fixed sent. TU
HU4S325FE	ACB HU4 85kA 2500A 3P Fixed Energy TU
HU4S332DB	ACB HU4 85kA 3200A 3P D/O sentinel TU
HU4S332DE	ACB HU4 85kA 3200A 3P Drawout Energy TU
HU4S332FB	ACB HU4 85kA 3200A 3P Fixed sent. TU
HU4S332FE	ACB HU4 85kA 3200A 3P Fixed Energy TU
HU4S340DB	ACB HU4 85kA 4000A 3P D/O sentinel TU
HU4S340DE	ACB HU4 85kA 4000A 3P Drawout Energy TU
HU4S340FB	ACB HU4 85kA 4000A 3P Fixed sent. TU
HU4S340FE	ACB HU4 85kA 4000A 3P Fixed Energy TU
HU4S410DB	ACB HU4 85kA 1000A 4P D/O sentinel TU
HU4S410DE	ACB HU4 85kA 1000A 4P Drawout Energy TU
HU4S410FB	ACB HU4 85kA 1000A 4P Fixed sent. TU
HU4S410FE	ACB HU4 85kA 1000A 4P Fixed Energy TU
HU4S412DB	ACB HU4 85kA 1250A 4P D/O sentinel TU
HU4S412DE	ACB HU4 85kA 1250A 4P Drawout Energy TU
HU4S412FB	ACB HU4 85kA 1250A 4P Fixed sent. TU
HU4S412FE	ACB HU4 85kA 1250A 4P Fixed Energy TU
HU4S416DB	ACB HU4 85kA 1600A 4P D/O sentinel TU

UKCA DECLARATION OF CONFORMITY

No. 23.3606.04.23

Type references

HU4S416DE	ACB HU4 85kA 1600A 4P Drawout Energy TU
HU4S416FB	ACB HU4 85kA 1600A 4P Fixed sent. TU
HU4S416FE	ACB HU4 85kA 1600A 4P Fixed Energy TU
HU4S420DB	ACB HU4 85kA 2000A 4P D/O sentinel TU
HU4S420DE	ACB HU4 85kA 2000A 4P Drawout Energy TU
HU4S420FB	ACB HU4 85kA 2000A 4P Fixed sent. TU
HU4S420FE	ACB HU4 85kA 2000A 4P Fixed Energy TU
HU4S425DB	ACB HU4 85kA 2500A 4P D/O sentinel TU
HU4S425DE	ACB HU4 85kA 2500A 4P Drawout Energy TU
HU4S425FB	ACB HU4 85kA 2500A 4P Fixed sent. TU
HU4S425FE	ACB HU4 85kA 2500A 4P Fixed Energy TU
HU4S432DB	ACB HU4 85kA 3200A 4P D/O sentinel TU
HU4S432DE	ACB HU4 85kA 3200A 4P Drawout Energy TU
HU4S432FB	ACB HU4 85kA 3200A 4P Fixed sent. TU
HU4S432FE	ACB HU4 85kA 3200A 4P Fixed Energy TU
HU4S440DB	ACB HU4 85kA 4000A 4P D/O sentinel TU
HU4S440DE	ACB HU4 85kA 4000A 4P Drawout Energy TU
HU4S440FB	ACB HU4 85kA 4000A 4P Fixed sent. TU
HU4S440FE	ACB HU4 85kA 4000A 4P Fixed Energy TU

UKCA DECLARATION OF CONFORMITY

No. 23.3606.04.23

Evidence(s)

Documents listed below have been developed to assure that all essential requirements of applied directive(s) are fulfilled:

If the product is not in the scope of Radio Equipment directive, fulfil table 1a, if yes fulfil table.

Table 1a Risk Assessment for Equipment without Radio		Applicable: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used:	No		
Scope and classification fully covers the product (case 1 of Hager Group risk analysis) :	Yes		
Comments :			
Hager Group risk analysis: Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document <u>DMS034433</u> - Hager Group risk analysis)	Risk Analysis ACB HW4		

Table 1b Risk Assessment for Radio equipment		Applicable: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Hager Group risk assessment: Fill document DMS063155			

Evidence(s) / Evidence(s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant directives

Certificate(s) / test report(s):	CB test certificate No. NL-86703 Test report No. 3326192.50
Mark approval(s):	No approval marks
Product documentation :	See Hager website
Comments:	None

Signature (technical design)

Name of signatory

Francis Diebold

Function of signatory

Engineering Director / Manager

Place and date of issue

Obernai, 6th April 2023

Signature

