

UKCA DECLARATION OF CONFORMITY No.

We **Hager Industrial de Envolvertes S.A.**  
**Alfred Nobel 18**  
**08430 LA ROCA DEL VALLES - SPAIN**

Declare that the product(s)

Designation

**Vector Dinrail Enclosure**  
**Surface Mounting**

Type reference(s)

**VE Range**

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
  - SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
  - SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
- .....
- .....

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

**BS EN 61439-1:2011**  
**BS EN 61439-3:2012**  
**BS EN IEC 63000:2018**

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

**This declaration of conformity is issued under the sole responsibility of the manufacturer.**

**On behalf of Hager Industrial de Envolvertes S.A.**

Name of signatory

Ian Ellis

Function of signatory

Certification Manager

Place and date of issue

Telford, UK 04/05/2022

Signature

*Ian Ellis*

## UKCA DECLARATION OF CONFORMITY

No. 22\_3408\_05\_22

### Type references

#### Vector Enclosures

Product Reference	Product Description
VE103D	Enclosure,vector, IP65,3 modules
VE106D	Enclosure,vector, IP65,6 modules
VE110D	Enclosure,vector, IP65,10 modules
VE103L	Enclosure,vector, IP5X, 3 modules
VE106L	Enclosure,vector, IP5X, 6 modules
VE110L	Enclosure,vector, IP5X, 10 modules
VE112L	Enclosure,vector, IP5X,12 modules
VE118L	Enclosure,vector, IP5X, 18 modules
VE212L	Enclosure,vector, JP5X, 24 modules
VE218L	Enclosure, vector, IP5X, 36 modules
VE312L	Enclosure, vector, IP5X, 36 modules
VE318L	Enclosure, vector, IP5X, 54 modules
VE412L	Enclosure, vector, IP5X, 48 modules
VE106R	Enclosure,vector, IP55, 6 modules
VE112R	Enclosure,vector, IP55,12 modules
VE118R	Enclosure,vector, IP65,18 modules
VE212R	Enclosure,vectorII, IP55, 24 modules
VE218R	Enclosure,vector, IP65,36 modules
VE312R	Enclosure,vector, IP55, 36 modules
VE103U	Enclosure,vector, IP65, 3 modules
VE106U	Enclosure,vector, IP5X, 6 modules
VE110U	Enclosure, vector, IP5X, 10 modules
VE112U	Enclosure,vector, IP5X,12 modules
VE118U	Enclosure,vector, IP55, 18 modules
VE212U	Enclosure,vector, IP5X, 24 modules
VE218U	Enclosure,vector, IP55, 2x18 modules
VE312U	Enclosure, vector, JP 5X modules
VE318U	Enclosure,vector, IP55, 3x18 modules
VE412U	Enclosure,vector ,IP55, 48 modules

#### Terminal Support Assembly

Product Reference	Product Description
VZ403	Single Phase Connector Assembly for Vector II Enclosures (Requires VZ744)
VZ428	Three Phase Connector Assembly for Vector II Enclosures (Requires VZ744)
VZ744	Mounting Support for VZ403 & VZ428 (1 Set = 2 Supports)
VZ311	For All Vector Enclosures with 2 Keys

## UKCA DECLARATION OF CONFORMITY

No. 22\_3408\_05\_22

### Evidence (s)

*Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation*

Evidences approved by: Site:	Engineering Quality / Certification Telford
Only designated standards published on GOV.UK ( <a href="https://www.gov.uk/guidance/designated-standards">https://www.gov.uk/guidance/designated-standards</a> ) are used:  Scope and classification fully covers the product (case 1 of Hager Group risk analysis):  Comments :	Yes BS EN 61439-1 BS EN 61439-3  Yes
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document <u>DMS034433</u> - Hager Group risk analysis)	DMS034433 followed using case 1 of Hager Group method:  Designated standard used
Certificate(s) / test report(s):	UK Test Report G2122-1 Vector Range DE1-59293/239632-CC3-1 Test Summery-239632-CC3-2 ROHS Test Report VE10* - 2022-03-17 ROHS Test Report VE11* - 2022-03-17 ROHS Test Report VE2* - 2022-03-17 ROHS Test Report VE3* - 2022-03-17 ROHS Test Report VE4* - 2022-03-17
Mark approval(s):	VDE
Product documentation :	6VU00700G 6V001300C 6LE004022B 6LE004021B 6LE003107F 6LE001216D 6LE000051D
Comments:	BS EN Standard requirements are identical to EN standards

## UKCA DECLARATION OF CONFORMITY

No. 22\_3408\_05\_22

### Evidence (s)

*Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation*

#### Designated Standards

Designated standard UKCA Electrical Equipment (Safety) Regulations 2016:

S.I. 2016 No. 1101	EN 61439-1:2011	Low-voltage switchgear and controlgear assemblies – Part 1: General rules	01/01/2021	0009/21
S.I. 2016 No. 1101	EN 61439-3:2012	Low-voltage switchgear and controlgear assemblies - Part 3: Distribution boards intended to be operated by ordinary persons (DBO)	01/01/2021	0009/21

Designated standard UKCA Electromagnetic Compatibility Regulations 2016:

S.I. 2016 No. 1091	EN 61439-1:2011	Low-voltage switchgear and controlgear assemblies – Part 1: General rules	01/01/2021	0007/21
S.I. 2016 No. 1091	EN 61439-3:2012	Low-voltage switchgear and controlgear assemblies - Part 3: Distribution boards intended to be operated by ordinary persons (DBO)	01/01/2021	0007/21

Designated standard UKCA RoHS:

S.I. 2012 No. 3033	EN IEC 63000:2018	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances	01/01/2021	0037/21
-----------------------	-------------------	--	------------	---------