



## LIMIT SWITCH, K SERIES, TOP ROLLER PUSH PLUNGER, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, METAL BODY, CONTACTS 1NO+1NC SLOW ACTION MAKE BEFORE BREAK. METAL ROLLER




Product designation	Top roller push plunger
Product type designation	KMB

Material				
Material				Aluminium-zinc
		Housing		alloy
		Roller		Metal
Contact characteristic	S			
				1NO+1NC Slow
Type of contact				action make
Thermal current Ith			Λ	before break 10
IEC/EN 60947-5-1 de	ecianation		A	A300 Q300
Rated insulation voltage	-		V	440
Rated impulse withsta			kV	4
•	•			10 gG/SC
Short-circuit protection	n with fuse		Class/A	QUICK FUSE
Switching speed				
		min	m/s	0.5
		max	m/s	1.5
IEC Conventional free	air thermal current Ith		Α	10
Resistance per pole (	average value)		mΩ	<10
Mechanical features				
Operating head fixing				Locking bayonet insert
Operating torque				
			Ν	5
			lb	1.1
Tightening torque (Ma				
	Switch fixing			
			Nm	2.5
			lbin	22.1
	Contact terminals		Nima	0.0
			Nm	0.8
	Body lid screw fixing		lbin	7
	Body lid screw lixing		Nm	0.8
			lbin	7
Conductor section				·
	AWG/Kcmil			
		min		16
		max		14
	IEC			
		min	mm²	1or 2
		max	mm²	2.5



LIMIT SWITCH, K SERIES, TOP ROLLER PUSH PLUNGER, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, METAL BODY, CONTACTS 1NO+1NC SLOW ACTION MAKE BEFORE BREAK. METAL ROLLER

Cable connection			Self-releasing
Cable Confidention			screw terminal
Cable entry			M20 on the sides
Operations			
Mechanical life		cycles	<10000000
Mechanical operation		cycles/h	3600
Ambient conditions			
Temperature			
Operating te	mperature		
	min	°C	-25
	max	°C	+70
Storage tem	perature		
	min	°C	-40
	max	°C	+70
Resistance & Protection			
IP degree			
	Terminals		IP20
	Body housing		IP65
Pollution degree			3
Dimensions			




Wiring diagrams



LIMIT SWITCH, K SERIES, TOP ROLLER PUSH PLUNGER, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, METAL BODY, CONTACTS 1NO+1NC SLOW ACTION MAKE BEFORE BREAK. METAL ROLLER

## Slow action



## 1NO + 1NC make before break

Certifications and com	npliance
Compliance	
	CSA C22.2 n° 14
	EN 50047
	IEC/EN 60204-1
	IEC/EN 60947-1
	IEC/EN 60947-5-1
	UL508
Certificates	
	CCC
	cULus
	EAC
ETIM elegation	

ETIM classification

ETIM 8.0 EC000030 - End switch