

We **Hager Electro SAS**
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)

Designation

Fuse Carrier & Accessories

Type reference(s)

LS, LR, LB, MZ Range

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
 - SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
 - SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)
-
-

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN IEC 60947-3 :2021

BS HD 60269-2:2010

BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS

Name of signatory

Eric Boivin

Function of signatory

FDS Certification Manager

Place and date of issue

Obernai, FR 21/03/2022

Signature



UKCA DECLARATION OF CONFORMITY

No. 22_3327_02_22

Type references

Références	Type	Description
LS703	L58	Coupe-circuit 3P 125A 690V L58 accessoriable 6M
LB026	Kit d'assemblage	Kit d'assemblage (pour 1 association)
LS701	L58	Coupe-circuit 1P 125A 690V L58 accessoriable 2M
LS704	L58	Coupe-circuit 3P+N 125A 690V L58 accessoriable 8M
LR702	L58	Coupe-circuit 2P 125A 690V L58 4M
LS504	C/C L58	Coupe-circuit 3P+N 32A 690V L38 4M
LS770	Microrupteur	Microrupteur 1P pour coupe-circuit L58
LS401	C/C L31	Coupe-circuit 1P 25A 500V L31 1M
LS404	C/C L31	Coupe-circuit 3P+N 25A 500V L31 4M
LR701	L58	Coupe-circuit 1P 125A 690V L58 2M
LR601	L51	Coupe-circuit 1P 50A 690V L51 1.5M
LB115	C/C BS	Coupe-circuit 1P15A 240V BS1361 1M avec cartouche
LR603	L51	Coupe-circuit 3P 50A 690V L51 4.5M
LS604	L51	Coupe-circuit 3P+N 50A 690V L51 6M accessoriable
LS702	L58	Coupe-circuit 2P 125A 690V L58 4M accessoriable
LS512	C/C L38	Coupe-circuit 1P+N 32A 690V L38 2M
LR704	L58	Coupe-circuit 3P+N 125A 690V L58 8M
LS503	C/C Unipolaire	Coupe-circuit 3P 32A 690V L38 3M
LR604	L51	Coupe-circuit 3P+N 50A 690V L51 6M
LS502	C/C Unipolaire	Coupe-circuit 2P 32A 690V L38 2M
LR703	L58	Coupe-circuit 3P 125A 690V L58 6M
LS402	C/C L31	Coupe-circuit 2P 25A 500V L31 2M
LS601	L51	Coupe-circuit 1P 50A 690V L51 1.5M accessoriable
LS603	L51	Coupe-circuit 3P 50A 690V L51 4.5M accessoriable
LR602	L51	Coupe-circuit 2P 50A 690V L51 3M
LS531	C/C L38 voyant	Coupe-circuit 1P 32A 690V L38 1M avec voyant
LS5011	C/C Unipolaire	Coupe-circuit 1P 32A 690V L38 1M
LS509	C/C L38	Coupe-circuit 1N 32A 690V L38 1M
LS672	Voyant	Voyant 230V p. coupe-circuit L51/L58
LB113	C/C BS	Coupe-circuit 1P 5A 240V BS1361 1M avec cartouche
LS670	Microrupteur	Microrupteur 1P pour coupe-circuit L51
LS403	C/C L31	Coupe-circuit 3P 25A 500V L31 3M
LS201	C/C BS	Coupe-circuit 1P 32A 415V BS88 1M
LS712	L58	Coupe-circuit 1P+N 125A 690V L58 4M accessoriable
LB116	C/C BS	Coupe-circuit 1P 20A 240V BS1361 1M avec cartouche
LS7711	Microrupteur	Microrupteur 3P pour coupe-circuit L58
LS612	L51	Coupe-circuit 1P+N 50A 690V L51 3M accessoriable
LB118	C/C BS	Coupe-circuit 1P 30A 240V BS1361 1M avec cartouche
LS431	C/C L31 voyant	Coupe-circuit 1P 25A 500V L31 1M avec voyant
LS6711	Microrupteur	Microrupteur 3P pour coupe-circuit L51
LS602	L51	Coupe-circuit 2P 50A 690V L51 3M accessoriable
LR612	L51	Coupe-circuit 1P+N 50A 690V L51 3M
LS412	C/C L31	Coupe-circuit 1P+N 25A 500V L31 2M
LR712	L58	Coupe-circuit 1P+N 125A 690V L58 4M

UKCA DECLARATION OF CONFORMITY

No. 22_3327_02_22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Evidences approved by: Site:	Engineering Quality / Certification Telford
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used: Scope and classification fully covers the product (case 1 of Hager Group risk analysis): Comments :	Yes BS EN 60947-3 BS HD 60269-2 Yes Designated Before 2016
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document <u>DMS034433</u> - Hager Group risk analysis)	DMS034433 followed using case 1 of Hager Group method: Designated Standard Used
Certificate(s) / test report(s):	According to Suppliers Information
Mark approval(s):	No
Product documentation :	See Hager Website
Comments:	BS EN Standard requirements are identical to EN Standard

UKCA DECLARATION OF CONFORMITY

No. 22_3327_02_22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Designated Standards

Designated standard UKCA Electrical Equipment (Safety) Regulations 2016:

S.I. 2016 No. 1101	EN 60947-3:2009	Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units	01/01/2021	0009/21
S.I. 2016 No. 1101	HD 60269-2:2013	Low-voltage fuses - Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) - Examples of standardized systems of fuses A to K	01/01/2021	0009/21

Designated standard UKCA Electromagnetic Compatibility Regulations 2016:

S.I. 2016 No. 1091	EN 60947-3:2009	Low-voltage switchgear and controlgear - Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units	01/01/2021	0007/21
-----------------------	-----------------	---	------------	---------

Designated standard UKCA RoHS:

S.I. 2012 No. 3033	EN IEC 63000:2018	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances	01/01/2021	0037/21
-----------------------	-------------------	--	------------	---------