

BRE Global Limited

Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX
Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk

EC-CERTIFICATE OF CONFORMITY

0832 - CPD - 1892

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

VESDA Laser Industrial (VLI) Aspirating Smoke Detector for use in fire detection and alarm systems

(For conditions of use for the product see the attached appendix)

placed on the market by

Xtralis Pty Limited

**4 North Drive, Virginia Park, 236-262 East Boundary Road, East Bentleigh, Victoria 3165,
Australia**

and produced in the factory

CC0144

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan. The initial type-testing for the relevant characteristics of the product, the initial inspection and continuous surveillance of the factory and factory production control has been performed under the control of the approved body BRE Global Limited.

This certificate attests that all provisions concerning the attestation of conformity (Level 1) and the performances described in Annex ZA of the standard(s)

EN 54 - 20: 2006 - Aspirating smoke detectors

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on 01/08/2012 and remains valid as long as the product continues to be manufactured and the conditions laid down in the harmonised technical specification referenced or the manufacturing conditions in the factory or the FPC itself are not modified significantly and the required annual FPC assessments are maintained.



Eman Mattie-Suleiman
Certification Manager
For and on behalf of BRE Global Limited

Date of Issue: 01/08/2012

Issue Number: 1

Page: 1 of 2

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.

To check the authenticity of this certificate, please visit our website or contact us.

BRE Global Limited

Bucknalls Lane, Garston, Watford, Hertfordshire, United Kingdom WD25 9XX

Telephone: +44(0)1923 664100 Fax: +44(0)1923 664603 E-mail: enquiries@breglobal.co.uk Web: www.breglobal.co.uk

Appendix to EC Certificate of conformity 0832 - CPD - 1892

The details and conditions of use for the VESDA Laser Industrial (VLI) Aspirating Smoke Detector, placed on the market by Xtralis Pty Limited are:

To be used in accordance with the suppliers installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (*where applicable*):

Variants:

VLI-880 VESDA Laser Industrial

VLI-88000-NF VESDA Laser Industrial (intended for French market)

VLI-885 VESDA Laser Industrial with VESDAnet card

VLI-88500-NF VESDA Laser Industrial with VESDAnet card (intended for French market)

Notes:

1. For compliance with clause 5.10 of EN 54-20 the detector shall be supplied with power from a power supply conforming to the requirements of EN 54-4.
2. The device is approved for sensitivity Classes A, B and C. The Class of any pipe/hole configuration and detector sensitivity must be determined using ASPIRE2.
3. System design, installation and commissioning shall be performed in accordance with the VESDA VLI product guide (18500).
4. Remote display, programmer and relay modules are also approved in a 19 sub rack.
5. The detector is also approved when used with in-line filter models, E700-FILASSY and VSP-850 in accordance with the appropriate VESDA application guide (10856 or 17785).
6. VLI-88000-NF and VLI-88500-NF are the alternative model numbers intended for French market.
7. When installing pipework systems containing in-line components, guidance from the 18336 "Xtralis Open-flow In-Line Components" document shall be sought and the recommendations followed.



Eman Mattie-Suleiman
Certification Manager
For and on behalf of BRE Global Limited

Date of Issue: 01/08/2012
Issue Number: 1
Page: 2 of 2

This certificate remains the property of BRE Global Limited and is issued subject to terms and conditions and is maintained and held in force through regular Factory Production Control audits.
To check the authenticity of this certificate, please visit our website or contact us.