

# LIMIT SWITCH, K SERIES, TOP PUSH ROD PLUNGER, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, METAL BODY, CONTACTS 1NO+2NC SLOW ACTION. METAL PLUNGER



Product designation	Top push rod plunger
Product type designation	KMA


#### General characteristics

Material				
		Housing		Aluminium-zinc
				alloy Aluminium-zinc
		Rod		alloy
Contact characteristics				,
Type of contact				1NO+2NC Slow action
Thermal current Ith			Α	10
IEC/EN 60947-5-1 design				A300 Q300
Rated insulation voltage			V	440
Rated impulse withstand	l voltage Uimp		kV	4
Insulation class				II
Short-circuit protection w	vith fuse		Class/A	10 gG/SC QUICK FUSE
Switching speed			,	
		min	m/s	0.5
IEC Conventional free ai	r thormal aurrent lth	max	m/s	1.5
Resistance per pole (ave			A mΩ	<10
Mechanical features	erage value)		11152	<10
Operating head fixing				Locking bayonet insert
Operating torque				
			N	5
			lb	1.1
Tightening torque (Max)				
	Switch fixing			
			Nm	2.5
			lbin	22.1
	Contact terminals			
			Nm	0.8
	D 1 " 1 " 1 " 1 " 1 " 1 " 1 " 1 " 1 " 1		lbin	7
	Body lid screw fixing		Nima	0.0
			Nm Ibin	0.8 7
Conductor section			IDITI	
	AWG/Kcmil			
	, (VV 5, (XOITIII	min		16
		max		14
•	IEC	. nex		<del>-</del>
		min	mm²	1or 2



## LIMIT SWITCH, K SERIES, TOP PUSH ROD PLUNGER, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, METAL BODY, CONTACTS 1NO+2NC SLOW ACTION. METAL PLUNGER

	max	mm²	2.5
Cable connection			Self-releasing
			screw terminal
Cable entry			M20 on the
- Cable Gilly			bottom
Operations			
Mechanical life		cycles	<10000000
Mechanical operation		cycles/h	3600
Ambient conditions			
Temperature			
Operating temp	rature		
	min	°C	-25
	max	°C	+70
Storage temper	ture		
	min	°C	-40
	max	°C	+70
Resistance & Protection			
IP degree			
-	Terminals		IP20
	Body housing		IP65
Pollution degree			3
Dimensions			




Wiring diagrams



LIMIT SWITCH, K SERIES, TOP PUSH ROD PLUNGER, 1 BOTTOM CABLE ENTRY. DIMENSIONS TO EN 50047, METAL BODY, CONTACTS 1NO+2NC SLOW ACTION. METAL PLUNGER

### Slow action



## Certifications and compliance

Compli	ance

CSA C22.2 n° 14

EN 50047

IEC/EN 60204-1

IEC/EN 60947-1

IEC/EN 60947-5-1

**UL508** 

Certificates

CCC

cULus

EAC

### ETIM classification

**ETIM 8.0** 

EC000030 - End switch