

Enabling and Using OPC UA on the Anybus X-Gateway IIoT

APPLICATION NOTE

SCM-1202-118 EN 1.0 ENGLISH



Important User Information

Liability

Every care has been taken in the preparation of this document. Please inform HMS Industrial Networks AB of any inaccuracies or omissions. The data and illustrations found in this document are not binding. We, HMS Industrial Networks AB, reserve the right to modify our products in line with our policy of continuous product development. The information in this document is subject to change without notice and should not be considered as a commitment by HMS Industrial Networks AB. HMS Industrial Networks AB assumes no responsibility for any errors that may appear in this document.

There are many applications of this product. Those responsible for the use of this device must ensure that all the necessary steps have been taken to verify that the applications meet all performance and safety requirements including any applicable laws, regulations, codes, and standards.

HMS Industrial Networks AB will under no circumstances assume liability or responsibility for any problems that may arise as a result from the use of undocumented features, timing, or functional side effects found outside the documented scope of this product. The effects caused by any direct or indirect use of such aspects of the product are undefined, and may include e.g. compatibility issues and stability issues.

The examples and illustrations in this document are included solely for illustrative purposes. Because of the many variables and requirements associated with any particular implementation, HMS Industrial Networks AB cannot assume responsibility for actual use based on these examples and illustrations.

Intellectual Property Rights

HMS Industrial Networks AB has intellectual property rights relating to technology embodied in the product described in this document. These intellectual property rights may include patents and pending patent applications in the USA and other countries.

1 Preface

This document describes how to setup and configure an Anybus X-gateway device to enable OPC UA and how to connect and use the desktop client UaExpert.

More documentation and downloads can be found at <u>www.anybus.com/support</u>. For more info regarding OPC UA and UaExpert, please visit the manufacturer's support website.

1.1 Document History

Version	Date	Description
1.0	2018-11-29	First release

1.2 Document Conventions

Ordered lists are used for instructions that must be carried out in sequence:

- 1. First do this
- 2. Then do this

Unordered (bulleted) lists are used for:

- Itemized information
- Instructions that can be carried out in any order

...and for action-result type instructions:

- This action...
 - leads to this result

Bold typeface indicates interactive parts such as connectors and switches on the hardware, or menus and buttons in a graphical user interface.

Monospaced text is used to indicate program code and other kinds of data input/output such as configuration scripts.

This is a cross-reference within this document: Document Conventions, p. 3

This is an external link (URL): www.hms-networks.com

(i)

This is additional information which may facilitate installation and/or operation.

This instruction must be followed to avoid a risk of reduced functionality and/or damage to the equipment, or to avoid a network security risk.

Caution

This instruction must be followed to avoid a risk of personal injury.



WARNING

This instruction must be followed to avoid a risk of death or serious injury.

2 Setup and Configuration

2.1 Prerequisites

- Download and install UaExpert from Unified Automation: <u>www.unified-automation.com/</u> products/development-tools/uaexpert.html
- Download and install an OPC UA Discovery server on a PC that the Anybus X-gateway can access to get time synchronized.
 - Local discovery server from OPC Foundation: <u>opcfoundation.org/developer-tools/</u> <u>developer-kits-unified-architecture/local-discovery-server-lds/</u>. This server installs as a service on a Windows PC and needs no configuration. It is, however, required to get a correct timestamp.
- An Anybus X-gateway IIoT device supporting OPC UA, configured according to the startup guide.

2.2 Configuration

When opening the local web page of the IIoT interface, an OPC UA configuration section shall be present. It is possible to specify what port the OPC UA server of the X-gateway listens to and the URL to the Discovery server to be accessed to get time synchronized.

Configure the Discovery Server URL to point to the PC where the Discovery Server is installed. The format of the URL must be: opc.tcp://<ipaddressorhostname>:<port>. The port is optional. If it is absent, the default port 4840 will be used.

MODULE	IP Configuration		
Overview	DHCP	Enabled 💌	
Parameters	IP Address	10.10.55.151	
NETWORK	Subnet Mask	255.255.254.0	
Status	Gateway Address	10.10.55.254	
Configuration	Host Name		
SERVICES	Domain name		
SMTD	DNS Server #1	10.10.55.254	
	Ethernet Configuration Port 1	Auto 💌	
	Port 2 Save settings	Auto 💌	
	OPC UA Configuration		
	TCP port	4840	
	Discovery server URL	opc.tcp://10.10.55.60:4840	
	Save settings		

Fig. 1

I

To get values timestamped correctly and to get valid timestamps in the responses from the X-gateway, a valid Discovery Server URL must be configured.

The configuration file has the same format as configuration files for web and FTP access. The opcua.cfg file can itself contain a set of user/password pairs or point out other user/password files in the filesystem. By pointing out one or several files with username and passwords it is possible to share configured users between OPC UA, web, and FTP.

3 Use UaExpert

3.1 Connect to the Anybus X-gateway

When starting UaExpert a new project will be loaded automatically. To add the X-gateway to the project, right click on the Servers folder of the Project window. Select "Add..." in the drop-down menu.

Unified Automation UaExp	ert - The OPC Unified	Architecture Client -	NewProject							-	0
File View Server Docur	ment Settings He	lp									
🌔 🧭 🖯 💆 🔘	💠 😑 🔅	× 🔍 🚨 🛙) 🕅 🥯								
oject	8 × 0	Nata Access View						6	Attributes		
Project Servers Servers D Documents D Data Access Vi	ew ð x	# Server	Node Id	Display Name	Value	Datatype	iource Timestamy Server Timestamp	Statuscode	Attribute Value		
									D-6		
									References		
									Reference Target DisplayNam	2	
9											
imestamp	Source	Server	Message								
019-11-21 14:22:15:010	HaEvnert		UaExpert is ready t	o use.							

Fig. 2

A new dialog window, "Add Server", shall pop up. On the Discovery tab, add the X-gateway device in the Custom Discovery section by double clicking on the "Double click to Add Server..." option.

Enter the IP address of the device in the format opc.tcp://<ip-address or hostname>: <port>, e.g. opc.tcp://192.168.0.10. If no port is specified, UaExpert will use the default TCP port 4840.



Fig. 3

When the device has been added, expand it to find the available OPC UA server on the device. Then expand the OPC UA server to see available endpoints to connect to. As the Anybus X-gateway does not support any security options there is only one unsecured endpoint available.

(username and password) via FTP. See the manual for more information.

Press the OK button to confirm the addition of the X-gateway device to the UaExpert project.

Add Server	?	×				
nfiguration Name bus X-Gateway IIoT - None - None (uatcp-uasc-u	abinary)				
Discovery Advanced						
Endpoint Filter: No Filter		-				
		_				
Gocal Network						
> Interview Microsoft Terminal Services						
> 💆 Microsoft Windows Network						
> 🔮 Web Client Network						
Y 😸 Custom Discovery						
Couble click to Add Server >						
 opc.tcp://10.10.55.151 Anubus V-Gateurus HaT (and ten) 						
 Anybus X-Gateway not (opc.tcp) None - None (uatcp-uasc-uak 	inary)					
Y 🕞 Recently Used		10 10 55 1	51,4940			
- <u>-</u>	ope.tep://	10.10.55.1	31:4040			
🚔 test						
Authentication Settings						
Anonymous		_				
Username						
Password	St	re				
		_				
Certificate						
Private Key						
Connect Automatically						
OK		ncel				

Fig. 4

When the X-gateway device has been added to the UaExpert project, it is possible to right click on the entry representing the device in the Servers folder of the project view. Click on the "Connect" option in the drop-down menu to connect to the device.





3.2 Browse the Address Space

Once connected, UaExpert will present the Address space of the device in the Address Space window (1). The address space can be browsed manually by expanding the folders and objects visible in the Address Space window. At the bottom UaExpert presents a log of events (2). If it fails to connect to the device or the Address Space is not populated as expected, it is recommended to take a look at this log to figure out the problem.



Fig. 6

When browsing the address space, it is possible to select any node to get more details about it. When a node has been selected in the Address Space window, all attributes of the node are presented in the Attributes window (1). All nodes always have a mandatory base set of attributes, then different node classes may specify additional attributes as well, both mandatory and optional ones.

The references of the selected node are presented in the References window (2). By default only forward references are shown. But there is a drop-down list that offers the possibility to show inverted references or references in both directions.

The Address Space window, the Attributes window and the References window also have a refresh button which forces UaExpert to reload the information presented in the window by requesting it from the device.



Fig. 7

3.3 Subscribe to Monitor the Configured Tags

The configured tags are present in the ParameterSet of the device in the address space. By selecting the node it is possible to see the current value of the tag in the Attributes window.

To setup a subscription and monitor the value of a tag, drag and drop one of the variable nodes from the ParameterSet into the Data Access View tab. UaExpert will display the current value of the parameter, its data type, timestamp when latest value was received etc. The OPC UA implementation in the X-gateway has support for 80 tags. To access all 80 tags, you need to configure two client connections toward the X-gateway. Each client connection will use two subscriptions and each subscription supports 20 tags.

UAExpert will only create one subscription per client connection, leaving you with a total maximum of 20 tags per client connection.

Unified Automation UaExpert - The OPC Unifie	d Architecture Client -	NewProject"	– a ×
The view server Document Settings H	ep		
🔰 🍋 🔚 🔯 🔟 🌲 📼 🛇	🗙 👒 👗 j I		
oject	e ×	Data Access View O Attributes	đ)
Servers Servers Servers Servers Anybux X-Gateway IIoT - None - N Documents Data Access View	one (uatop-uasic-uabir	Server Need M Explay/Need 2 Study Need 2 St	ć
()	>	DisplayName "en", "Son1_MotorTemperature"	
interes Strates	4 x	Description and an a	
No Hohicht		withewass 0 Use/WitheMask 0	
Rent	0	2 damage	
 Objects QuiceSet 		original →	C
 Anytou X-Gateway IloT DeviceMenual DeviceMenual DeviceMenual HardwareRevision HardwareRevision Manufacturer Model Sn1, MocorRotationRvd Sn1, MocorRotationRvd Sn1, MocorRotationRvd Sn1, MocorRotationRvd Sn1, MocorRotationRvd Sn1, MocorRotationRvd 		C	
9 9			80
• E2	Francis	Nama	
18-11-21 14:42:47.463 DA Plugin	Anybus X-Gate	mmsage Item INS1[Numeric][4777472] succeeded : RevisedSamplingInterval=1000, RevisedQueueSize=1, MonitoredItemId=1 [ret = Good]	i

Fig. 8

3.4 UaExpert Devices View

UaExpert also has a specific view to display the information about an OPC UA device. It is enabled by selecting the "Activate Devices Plugin" icon in the toolbar. Note that to display this view, UaExpert needs to load a lot of information from the X-gateway. It therefore takes some time for UaExpert to load all data before this view is presented.

Unified Automation UsExpert - The OPC Unified Architecture Client - N	lewProject"							- 0 ×
File View Server Document Settings Help								
D 💋 🕞 🖉 🔯 💠 🗕 🌣 🗙 🔧 🙎 🖻	📓 🥪							
Project 8 ×	Data Access View Arrybus X-Gateway IIoT				0	Attributes		8 >
✓ [™] Project	Consulta.					😏 🥪 🔖 🛞		c
✓	Properties				A	Attribute	Value	
Anybus X-Gateway IIoT - None - None (uatcp-uasc-uabir	DeviceMaguali	DeviceBevision1	н	andware Revision	3	✓ Nodeld	Nodeld	
V 🗊 Documents						Namespacels	index 1	
Data Access New	Manufacturer: HHS Industrial Networks	Model	*	evision.counter:	-1	IdentifierTyp	pe Numeric	
	SerialNumber: A03A9EE8	SoftwareRevision: 3.25	9.01			Identifier	16777472	
						Renarchise	Variable	
	Parameters					DisplayName	"en", "Sto1 MotorTemperature"	
< >	DisplayName Value Description					Description		
Devices Address Space 8 ×	Stn1_MotorRotationBwd_false					WriteMask	0	
Y 🗀 DeviceSet	Stn1_MotorRotationFwd false					UserWriteMask	0	
Y 🧼 Anybus X-Gateway IoT	Stn1_MotorTemperature 0					References		8 >
						9 🗸 🚠 🐵 For	rward 👻	c
						Reference T	Target DisplayName	
						HarTyneDefiniti B	ReseDataVariableTurne	
							and a second	
					Apply Cancel			
	Methods							
Address Space Devices Address Space							6	

