


# Carlton®




## INSTRUCTION SHEET For ADAPTER RING Cat. No. E97ABR2

Carlton Adapter Ring is designed to allow the installation of metal covers to the Carlton PVC Floor Box (E971FB).

### The following should be noted:


- Metal covers must be at least 4-3/4" diameter.
- Brass, bronze, or aluminum covers may be used provided the attachment screw positions of the cover match the screw positions on the adapter ring.
- The metal cover must be grounded by attachment of the grounding conductor to the green grounding screw of the adapter ring.  
**NOTE:** If the device is mounted directly to the adapter ring, the device must also be grounded.
- Adapter Ring to be used with metal covers listed below.

TWO DOOR  
DUAL SERVICE




E97BR2D Brass  
E97SS2D Stainless Steel

TWO DOOR




E97BR2 Brass  
E97SS2 Stainless Steel

SINGLE DOOR



E97BR Brass  
E97SS Stainless Steel

NPS OPENING



E97BRG Brass  
E97SSG Stainless Steel

### INSTRUCTIONS:

1. Cut the floor box flush with the finished floor.
2. Assemble the metal cover to the Adapter Ring, following the instructions of the cover manufacturer.
3. Apply solvent cement to outer surface of the Adapter Ring and to the floor box wall (I.D.). Insert assembly into the floor box and position as desired. Allow cement to dry thoroughly.
4. Remove metal cover attachment screws and lift cover from the floor box.
5. Install device following the manufacturer's instruction and reassemble the metal cover to the Adapter Ring.

Limited Warranty Applies. Refer to:  
[www.tnb.com/ecpwarranty](http://www.tnb.com/ecpwarranty)  
for full warranty terms.

## **Thomas & Betts**

Thomas & Betts Corporation  
Memphis, Tennessee  
[www.tnb.com](http://www.tnb.com)