



131 Regalcrest Court
Woodbridge, ON L4L 8P3
Tel: (905) 856-7550
Fax: (905) 856-4367
Toll free: 1-800-263-2353

TECHNICAL SPECIFICATION

PVC Rigid Conduit Fittings Single Gang Boxes-F Series

SCOPE

This specification covers the requirements for Rigid PVC Non-Metallic Single Gang Boxes. These boxes are certified to the Canadian Standards Association (CSA) standard C22.2 Nos. 85 and 18.2 and Underwriters Laboratories (UL) Standard 514C. These boxes also meet all requirements of NEMA OS2-2003. The following are the individual trade names/configurations:

RFS10, RFS15, RFSS10, RFSS15
RFSC10, RFSC15, RFSCC10, RFSCC15

MATERIALS

The PVC material used in the manufacture of these Non-Metallic Boxes is UV and impact resistant.

MARKING

Single Gang Box markings are as specified in CSA C22.2 Nos. 85 and 18.2 and UL 514C.

BOX CONFIGURATIONS

Non-Metallic Outlet Boxes are available in various configurations, with sockets to accommodate 1/2" and 3/4" PVC rigid conduit.



RFS10, RFS15
1/2", 3/4"



RFSS10, RFSS15
1/2", 3/4"



RFSC10, RFSC15
1/2", 3/4"



RFSCC10, RFSCC15
1/2", 3/4"

Prepared: August 31, 2006
By: S. Scott
Revised: February 13, 2009