



131 Regalcrest Court  
Woodbridge, ON L4L 8P3  
Tel: (905) 856-7550  
Fax: (905) 856-4367  
Toll free: 1-800-263-2353

## TECHNICAL SPECIFICATION

### PVC Rigid Conduit, Octagonal Boxes ROB15/10, ROB20

#### **SCOPE**

This specification covers the requirements for Rigid PVC (polyvinyl chloride) Conduit Octagonal Boxes in ½", ¾" and 1" sizes. Included with the box is the gasket, cover and screws (for mounting of cover).

#### **MATERIALS**

The box and cover are injection molded from virgin PVC compound. The gasket is injection molded from virgin flexible PVC compound.

PVC material used in the manufacture of the box and cover is UV and impact resistant.

#### **CERTIFICATIONS**

This part is certified to the following standards:

Canadian Standards Association:


- Certified to CSA C22.2 No. 18 and 85
- Certified as Rain-Tight

Underwriter's Laboratories Inc.:

- Certified to UL 514C
- Certified for use in Wet Locations

#### **BOX DIMENSIONS**

Box dimensions are available upon request.



Prepared: May 2, 2008

By: S. Scott

Revised: N/A