


JOB: UNIT TAG: ENGINEER: CONTRACTOR:	REPRESENTATIVE: ORDER NO. SUBMITTED BY: APPROVED BY:	DATE: DATE: DATE:
---	---	--



ZoneTrol II™

AZ-1A Zone Pump Controller


DESCRIPTION

The ZoneTrol II AZ-1A pump controller can be field mounted to any B&G NRF, NBF, SSF or 1/12 to 1/6 HP Series PL™ booster pump. The AZ-1A controller operates the pump when the thermostat calls for heat. The controller can be wired to fire the boiler through a 24 volt rated isolated endswitch. The AZ-1A relay boxes can be daisy-chained to form up to a maximum of three zones. The AZ-1A pump controllers are UL and cUL listed. When the AZ-1A is mounted on a B&G pump, the pump and controller assembly maintains the UL listings.

CONSTRUCTION

The ZoneTrol II AZ-1A pump controllers are solidly constructed, easy to mount units featuring printed circuit board design and a powerful 2.5 VA transformer for operating up to three zones. An amber LED light on the PC board indicates a call for heat. The units are listed with Underwriters Laboratories, Inc.

SCHEDULE

MODEL NO.	MAXIMUM NUMBER OF ZONES	TAGGING INFORMATION	QUANTITY
AZ-1A	1		

Add-A-Zone™ Zone Pump Controller

A-360A

SPECIFICATION INFORMATION

PART NO.	MODEL NO.	TRANSFORMER RATING	THERMOSTAT CURRENT	RELAY TYPE	DIMENSIONS (L X W X H) INCHES	MOTOR RATING EACH ZONE	APPROX. SHPG. WT. OZ. (kg)
						120V, 1Ø	
109423	AZ-1A	2.5 VA	0.18 A	DPDT	2-5/8" x 3-1/2" x 2-5/8"	1/6 HP	12 (0.3)

TYPICAL SPECIFICATIONS

Single Zone (AZ-1A)

Furnish and install zone pump controller(s) as shown on plans. The controller(s) shall be UL and cUL listed and suitable for operation of a single circulator pump. Controller shall include a nominal 2.5 VA transformer, pre-wired printed circuit board that can be easily field mounted to Bell & Gossett pump model _____ [choose from NRF, NBF, SSF and Series PL boosters]. The pump controller shall have a 24-volt rated isolated endswitch to fire the boiler when there's a call for heat. An amber LED shall be on the PC board to indicate a call for heat. The pump controller must be rated for a full 5 amps and have a DPDT switching action. All models shall be Bell & Gossett Model AZ-1A. When the control is mounted to a single circulator pump, the pump/controller assembly will be UL listed.