

Slant/Fin[®]



Monitron[™] S2

MODEL EH ELECTRIC BOILER

EH-08-135-S2 through EH-40-135-S2, single phase, 3 wire, 120/208V, 120/240V
EH-12-345-S2 through EH-40-345-S2, three phase, 4 wire, 120/208V, 120/240V

OPERATION AND INSTALLATION INSTRUCTIONS

CONTENTSPAGE

Description	2
Mounting	2
Piping	2
Air Eliminator and Expansion Tanks	2
Flow Switch	2
Bypass	2
Wiring	2
Wall Thermostat Flow Switch and Circulator	2
Typical Wiring	2
Service Connections and Electrical Ratings	2
Rough-In Dimensions	3
Electrical Ratings	4
Typical Piping	5
Typical Zone Valve Wiring	6
Start-up	7
Fill System	7
Air Elimination	7
Bypass Flow Adjustment	7
Check for Proper Boiler and System Operation	7
Operation (models equipped with seq. control system)	7
Periodic Inspection	7
Appendix A, B, C & D	8



IMPORTANT:

This manual must be left with owner and should be hung on or adjacent to the boiler for reference.

Wiring diagram located on inside front panel.

Heating Contractor

Address

Phone Number

Boiler Model Number

Boiler Serial Number

Installation Date

DESCRIPTION

The Monitron boiler is a low pressure hot water heating electric boiler. The heating elements are sheathed resistance type. The heat exchanger is cast-iron. The heat exchanger is constructed, inspected, and stamped in accordance with Section IV of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code. In addition, the Monitron Boiler is equipped with a safety relief valve, operating control and two high limit controls.

MOUNTING

The Monitron is intended for wall mounting, utilizing the wall brackets attached to the boiler (see Figure 1). Allow sufficient space for piping and service. The boiler may be installed in an enclosed space (see Figure 1). The boiler must be INSTALLED LEVEL.

PIPING

Air Separator and Expansion Tanks

The recommended piping arrangement is shown in figures 3 through 5. Note that there is a built-in air eliminator in the heat exchanger (air vent, however, is by others). The air vent tapping is 13mm (1/2"). A bushing (by others) to suit the size of the air vent thread is required. Additional air vents should be installed at points just upstream from all drops in elevation of the piping system (high points).

Relief Valve Discharge Piping

Use same size or larger piping than valve outlet. Must terminate 152mm (6") minimum from floor with a plain (no threads) end. Place a bucket under pressure relief valve discharge. Make sure discharge is always visible. DO NOT hard-pipe to drain piping.

Flow Switch

THE INSTALLATION OF A FLOW SWITCH IS STRONGLY RECOMMENDED. It is intended to prevent the burnout of heater elements should the circulator fail, or should air accumulate in the boiler due to faulty air elimination (see Table 3 for flow switch size required). FLOW SWITCH MUST BE INSTALLED IN HORIZONTAL POSITION. IF A FLOW SWITCH IS NOT USED JUMPER THE "FF" TERMINALS (JUMPER NOT SUPPLIED.)

Bypass

The bypass shown must be set so that a sufficient amount of water can circulate through the boiler when all zone valves are closed. (See Figure 4.) A bypass is mandatory on a constant circulation system using zone valves if a wild loop is not part of the system. The bypass line will prevent circulator damage caused by a circulator running up on head.




Figure 2. Typical Wiring Diagram for Models equipped with Circuit Breakers.

Multi-zone Balancing

Raise all zone thermostat settings and verify that all zone valves are open (bypass valve should be closed). Close all electrical panels. Turn on 15 amp control circuit breaker ONLY. Pump should operate. Note the pressure reading on the pump discharge. Lower each zone thermostat setting to close corresponding zone valve. Adjust the corresponding balancing valve to maintain pump discharge pressure. The pump discharge pressure should remain the same when all zones are in bypass or when all zones are open or any combination of opened and closed. (See Figure 4 & 5.)

WIRING

To wire the electric boiler, perform the following procedures:

1. Wall Thermostat Flow Switch and Circulator

All circuit breakers ahead of boiler must be OFF. Remove the Control Panel (left-hand front cover) by removing 5 screws from top, bottom and side flanges. The centre compartment contains a 24V control terminal board marked, "FF/TT" (see figure 2). Wire a 24V, two-wire heating thermostat or the auxiliary end switch terminals from zone valves (see Figure 7) to "TT". The "FF" terminals are for a flow switch. Do not connect the wires to the flow switch "FF" terminals until the by-pass flow adjustments are completed. Refer to "Bypass Flow Adjustment" (page 7) for wiring and adjustment procedures. The flow switch wires should be taped at the boiler until they are to be connected to "FF".

The left compartment contains a 120V terminal board marked "A-B/Circulator". Wire the circulator and connect wires and conduit through the 13 mm (1/2") knockout (provided on the bottom left hand corner of the cabinet) to the terminal board "Circulator" terminals. These terminals supply 120 volts to the circulator only when there is a call for heat.

Wire an external zone valve transformer to the "A-B" terminals if zone valves are used. These terminals provide a constant 120 volts and can alternately be used to power the circulator if constant circulation is desirable. Use 90°C minimum wire, copper or aluminum.

2. Service Connections and Electrical Ratings

- All circuit breakers ahead of boiler must be OFF. Remove the Service Connection Panel (right hand front) cover by removing 5 screws from the top, bottom and side flanges (see wiring diagram on back of the Service Connection Panel and Figure 2).
- Draw power feeder cable (75°C minimum) and conduit through service K.O. provided on side, top or bottom.
- Connect hot lines to main lugs on breaker base provided in service compartment. A ground lead should be drawn and wired to the ground lug in the service compartment. If rating plate indicates boiler is a single phase 3-wire or 3-phase 4-wire model, draw a neutral wire #12 AWG maximum, 75°C minimum and connect to neutral lug provided in service compartment. See Tables 1 and 2 for lug sizes and current ratings.

Figure 1

MONITRON "ROUGH-IN" DIMENSIONS

1. UNIT MAY BE FULLY ENCLOSED IF CLEARANCE DIMENSIONS ARE RESPECTED.
2. DUAL DIMENSIONS ARE INCH [MM]








Figure 1a



BOILER HEIGHT ABOVE WALL BRACKET TAB




Table 1. Lug Sizes

Model	Phase	Distribution Block Wire Size CU-AL†	Grounding Lug Wire Size CU	Neutral Lug Wire Size CU
EH-24 thru EH-40S2	1	1-250 CU 2/0-250 AL	6-2/0	6-2/0
EH-8 thru 20S2	1	6-2/0 CU-AL	6-2/0	6-2/0
EH-12 thru 40S2	3	6-2/0 CU-AL	6-2/0	6-2/0
The maximum wire size of the neutral should not exceed 12 AWG in order for 51 mm (2") conduit to accommodate incoming power feeder, plus the neutral wire and a ground conductor for the larger models.				

† ALUMINUM conductors may be used, lug size, conduit size, ampacity and all applicable codes permitting. However, aluminum conductors may NOT be used for models over 32 Kw.

Table 2. Current Ratings

SINGLE PHASE 3 WIRE 120/208V, 120/240V‡			THREE PHASE, 4 WIRE 120/208V-WYE 120/240V-DELTA		
Basic Model No.	Heater Ampres* @240V	FLA @240V	Basic Model No.	FLA @208V	FLA @240V
EH-8	33	45			
EH-9	38	49			
EH-10	42	54			
EH-12	50	62	EH-12	38.9†	42.6†
EH-15	63	74	EH-15	44.9†	49.5†
EH-16	67	79	EH-16	53.1†	58.9†
EH-18	75	87	EH-18	55.4†	61.6†
EH-20	83	95	EH-20	62.5†	69.8†
EH-24	100	112	EH-24	62.5†	69.8†
EH-25	104	116	EH-25	62.5†	72.1†
EH-28	117	129	EH-28	72.7†	81.7†
EH-30	125	137	EH-30	75.4†	84.9†
EH-32	133	145	EH-32	72.5†	83.6†
EH-35	146	158	EH-35	78.7†	90.8†
EH-38	158	170	—	—	—
EH-40	167	179	EH-40	95.5†	110.2†

* For current values @ 208V, multiply current @ 240V by 0.867.

† Leg with the highest value of line current of an unbalanced 3-phase load.

‡ 125 VAC maximum rating of all hot conductors.

Table 3. Flow Switch Size Selection

Model No.	Flow Switch McDonnell & Miller No.	Pipe Size		Minimum Length of Straight Pipe*	
		mm	inch	mm	inch
EH-40	FS8V	32	1-1/4	216	8-1/2
EH-8 thru EH-35	FS4-3T3-1	25	1	165	6-1/2

* Both upstream and downstream of flow switch.




Figure 3. Typical Single Zone Piping




Figure 4. Typical Multi-Zone using 2-Way Valves




Figure 5. Typical Multi-Zone Using 3-Way Valves

NOTES:

1. Optional blocking gate valve and hose end valve used (with drain valve) for fast fill and purge of system.
IMPORTANT: Close bypass line valve (if used) during purging.
2. Circulator should not be installed at lowest point of piping.
3. There should be no elbows, tees, or change of pipe size for at least 5 diameters of pipe size (see Table 3) upstream and downstream of flow switch.
Flow switch should always be mounted in the horizontal position. See Table 3.




Figure 6. Typical Zoning Valve Wiring




Figure 7. Multi-Zoning of boiler; pump zoning system using R845A relay.

START-UP

NOTE: Make sure that all circuit breakers ahead of and at the boiler are OFF.

Fill System

See Figures 3 through 5 for suggested purge valve and blocking valve. If system is filled but not purged, radiators must be vented individually, to prevent air blocking of water flow. Fill approximately 83 kPa (12 psi) (cold water), whether automatic or manual fill is used. Do not apply full line pressure to system; boiler and relief valve are rated at 207 or 345 kPa (30 or 50 psi) (see rating plate). Suddenly applied main pressure can exceed 690 kPa (100 psi).

WATER CONTENT OF BOILER

All models EH-8 through EH-40 14.2 litres (3.75 U.S. Gallons)

Air Elimination

Diaphragm tank and air vent valve are recommended, see Figures 3 through 5. Air remaining in system will vent from the automatic vent valve during system operation. Valve cap must be loose or removed to allow automatic venting. Open relief valve briefly after filling to pressure, to make sure boiler is free of air.

Bypass flow adjustment (Figure 4)

Close bypass valve. Turn down all zone thermostats. Inspect all zone valves to be sure all are closed. Put a jumper on TT terminals. Close ALL panels and turn on the 15 AMP control circuit breaker ONLY. Be certain that the flow switch wires are not connected to the flow switch terminals and the ends of the wires are taped. Connect the ohmmeter or other continuity tester across the common terminal and the terminal that is normally open during NO FLOW. Slowly open bypass valve until continuity tester lights or ohmmeter kicks to zero: flow switch now has closed contacts, indicating required minimum bypass flow rate when piping circuits are shut off. Bypass valve should be locked at this position. Shut OFF ALL circuit breakers ahead of and at boiler and open CONTROL PANEL (left hand FRONT COVER). Remove jumper on "TT" terminals. Connect zone valve end switches (in parallel) to thermostat "TT" terminals. See figure 7 and wiring diagram on boiler. Connect flow switch wire to flow switch common and N.O. terminals and to the "FF" terminals in the boiler. Replace CONTROL PANEL COVER.

Check for Proper Boiler and System Operation

To check for proper boiler and system operation, perform the following procedures:

1. Open boiler water supply valve. Boiler will not operate properly for approximately 15 minutes, until all air is purged from water lines.
2. Turn up all room thermostats.
3. Turn "ON" Control (15 Amp, 120 Volt) single circuit breaker only. Make sure that all Double (208/240 Volt) circuit breakers are "OFF".
4. Water flow through the boiler should be sufficient to keep the flow switch closed. The two limit switches should be closed.
5. There will be a delay of up to 5 minutes before all circuits are energized.
6. Check aquastat settings against aquastat control manual. The aquastat is located under the left front control panel. **CAUTION:** The aquastat control has line voltage in it. Care should be taken to avoid touching any "LIVE" electricity carrying components.
7. Turn "OFF" Control (15 Amp, 120 Volt) single circuit breaker.
8. Replace all Control Panel Covers.
9. Turn "ON" all Double (208/240 Volt) circuit breakers.
10. Turn "ON" Control (15 Amp, 120 Volt) single circuit breaker.
11. The current may be checked by a qualified electrician at the feeder panel and compared to the values shown in Table 2.

OPERATION

IMPORTANT:

DO NOT operate boiler until the following criteria have been met:

1. **Must be installed by qualified heating and electrical contractors in accordance with instructions in this manual.**
2. **Must be installed in compliance with local codes.**
3. **Must be inspected and approved by installing contractors and any local authority having jurisdiction, and be approved for operation by them.**

- Ask the installer to explain operation of the entire heating system.
- Turn on all circuit breakers for boiler and circulator.
- Adjust wall thermostat to required temperature. If room temperature is lower than the thermostat setting, the first heater stage will go on immediately and the balance of the heater stages will go on one at a time with a delay of between several seconds and 1-1/2 minutes between stages.
- In mild weather you may wish to reduce the total output of heat. You may do this by turning off one or more of the circuit breakers on the boiler. Do not turn off the 15 AMP control circuit breaker.

PERIODIC INSPECTION

The hot water system, which includes the Monitron boiler, the radiators and water control devices, should remain filled with water at all times. DO NOT drain except to make repairs or to prevent freeze-up during extended cold weather shutdown.

The pressure/temperature gauge on the Monitron should be checked frequently: at the highest operating temperature, pressure should be the same throughout the heating season. If pressure (at a constant temperature) consistently rises or falls over a period of time, a fill valve leak, a system leak or compression tank malfunction is indicated. Leaks anywhere in the system must be repaired without delay. Regular addition of fresh water to replenish leaks adds oxygen and lime. Oxygen corrosion will cause further leaks and parts failure, lime buildup on heating elements will cause element failure due to overheating. If any leaks are found, or if pressure changes, call for service immediately.

IMPORTANT

Under no circumstances should any electrical wiring or internal controls be touched, except by an authorized electrician (wiring and controls) or heating system service expert (system service, repair, shutdown). Any mechanical adjustments to the heating equipment and system must be made by a qualified heating serviceperson.

Appendix A

Thermostat Heat Anticipator Settings

Fixed anticipator thermostats are not adjustable. Adjustable anticipator thermostats, depending on thermostat model, may be adjustable from a .18 to a .9 setting by moving a pointer on the anticipator.

The higher the anticipator setting (towards .9) the longer it will take for the thermostat to respond to a change in room temperature. Too high a setting and the boiler will be slow to respond to a temperature change in the room. This can cause the room temperature to drop to an uncomfortable level before the boiler starts. This may generate homeowner complaints.

The lower the anticipator setting (toward .18) the faster the thermostat will respond to a change in room temperature. Too low a setting and the boiler will short cycle. Boiler short cycling will cause unnecessary wear on the equipment and in the case of oil boilers it can lead to poor combustion and more frequent cleaning of the combustion area.

It is important to understand what the thermostat is controlling and then determine the amp rating of that relay, gas valve, zone valve or control. This information is usually stamped somewhere on the component. A properly set anticipator will allow the system to operate at its maximum effectiveness.

Appendix B

Accumulation of foreign deposits in heat exchanger

Recent investigations of boilers which were installed in hard water areas, revealed that mineral deposits had accumulated in the heat exchanger. In addition, sludge, scale and other solid contaminants were present in boilers installed in older systems or where the water was supplied from a well. This accumulation creates an insulating layer that drastically may affect boiler efficiency.

THE TERMS OF THE BOILER WARRANTY WILL NOT APPLY TO FAILURES ENCOUNTERED UNDER THESE CIRCUMSTANCES.

RECOMMENDATIONS:

On all installations in hard water areas:

1. The system should be thoroughly inspected for leaks which must be repaired however minor they may be.
2. The initial water charge of the system must be treated to reduce its hardness to an acceptable level.

In addition to the aforementioned, older systems and those supplied from wells may require that a filter or strainer be incorporated in the circuit at some point on the return line closest to the boiler. Suitable water treatment filters are commercially available for this purpose.

WE STRONGLY RECOMMEND THAT YOU CONVEY THIS VITAL INFORMATION TO ALL PARTIES CONCERNED.

Water Treatment

A good water treatment program will not only extend the useful life of this boiler but it will also save much of the time and expense of repairs made necessary by preventable occurrences. A reputable water treatment company should be consulted to evaluate and determine the best overall treatment program for your boiler equipment.

Appendix C

Replacement of Electric Heaters and gaskets

When replacing heating elements replace the gasket at the same time. It is not recommended to re-use an old gasket as it may have become damaged or brittle. To prevent binding and leaks when installing a new gasket wet the gasket with water or coat it with talcum powder to allow it to move into position properly without binding.

Appendix D

Use of Non-oxygen Diffusion Barrier Underfloor Tubing

The boiler warranty does not cover leaks resulting from corrosion caused by the use of underfloor plastic tubing without an oxygen diffusion barrier. Systems must have the non-oxygen diffusion barrier tubing separated from the boiler with a heat exchanger. Slant/Fin recommends the use of underfloor plastic tubing with an oxygen diffusion barrier. Other systems components may also require protection from oxygen permeation.



U.S.A.
Slant/Fin Corporation • 100 Forest Drive
Greenvale, NY 11548 • 516-484-2600
www.slantfin.com

Canada
Slant/Fin LTD/LTEE • 400 Ambassador Drive,
Mississauga, Ontario L5T 2J3 • 905-677-8400
www.slantfin.ca



E.-U.
Slant/Fin Corporation • 100 Forest Drive
Greenville, NY 11548 • 516-484-2600
www.slantfin.com

Canada
Slant/Fin LTD/LTEE • 400 Ambassador Drive,
Mississauga, Ontario L5T 2J3 • 905-677-8400
www.slantfin.ca

Utilisation de tuyauterie sous le sol avec barrière anti-diffusion d'oxygène

La garantie de la chaudière ne couvre pas les fuites résultant de la corrosion causée par l'utilisation de tuyauterie en plastique sous le sol sans diffusion d'oxygène. Les systèmes doivent être munis d'une tuyauterie avec barrière anti-diffusion d'oxygène séparée de la chaudière avec un échangeur de chaleur. Slant/Fin recommande l'utilisation de tuyauterie en plastique sous le sol avec une barrière de diffusion d'oxygène. D'autres composants du système pourraient avoir besoin d'une protection relative à la perméabilité de l'oxygène.

Annexe D

Remplacement des radiateurs électriques et des joints d'étanchéité.

Lorsque vous remplacez les éléments de chauffage, remplacez le joint au même moment. Il n'est pas recommandé de réutiliser un vieux joint, puisqu'il peut être endommagé ou fragilisé. Pour éviter la rétention et les fuites lorsque vous installez un nouveau joint d'étanchéité, mouillez le joint ou enduisez-le de poudre de talc pour lui permettre de se mettre en position adéquatement sans rétention.

Annexe C

Traitement de l'eau

Un bon programme de traitement de l'eau prolongera non seulement la durée de vie utile de cette chaudière, mais il fera également épargner beaucoup de temps et éviter des dépenses concernant les réparations rendues nécessaires par des incidents évitables. Une compagnie de traitement d'eau digne de confiance devrait être consultée pour évaluer et déterminer le meilleur programme de traitement global pour l'équipement de votre chaudière.

NOUS VOUS RECOMMANDONS FORTEMENT DE DISTRIBUER CETTE INFORMATION VITALE À TOUTES LES PARTIES CONCERNÉES.

En plus de ce qui est mentionné ci-avant, des systèmes plus vieux et ceux alimentés par des puits pourraient nécessiter l'incorporation d'un filtre ou d'une crépine dans le circuit à un moment donné, sur la tuyauterie de retour la plus proche de la chaudière. Des filtres de traitement d'eau adéquats sont disponibles sur le marché à cet effet.

1. Le système devrait être inspecté de fond en comble pour des fuites qui doivent être réparées, qu'elles soient mineures ou non.
2. La charge d'eau initiale du système doit être traitée pour réduire sa dureté à un niveau acceptable.

RECOMMANDATIONS :

Sur toutes les installations dans des zones d'eau calcaire :

LES TERMES DE LA GARANTIE DE LA CHAUDIÈRE NE S'APPLIQUERONT PAS AUX PANNES DANS CES CIRCONSTANCES.

l'efficacité de la chaudière.

Accumulation de dépôts étrangers dans l'échangeur de chaleur

Des inspections récentes de chaudières qui ont été installées dans des zones d'eau calcaire ont révélé que des dépôts minéraux s'étaient accumulés dans l'échangeur de chaleur. En plus, de la boue, du tartre et d'autres contaminants solides étaient présents dans des chaudières installées dans les systèmes plus vieux, là où l'eau était fournie par un puits. Cette accumulation crée une couche isolante qui pourrait considérablement affecter

Annexe B

Il est important de comprendre ce que le thermostat contrôle et de déterminer par la suite l'ampérage de ce relais, de la soupape de gaz, de la vanne de zone ou du contrôle. Cette information est normalement étampée quelque part sur le composant. Un anticipateur bien réglé permettra au système de fonctionner à son efficacité maximale

Plus le réglage de l'anticipateur est élevé (aux alentours de 0,9), plus le thermostat réagira rapidement à un changement de température de la pièce. En cas de réglage trop bas, la chaudière aura un cycle court. Un cycle court de la chaudière causera l'usure inutile de l'équipement et, dans le cas des chaudières au mazout, cela peut conduire à une combustion faible et un nettoyage plus fréquent de la zone de combustion.

Plus le réglage de l'anticipateur est élevé (aux alentours de 0,9), plus il faudra du temps au thermostat pour réagir à un changement de température de la pièce. En cas de réglage trop élevé, la chaudière sera lente à réagir à un changement de température dans la pièce. Cela peut provoquer une baisse de la température à un niveau inconfortable avant que la chaudière se mette en marche. Cela peut générer des plaintes du propriétaire.

Les thermostats fixés de l'anticipateur ne sont pas ajustables. Les thermostats d'anticipateur ajustables, tout dépendant du modèle, pourraient être ajustés à partir d'un réglage 0,18 à 0,9, en déplaçant un pointeur sur l'anticipateur.

Annexe A

Réglages de l'anticipateur de chaleur du thermostat

Figure 6. Câblage typique des vannes de zone




Figure 7. Multi-zonage de la chaudière ; système de zonage de la pompe utilisant un relais R845A.




Figure 7. Multi-zonage de la chaudière ; système de zonage de la pompe utilisant un relais R845A.





Figure 6. Câblage typique des vannes de zone






Figure 3. Tuyauterie en zone unique




Figure 4. Multivoie typique utilisant des vannes à deux voies




Figure 5. Multivoie typique utilisant des vannes à trois voies

- REMARQUES :
1. Robinet-soupape de blocage et robinet d'incendie (avec robinet de vidange) optionnels utilisés pour un remplissage rapide du système.
 2. **IMPORTANT** : Fermez la vanne de ligne de dérivation (si elle est utilisée) lors de la purge.
 3. Le circulateur ne devrait pas être installé au point le plus bas de la tuyauterie.
 3. Il ne devrait pas y avoir de coudes, de raccord(s) en T, ou de changement de diamètre du tuyau sur au moins 5 diamètres de tuyau (voir Tableau 3).
- Le limiteur de débit devrait toujours être monté en position horizontale. Voir Tableau 3.

Tableau 1. Tailles de cosse

N° de modèle	Phase	Taille du câble		
		Taille du câble du répartiteur	terre CU	Taille du câble de mise à la terre CU de la cosse
EH-24 à EH-40S2	1	1-250 CU	2/0-250 AL	6-2/0
				6-2/0
EH-8 à 20S2	1	6-2/0 CU-AL	6-2/0	6-2/0
EH-8 à 40S2	3	6-2/0 CU-AL	6-2/0	6-2/0
La taille maximale du câble neutre ne doit pas dépasser 12 AWG afin que le conduit de 51 mm (2") puisse laisser passer le câble d'alimentation en énergie, plus le câble neutre et un conducteur de terre pour les modèles plus grands.				

† Des conducteurs en ALUMINIUM peuvent être utilisés, si la taille de la cosse et du conduit, le courant admissible et tous les codes applicables le permettent. Cependant, les conducteurs en aluminium NE peuvent PAS être utilisés pour des modèles de plus de 32kw.

Tableau 2. Courants nominaux

MONOPHASE À 3 FILS 120/208V, 120/240V†					TRIPHASÉ À 4 FILS 120/208V-COUPPLAGE 120/240V†				
N° de modèle	Chaudière Ampres* @240V	Courant @240V	N° de modèle de base	Courant @208V	Courant @240V	N° de modèle	Chaudière Ampres* @240V	Courant @240V	N° de modèle de base
EH-8	33	45				EH-8	33	45	
EH-9	38	49				EH-9	38	49	
EH-10	42	54				EH-10	42	54	
EH-12	50	62	EH-12	38.9†	42.6†	EH-12	50	62	EH-12
EH-15	63	74	EH-15	44.9†	49.5†	EH-15	63	74	EH-15
EH-16	67	79	EH-16	53.1†	58.9†	EH-16	67	79	EH-16
EH-18	75	87	EH-18	55.4†	61.6†	EH-18	75	87	EH-18
EH-20	83	95	EH-20	62.5†	69.8†	EH-20	83	95	EH-20
EH-24	100	112	EH-24	62.5†	69.8†	EH-24	100	112	EH-24
EH-25	104	116	EH-25	62.5†	72.1†	EH-25	104	116	EH-25
EH-28	117	129	EH-28	72.7†	81.7†	EH-28	117	129	EH-28
EH-30	125	137	EH-30	75.4†	84.9†	EH-30	125	137	EH-30
EH-32	133	145	EH-32	72.5†	83.6†	EH-32	133	145	EH-32
EH-35	146	158	EH-35	78.7†	90.8†	EH-35	146	158	EH-35
EH-38	158	170	—	—	—	EH-38	158	170	—
EH-40	167	179	EH-40	95.5†	110.2†	EH-40	167	179	EH-40

* Pour les valeurs de courant @ 208V, multipliez le courant @ 240V par 0,867.
† Tronçon avec la plus grande valeur du courant d'une charge triphasée déséquilibrée.
‡ Puissance nominale maximale de 125 volts c.a. pour tous les conducteurs chauds.

* Aussi bien en amont et qu'en aval du limiteur de débit.

Tableau 3. Choix de la taille du limiteur de débit

N° de modèle	Limiteur de débit N° McDonnell & Miller	Taille du tuyau		FS8V	FS4-3T3-1	De EH-8 à EH-35
		mm	pouces			
Longueur minimale de tronçon de tuyauterie rectiligne*		mm	165	1	25	EH-8 à EH-35
		pouces	216	1-1/4	32	EH-40

DIMENSIONS DE POMPERIE BRUTES DU MONITRON

Figure 1

1. IL EST POSSIBLE D'ENCLOSENNER COMPLÈTEMENT L'APPAREIL SI L'ON RESPECTE LES DIMENSIONS DE DÉGAGEMENT.
2. LES DIMENSIONS SONT PRÉSENTÉES EN POUCES ET EN MM (ENTRE CROCHETS).









Figure 2. Schéma de câblage typique des modèles équipés de disjoncteurs.



Limiteur de débit
NOUS VOUS RECOMMANDONS FORTEMENT D'INSTALLER UN LIMITEUR DE DÉBIT. Son installation sert à prévenir le grillage des éléments de chauffage au cas où le circulateur cesserait de fonctionner, ou au cas où de l'air s'accumulerait dans la chaudière en raison d'une élimination d'air défectueuse (voir Tableau 3 pour la taille requise du limiteur de débit). LE LIMITEUR DE DÉBIT DOIT ÊTRE INSTALLÉ EN POSITION HORIZONTALE. SI UN LIMITEUR DE DÉBIT N'EST PAS UTILISÉ, PLACEZ UN CAVALIER SUR LES BORNES « FF » (CAVALIER NON FOURNI).

Tuyauterie de décharge de la soupape de sûreté
Utilisez une tuyauterie de la même taille ou plus grosse que la tuyauterie de la soupape d'écoulement. Doit embouter au minimum 152 mm (6") à partir du plancher avec un bout (aucun fil) uni. Placez un sceau sous la décharge de la soupape de sûreté. Assurez-vous que la décharge soit toujours visible. NE FAITES PAS DE RACCORDEMENT FIXE à la tuyauterie d'évacuation.

Séparateur d'air et vases d'expansion
Le dispositif de tuyauterie recommandé est présenté sur les Figures 3 à 5. Veuillez noter qu'il y a un éliminateur d'air intégré dans l'échangeur de chaleur (l'aération provient cependant des autres). Le piquage d'aération est de 13 mm (1/2"). Une douille taraudée (par d'autres) est nécessaire pour s'adapter à la taille du filetage de l'aération. Des bouches d'aération supplémentaires devraient être installées à des points situés juste en amont de toutes les dénivellations de la tuyauterie (points élevés).

TUYAUTERIE

INSTALLÉE À NIVEAU.
installée dans un espace confiné (voir Figure 1). La chaudière doit être suffisamment d'espace pour la tuyauterie et l'entretien. La chaudière peut être pattes de support mural fixées à la chaudière (voir Figure 1). Laissez suffisamment d'espace pour un montage mural, en utilisant les

MONTAGE

maximale.
rite, de commandes opérationnelles et de deux commandes de pression pression. De plus, la chaudière Mintron est munie d'une soupape de sécurité, en vertu du code des chaudières et des cuves sous conformément à la Section IV de la American Society of Mechanical Engineers (ASME), l'échangeur de chaleur est construit, inspecté et estampillé est en fonte. L'échangeur de chaleur est construit, inspecté et estampillé éléments de chauffage sont à résistance gainée. L'échangeur de chaleur La chaudière Mintron est une chaudière électrique à basse pression. Les

DESCRIPTION

- A. Tous les disjoncteurs en amont de la chaudière doivent être ETEINTS. Retirez le panneau de branchement de service (à l'avant, côté droit). Couvrez en retirant 5 vis des parties supérieure, inférieure et latérale des brides (voir le schéma de câblage au dos du panneau de branchement et sur la Figure 2).
- B. Faites passer le câble d'alimentation électrique (minimum 75°C) et le conduit par l'ouverture de branchement située sur le côté, au-dessus ou en-dessous.
- C. Raccordez les lignes sous tension aux bornes d'arrivée situées à la base du disjoncteur, incluses dans le compartiment de branche-

2. Connexions de service et caractéristiques électriques

un câble en cuivre ou aluminium de 90°C (75°F) minimum.
mentation du circulateur si une circulation constante est souhaitée. Utilisez constante de 120 volts et peuvent être utilisées alternativement pour l'alimentation des vannes de zone sont utilisées. Ces bornes fournissent une tension les vannes de zone aux bornes « A-B » si Câblez un transformateur externe de vanne de vanne de zone aux bornes « A-B » si

demande de chaleur.
fournissent 120 volts au circulateur uniquement lorsqu'il n'y a pas de (voir la plaque à bornes « Circulator ») aux bornes « Circulator » de la plaque à bornes. Ces bornes vers de l'ouverture de 13 mm (1/2") (dans le coin inférieur gauche de l'arcade) le circulateur et raccordez les fils et un conduit au tra-

Le compartiment à gauche contient un bornier 120V marqué « A-B/Disjoncteur ». Câblez le circulateur et raccordez les fils et un conduit au tra-

1. Limiteur de débit du thermostat mural et diffuseur

Tous les disjoncteurs en amont de la chaudière doivent être ETEINTS. Retirez la couverture du panneau de commande (à l'avant, du côté gauche) en retirant 5 vis sur les parties supérieure, inférieure et latérale des brides. Le

CÂBLAGE

Pour mettre en place le câblage de la chaudière électrique, procédez comme suit :

Augmentez tous les réglages du thermostat de zone et assurez-vous que toutes les vannes de zone soient ouvertes (la vanne de dérivation doit être fermée). Étiquetez tous les panneaux électriques. Allumez SEULEMENT le disjoncteur de commande à 15 amp. La pompe devrait fonctionner. Notez la lecture de pression sur la décharge de pompe. Diminuez le réglage de chaque thermostat de zone pour fermer la vanne de zone correspondante. Ajustez la soupape d'équilibre correspondante pour maintenir la pression de décharge de la pompe. La pression de décharge de la pompe devrait rester la même quand toutes les zones sont en dérivation ou quand toutes les zones sont ouvertes ou toute combinaison de vannes ouvertes et fermées. (Voir Figure 4 et 5).

Équilibrage multizone

La dérivation indiquée doit être ajustée pour qu'une quantité suffisante d'eau puisse circuler dans la chaudière quand toutes les vannes de zone sont fermées. (Voir Figure 4.) Une dérivation est obligatoire sur un système de circulation constante qui utilise des vannes de zone, si aucune boucle libre ne fait partie du système. La ligne de dérivation permettra d'éviter l'endommagement du circulateur causé par un circulateur fonctionnant sur la tête.

Dérivation



Monitron™ S2


CHAUDIERE ELECTRIQUE MODELE-EH

De EH-08-135-S2 à EH-40-135-S2, monophasé, 3 fils, 120/208V, 120/240V
De EH-12-345-S2 à EH-40-345-S2, triphasé, à 4 fils, 120/208V, 120/240V

INSTRUCTIONS D'UTILISATION ET D'INSTALLATION

TABLE DES MATIERES PAGE

Description	2
Montage	2
Tuyauterie	2
Eliminateur d'air et vases d'expansion	2
Limiteur de débit	2
Dérivation	2
Cablage	2
Limiteur de débit du thermostat mural et diffuseur	2
Cablage typique	2
Connexions de service et caractéristiques électriques	2
Dimensions approximatives	3
Caractéristiques électriques	4
Tuyauterie typique	5
Cablage typique des vannes de zone	6
Démarrage	7
Système de remplissage	7
Elimination d'air	7
Ajustement du débit de dérivation	7
Vérification du bon fonctionnement de la chaudière et du système	7
Fonctionnement (modèles équipés de système de contrôle de séq.)	7
Inspection périodique	7
Annexes A, B, C et D	8



IMPORTANT :
Le manuel doit être laissé au propriétaire et devrait être accroché soit sur la chaudière soit à côté de la chaudière pour toute référence ultérieure.

Schéma de câblage situé à l'intérieur du panneau avant.